

85-17D

Public Service
Electric and Gas
Company

Corbin A. McNeill, Jr.
Vice President -
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

October 8, 1985

Dr. Thomas E. Murley, Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Dr. Murley:

QUALITY ASSURANCE PROGRAM DESCRIPTION
SALEM GENERATING STATION
UNITS NOS. 1 AND 2
DOCKET NOS. 50-272 AND 50-311

Mr. Robert Winters of your staff identified two areas requiring clarification during a telephone conversation on September 26, 1985, between Messrs. C. P. Johnson and W. R. Schultz of my staff. The required clarification, as provided herein, was reviewed with Mr. Winters by Mr. W. Schultz on October 4, 1985, and was found to be acceptable. These clarifications will be incorporated in the next UFSAR change.

Paragraph 17.2.2 page 17.2-10 The revised section will be clarified to read: "Personnel requiring certification in accordance with Regulatory Guide 1.58 are limited to and members of the Operational Test Group (OTG) who perform post-design modification testing. Personnel who perform visual examination in accordance with the Inservice Inspection Program are trained and certified in accordance with a program which meets the intent of SNT-TC-1A and ASME Section XI.

Paragraph 17.2.5, page 17.2-20 The last paragraph will be clarified to read: "The SQAE reviews and approves selected station inspection plans and procedures for test, calibration, maintenance, modification and repair for designation of QA holdpoints in accordance with the criteria established in section 17.2.10".

Sincerely,



8510220270 851008
PDR ADDCK 05000272
P PDR

C (See attached page)

9001
110

C Mr. Donald C. Fischer
Licensing Project Manager

Mr. Thomas Kenny
Senior Resident Inspector

RECEIVED-REGION 1

1985 OCT 15 PM 2:33