

Public Service
Electric and Gas
Company

Corbin A. McNeill, Jr.
Vice President -
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

March 5, 1986

NLR-N86023

Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20014

Attention: Mr. Steven A. Varga, Director
PWR Project Directorate #3
Division of PWR Licensing A

Gentlemen:

LOW-LOW STEAM GENERATOR LEVEL SETPOINTS
FACILITY OPERATING LICENSES DPR-70 AND DPR-75
SALEM GENERATING STATION
UNIT NOS. 1 AND 2
DOCKET NOS. 50-272 AND 50-311

Pursuant to our telephone conversation with Mr. D. C. Fischer, of your staff, on February 10, 1986, this letter confirms and corrects an administrative error within the Salem Unit Nos. 1 and 2 Technical Specifications. The correction involves the Low-Low Steam Generator Level setpoint, which has inputs to two functions: Reactor Trip and Auxiliary Feedwater Pump Start.

In Technical Specifications Table 2.2-1, Reactor Trip System Instrumentation Trip Setpoints, the Low-Low Steam Generator Level trip setpoints were revised by Amendments 53 and 21 for Salem Units 1 and 2 respectively as requested in our License Change Request, LCR 83-06, dated May 4, 1983. However, the same setpoints in Table 3.3-4, Engineered Safety Feature Actuation System Instrumentation Trip Setpoints, for start of the Auxiliary Feedwater Pumps, were inadvertently omitted from our License Change Request.

As we have been advised that this correction may be made without the submittal of an additional amendment request, we have enclosed corrected pages to the Salem Technical Specifications for disposition as you deem appropriate.

8603110480 860305
PDR ADOCK 05000272
P PDR

Acc 11

Mr. Steven A. Varga

-2-

3-5-86

If you have any questions, please let us know.

Sincerely,



Attachments

C Mr. Donald C. Fischer
Licensing Project Manager

Mr. Thomas J. Kenny
Senior Resident Inspector