

Public Service
Electric and Gas
Company

Corbin A. McNeill, Jr.
Vice President -
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

September 24, 1986
NLR-N86130

United States Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Washington, DC 20555

Attention: Mr. Steven A. Varga, Director
PWR Project Directorate #3
Division of PWR Licensing A

Gentlemen:

INSERVICE TESTING PROGRAM REVISIONS
(RE: LER 86-002-00)
SALEM GENERATING STATION
UNIT NOS. 1 AND 2
DOCKET NOS. 50-311 AND 50-272

In accordance with the commitments made in LER 86-002-00, PSE&G hereby transmits Revision 4 to the Salem Unit No. 1 Inservice Testing (pump and valve) Program and Revision 3 to the Salem Unit No. 2 Inservice Testing Program. These documents supersede those previously transmitted on December 31, 1985 and January 28, 1986, respectively. These programs will be in effect within 30 days; at which time procedures will be approved and in place.

These submittals are the result of an extensive review of systems and components required to place and maintain the reactors in a safe shutdown condition. The following is a summary of the types of changes made to the programs as a result of the reviews:

1. No changes were made to the pump testing programs.
2. Valves were added and deleted as appropriate.
3. Relief requests for valves were deleted, modified or added based on the guidance provided by the NRC SER on this subject dated April 12, 1983.
4. We have maintained the relief requests to incorporate 90 day frequency for pump testing, deletion of all Category E valves and incorporation of the passive valve concept as described in later NRC approved editions of ASME Section XI.

8610060172 860924
PDR ADDCK 05000272
P PDR

Limited Distribution

A047
1/1

Mr. Steven A. Varga

2

9/24/86

Also, in accordance with the LER commitments, initial training was completed for personnel in our Operations Staff, ISI Staff and QA Staff.

Sincerely,

A handwritten signature in black ink, appearing to read "C. A. W." followed by a long horizontal flourish.

Attachments

C Mr. Donald C. Fischer
Licensing Project Manager

Mr. Thomas J. Kenny
Senior Resident Inspector