

**HOPE CREEK No 1
GENERATOR OPERATING GUIDE**

FEBRUARY 1986

REPORT No. 36.86.2

PREPARED BY

**SYSTEM PLANNING DEPARTMENT
TRANSMISSION PLANNING DIVISION**

**JOHN POPOVICH
ROCCO A LABATO
VIET T NGUYEN**

J. D. Helson, Jr.
MANAGER - TRANSMISSION PLANNING

8704070345 870403
PDR ADOCK 05000272
P PDR

TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION	1
OBJECTIVE	1
RESULTS	2
Single Unit Operation - Hope Creek No. 1	3
Two Unit Operation - Hope Creek No. 1 and Salem No. 1 or 2	4
Three Unit Operation - Hope Creek No. 1 and Salem No. 1 and 2	5
Exhibit 1 - 1987 500-kV Transmission - Vicinity Hope Creek and Salem	6
Exhibit 2 - Summary Tabulation Single Unit Operation	7
Exhibit 3 - Summary Tabulation Two Unit Operation	8
Exhibit 4 - Summary Tabulation Three Unit Operation	9
DISCUSSION	
Power Flow Assumptions and Simulations	10
Transient Stability Analysis	13
1. Machine Representation	13
2. Generator Terminal Representation	14
3. System Load Representation	14
4. Stability Simulations	15
a. all transmission in service	16
b. 500-kV transmission maintenance outages	17
c. 500-kV circuit breaker maintenance outages	18
d. 75% of peak and 100% peak load	18
e. 500-kV transmission line reclosure	19
f. 500-kV transmission line tripping and reclosure	20
g. generating unit tripping	21
h. 1 ϕ fault with breaker failure	22

TABLE OF CONTENTS (CONT'D.)

	<u>Exhibit</u>
<u>APPENDIX</u>	
1. Generator Capability Curves	
. Single Unit Operation - Hope Creek	5-9
. Two Unit Operation	
- Hope Creek	10-13
- Salem 1	14-17
- Salem 2	18-21
. Three Unit Operation	
- Hope Creek	22-28
- Salem 1	29-35
- Salem 2	36-42
2. Power Flow Simulations	
. 40% of Peak Load - single, two and three unit	
Single Unit Operation	
Case Listing	43
Power Flow Simulation System Summary - Base Case	44
Power Flow Transcriptions	45-52
Two Unit Operation	
Case Listing	53
Power Flow Simulation System Summary - Base Case	54
Power Flow Transcriptions	55-62
Three Unit Operation	
Case Listing	63
Power Flow Simulation System Summary - Base Case	64
Power Flow Transcriptions	65-72
. 75% of Peak Load	
Power Flow Simulation System Summary	73
Power Flow Transcription	74
. 100% of Peak Load	
Power Flow Simulation System Summary	75
Power Flow Transcription	76

TABLE OF CONTENTS (CONT'D.)

Exhibit

APPENDIX (cont'd.)

3. Stability Curves - Power Vs. Rotor Angle and
Rotor Angle Vs. Time

Single Unit Operation

- | | |
|--|-------|
| a. All Transmission In Service | 77 |
| b. 500-kV Transmission Maintenance Outages | 78-84 |

Two Unit Operation

- | | |
|--|-------|
| a. All Transmission In Service | 85 |
| b. 500-kV Transmission Maintenance Outages | 86-92 |

Three Unit Operation

- | | |
|---|---------|
| a. All Transmission In Service | 93 |
| b. 500-kV Transmission Maintenance Outages | 94-100 |
| c. Hope Creek Circuit Breaker Maintenance Outages | 101-102 |
| d. 75% of Peak and 100% Peak Load | 103-104 |
| e. 500-kV Transmission Line Reclosure | 105-107 |
| f. 500-kV Transmission Line Trip and Reclosure | 108 |
| g. Generating Unit Trip | 109-110 |
| h. 1 ϕ Fault With Breaker Failure | 111-114 |

4. Simulation Modifications - PE, DPL and AE

5. Scope and Procedure

6. Transient Stability Simulation - Machine Data

INTRODUCTION

This Operating Guide has been prepared for the operation of the Hope Creek Generating Unit No. 1 in conjunction with the operation of Salem Generating Units Nos. 1 and 2 for the following operating combinations:

1. Single Unit - Hope Creek No. 1 alone, i.e. no Salem units
2. Two Unit - Hope Creek No. 1 and one Salem unit
3. Three Unit - Hope Creek No. 1 and Salem Nos. 1 and 2

OBJECTIVE

The objective of this analysis was to provide a generator operating guide for Hope Creek No. 1 unit. The Operating Guide has been prepared to provide guidance to the PSE&G System and Hope Creek and Salem Generating Station operators, based on stability consideration for various system conditions. This guide is in the form of tables and curves which specify operating limits in terms of unit and system imposed restrictions.

RESULTS

The results of this analysis are in the form of a summary tabulation and generator capability curves for each of the three operating combinations of Hope Creek No. 1 and Salem Nos. 1 and 2, specified in the Introduction for various system conditions.

The summary tabulation lists for each of the three generator operating combinations; the maximum MW, minimum MVAR and resultant generator terminal and 500-kV bus voltage conditions for the Hope Creek and Salem generating units (see Exhibits 2, 3 and 4). These constraints are necessary to maintain generator stability following the critical fault condition for various transmission system configurations. This analysis observed a maximum generator terminal bus voltage of 1.05 pu and a maximum generator step-up transformer high side voltage of 1.10 pu.

The conditions which impact generator operability are; the 500-kV transmission configuration (Exhibit 1), system and generator terminal voltages and system generation dispatch, i.e. MW level of generator output and the number of generators running in the area being studied. Therefore, the guide was prepared using a 40% of peak load case dispatched for a minimum generation schedule. Critical cases were tested at the 75% and 100% of peak load level.

In addition to each summary tabulation, a set of generator capability curves showing the Hope Creek and Salem operating limitations for each operating combination appears in Appendix 1, Exhibits 5 to 42. These exhibits are the manufacturers' machine design capabilities on which are superimposed stability and voltage constraints for probable system transmission configurations.

Single Unit Operation - Hope Creek No. 1

Based on the analysis performed, there are no stability limits requiring generation MW output reduction of the Hope Creek No. 1 unit when the Salem No. 1 and 2 units are out of service. This is true for the following conditions and at all load levels:

- . all transmission in-service
- . maintenance outage of any one of the following 500-kV lines;
 - Salem-Deans (5021)
 - Hope Creek-Salem (5037)
 - Keeney-Peach Bottom (5014)
 - Salem-New Freedom (5024)
 - Hope Creek-New Freedom (5023)
 - Deans-Branchburg (5019)
- . maintenance outage of any one Hope Creek 500-kV circuit breaker; 50X, 51X, 52X, 60X or 61X

The minimum MVAR absorptive capability limit for the Hope Creek machine in all but one case is determined by the minimum generator terminal bus voltage of .95 pu. However, for the unavailability of the Hope Creek-Keeney (5015) 500-kV line transient stability considerations require a 0 MVAR minimum output with the Hope Creek unit at full MW output. Also, terminal voltage values listed in Exhibit 2 should be observed.

The single unit Hope Creek results are in the summary tabulation, Exhibit 2. The corresponding capability curves are in Appendix 1, Exhibits 5 to 9. The corresponding Power Vs. Rotor Angle and Rotor Angle Vs. Time curves for Hope Creek No. 1 are shown in Appendix 3, Exhibits 77 to 84.

Two Unit Operation - Hope Creek No. 1 and Salem No. 1 or 2

The operation of two units was analyzed and appropriate limits were determined for the Hope Creek unit running with one of the two Salem units. There were no MW reductions from full output required for operation of two units for the following conditions:

- . all transmission in service

- . maintenance outage of any one of the following 500-kV lines:
 - Hope Creek-Salem (5037)
 - Keeney-Peach Bottom (5014)
 - Salem-New Freedom (5024)
 - Hope Creek-New Freedom (5023)
 - Deans-Branchburg (5019)

- . maintenance outage of any one Hope Creek 500-kV circuit breaker; 50X, 51X, 52X, 60X or 61X.

Two 500-kV line maintenance outages, the Hope Creek-Keeney 500-kV line and the Salem-Deans 500-kV line, require a reduction from full MW output of the Hope Creek unit and the single Salem unit. A MW reduction is necessary to maintain transient stability even though the generating units have not reached their maximum MVAR capability. The maximum MVAR output is limited by the system voltage. These results are in the two unit summary tabulation, Exhibit 3. The corresponding capability curves are in Appendix 1, Exhibits 10 to 21. The corresponding Power Vs. Rotor Angle and Rotor Angle Vs. Time curves for Hope Creek No. 1, Salem No. 1 and No. 2 are shown in Appendix 3, Exhibits 85 to 92.

Three Unit Operation - Hope Creek No. 1 and Salem No. 1 and 2

The operation of all three units was analyzed and appropriate limits were determined for each unit. There were no MW reductions required for operation of three units for the following conditions; however, reactive output ranging from 125 to 300 MVAR was required to maintain stability:


- . all transmission in service

- . maintenance outage of any one of the following 500-kV lines;
 - Keeney-Peach Bottom (5014)
 - Salem-New Freedom (5024)
 - Hope Creek-New Freedom (5023)
 - Deans-Branchburg (5019)

- . maintenance outage of any one Hope Creek 500-kV circuit breaker 50X, 51X, 52X, 60X or 61X.

Two 500-kV line maintenance outages, the Hope Creek-Keeney or the Salem-Deans, require a reduction from full MW output of all three units. In addition, the maintenance outage of the Hope Creek-Salem 500-kV line requires a reduction from full MW output of Salem units only. With the tie between Hope Creek 500-kV bus and Salem 500-kV bus unavailable, the 500-kV bus voltages are not equal, thus permitting the higher Hope Creek MVAR output needed to maintain stability without a MW reduction.

The corresponding MW reductions, MVAR reactive output requirements and resultant terminal and 500-kV voltages appear in the three unit summary tabulation, Exhibit 4. The three unit generator capability curves for Hope Creek No. 1 and Salem Nos. 1 and 2 appear in Appendix 1, Exhibits 22 to 42. The corresponding Power Vs. Rotor Angle and Rotor Angle Vs. Time curves for Hope Creek No. 1 are shown in Appendix 3, Exhibits 93 to 100.



1987 PJM 500-KV SYSTEM
VICINITY OF HOPE CREEK AND SALEM
GENERATING AND SWITCHING STATIONS

DEC 1986

Summary of Hope Creek/Salem Limits - Single Unit Operation

Hope Creek No. 1 With Salem No. 1 and Salem No. 2 Not Running

500-kV Transmission System Configuration Maintenance Outage	Hope Creek and Salem Generator Terminal and 500-kV Conditions - 40% of Peak Load						
	Critical 3 ϕ Faulted Line ⁽¹⁾	Maximum MW	Minimum ⁽²⁾ MVAR	Terminal Voltage - PU ⁽³⁾	500-kV Voltage - PU ⁽³⁾	Case ⁽⁴⁾ No.	Reference ⁽⁵⁾ Exhibits
None - All Transmission In Service	Hope Creek-Keeney	1100	-75	.95	1.06	SIBASE	5,77
Hope Creek-Keeney	Salem-Deans	1100	0	.98	1.08	SIM1	6,78
Salem-Deans	Hope Creek-Keeney	1100	0	.95	1.05	SIM5	8,82
Hope Creek-Salem	Hope Creek-Keeney	1100	0	.96	1.06	SIM3	8,80
Salem-New Freedom	Hope Creek-Keeney	1100	-50	.95	1.06	SIM4	7,81
Hope Creek-New Freedom	Hope Creek-Keeney	1100	-50	.95	1.06	SIM2	7,79
Keeney-Peach Bottom	Salem-Deans	1100	-125	.95	1.08	SIM6	9,83
Deans-Branchburg	Hope Creek-Keeney	1100	-75	.95	1.07	SIM7	5,84
Hope Creek CB - 50X 51X 52X 60X 61X	Hope Creek-Keeney Hope Creek-Salem Hope Creek-Keeney Hope Creek-N. Freedom Hope Creek-Salem	1100	0	.96	1.07	-	8

(1) Fault applied to the "from" end of line

(2) Negative values indicate leading reactive machine output

(3) Terminal and 500-kV bus voltages are a result of system conditions and Hope Creek MVAR output and step-up transformer tap setting of 1.092.

(4) Case number reference Appendix 2 Rotor Angle Vs. Time Curves

(5) Reference Exhibits; Appendix 1 Generator Capability Curves, Appendix 2 Rotor Angle Vs. Time Curves

EXHIBIT 2

Summary of Hope Creek/Salem Limits - Two Unit Operation

Hope Creek No. 1 With Salem No. 1 or Salem No. 2 Running

500-kV Transmission System Configuration Maintenance Outage	Critical 3φ Faulted Line ⁽¹⁾	Hope Creek and Salem Generator Terminal and 500-kV Conditions - 40% of Peak Load									
		Maximum MW		Minimum MVAR ⁽²⁾		Terminal Voltage - PU ⁽³⁾		500-kV Voltage - PU ⁽³⁾		Case ⁽⁴⁾ No.	Reference ⁽⁵⁾ Exhibits
		HC 1	Salem 1 or 2	HC 1	Salem 1 or 2	HC 1	Salem 1 or 2	HC	Salem		
None - All Transmission In Service	Hope Creek-Keeney	1100	1123/1162	0	0	.95	.95	1.05	1.05	S2BASE	10,14,18,85
Hope Creek-Keeney	Salem-Deans	950	973/1012	125	125	1.01	1.01	1.10	1.10	S2H1	11,15,19,86
Salem-Deans	Hope Creek-Keeney	900	923/962	225	225	1.03	1.03	1.10	1.10	S2H5	12,16,20,90
Hope Creek-Salem	Salem-Deans	1100	1123/1162	0	0	.95	.95	1.05	1.05	S2H3	10,14,18,88
Salem-New Freedom	Hope Creek-Keeney	1100	1123/1162	50	50	.96	.96	1.05	1.05	S2H4	13,17,21,89
Hope Creek-New Freedom	Hope Creek-Keeney	1100	1123/1162	50	50	.96	.96	1.05	1.05	S2H2	13,17,21,87
Keeney-Peach Bottom	Salem-Deans	1100	1123/1162	0	0	.95	.95	1.06	1.06	S2H6	10,14,18,91
Deans-Branchburg	Hope Creek-Keeney	1100	1123/1162	0	0	.95	.95	1.05	1.05	S2H7	10,14,18,92
Hope Creek CB - 50X	Hope Creek-Keeney	1100	1123/1162	0	0	.95	.95	1.05	1.05	-	10,14,18
51X	Hope Creek-Salem	1100	1123/1162	50	50	.96	.96	1.06	1.06	-	13,17,21
52X	Hope Creek-Keeney	1100	1123/1162	0	0	.95	.95	1.05	1.05	-	10,14,18
60X	Hope Creek-N. Freedom	1100	1123/1162	50	50	.96	.96	1.06	1.06	-	13,17,21
61X	Hope Creek-Salem	1100	1123/1162	50	50	.96	.96	1.06	1.06	-	13,17,21

(1) Fault applied to the "from" end of line

(2) Negative values indicate leading reactive machine output

(3) Terminal and 500-kV bus voltages are a result of system conditions and Hope Creek and Salem MVAR output and step-up transformer tap setting of 1.092.

(4) Case number reference Appendix 2 Rotor Angle Vs. Time Curves

(5) Reference Exhibits; Appendix 1 Generator Capability Curves, Appendix 2 Rotor Angle Vs. Time Curves

Summary of Hope Creek/Salem Limits - Three Unit Operation

Hope Creek No. 1 With Salem No. 1 and No. 2 Running

500-kV Transmission System Configuration Maintenance Outage	Critical 3 ϕ Faulted Line ⁽¹⁾	Hope Creek and Salem Generator Terminal and 500-kV Conditions - 40% of Peak Load											Case ⁽⁴⁾ No.	Reference ⁽⁵⁾ Exhibits
		Maximum MW			Minimum MVAR ⁽²⁾			Terminal Voltage - PU ⁽³⁾			500-kV Voltage - PU ⁽³⁾			
		HC 1	Salem 1	Salem 2	HC 1	Salem 1	Salem 2	HC 1	Salem 1	Salem 2	HC	Salem		
None - All Transmission In Service	Hope Creek-Keeney	1100	1123	1162	200	200	200	1.01	1.01	1.01	1.08	1.08	S3BASE	22,29,36,93
Hope Creek-Keeney	Salem-Deans	800	823	862	125	125	125	1.02	1.02	1.02	1.10	1.10	S3M1	23,30,37,94
Salem-Deans	Hope Creek-Keeney	800	823	862	200	200	200	1.03	1.03	1.03	1.10	1.10	S3M5	24,31,38,95
Hope Creek-New Freedom	Hope Creek-Keeney	1100	1123	1162	275	275	275	1.03	1.03	1.03	1.09	1.09	S3M2	25,32,39,96
Hope Creek-Salem	Salem-Deans	1100	1073	1112	300	225	225	1.03	1.03	1.03	1.09	1.10	S3M3	26,33,40,97
Salem-New Freedom	Hope Creek-Keeney	1100	1123	1162	250	250	250	1.02	1.02	1.02	1.09	1.09	S3M4	27,34,41,98
Keeney-Peach Bottom	Salem-Deans	1100	1123	1162	225	225	225	1.03	1.03	1.03	1.10	1.10	S3M6	28,35,42,99
Deans-Branchburg	Hope Creek-Keeney	1100	1123	1162	225	225	225	1.02	1.02	1.02	1.09	1.09	S3M7	28,35,42,100
Hope Creek CB - 50X	Hope Creek-Keeney	1100	1123	1162	275	275	275	1.04	1.04	1.04	1.10	1.10	S3CB1	25,32,39,101
51X	Hope Creek-Salem	1100	1123	1162	250	250	250	1.03	1.03	1.03	1.10	1.10	S3CB2	27,34,41,102
52X	Hope Creek-Keeney	1100	1123	1162	250	250	250	1.03	1.03	1.03	1.10	1.10	S3CB2	27,34,41,102
60X	Hope Creek-New Freedom	1100	1123	1162	275	275	275	1.04	1.04	1.04	1.10	1.10	S3CB1	25,32,39,101
61X	Hope Creek-Salem	1100	1123	1162	250	250	250	1.03	1.03	1.03	1.10	1.10	S3CB2	27,34,41,102

(1) Fault applied to the "from" end of line

(2) Negative values indicate leading reactive machine output

(3) Terminal and 500-kV bus voltages are a result of system conditions and Hope Creek and Salem MVAR output and step-up transformer tap setting of 1.092

(4) Case number reference Appendix 2 Rotor Angle Vs. Time Curves

(5) Reference Exhibits; Appendix 1 Generator Capability Curves, Appendix 2 Rotor Angle Vs. Time Curves

DISCUSSION

Power Flow Assumptions and Simulations

An updated version of the 1987 Hope Creek MAAC Filing base case power flow was used to develop simulations for the 100%, 75% and 40% of peak load conditions. This was done to establish the voltage and power flow patterns for the 500-kV transmission system in the vicinity of Hope Creek and Salem Generating Station.

- The 100% peak load level PJM case was economically dispatched, with a PJM economy import of 3000 MW.
- The 75% of peak load level PJM case was economically dispatched, with a PJM economy import of 3600 MW.
- The 40% of peak load level PJM case was economically dispatched, with a PJM economy import of 1000 MW.

The net base interchange for the three load levels was modelled as follows:

<u>Unit Name</u>	<u>Unit MW Capability</u>	<u>CEI/NYSEG Share - MW</u>	<u>MW Export - Load Level</u>		
			<u>Peak</u>	<u>75%</u>	<u>40%</u>
Homer City 1	620	310	310	310	310
Homer City 2	614	307	0*	0*	0*
Homer City 3	650	325	325	325	325
Seneca	390	304	304	164**	-343***
Load in GPU Served by NYPA			-107	-100	-60
			832	699	232
Base Economy Import (-)			-3,000	-3,600	-1,000
Net Base Interchange			-2,168	-2,901	-768

*Unit assumed out-of-service
 **Capacity reduction due to water level
 ***Pumping load (343 MW CEI, 105 MW GPU)

The PJM generating units were dispatched without EFOR deration. Generator unavailability was accounted for by discrete outages, primarily on the 500-kV system. The combination of one Peach Bottom unit and one Susquehanna unit out of service was assumed as the most critical 500-kV unit outage combination. In addition, the following is a listing of some of the underlying generators assumed out of service:

- . Three Mile Island No. 1
- . Martins Creek Nos. 3 and 4
- . Eddystone Nos. 3 & 4
- . Indian River No. 2
- . Homer City No. 2
- . Sewaren No. 2
- . Linden No. 2

The PJM 500-kV and 230-kV switched capacitors were modelled explicitly. The capacitors were switched on for the 100% and 75% of peak load levels and switched off for the 40% of peak load level.

A Power Flow Simulation System Summary and 500-kV power flow transcription for each of the the following base case power flow simulations are included as exhibits and in Appendix 2.

Base Case - Power Flow Simulation

- 40% of peak load - 1 unit - Hope Creek
- 2 units - Hope Creek/Salem
- 3 units - Hope Creek/Salem
- 75% of peak load - 3 units - Hope Creek/Salem
- 100% peak load - 3 units - Hope Creek/Salem

In addition, a 500-kV power flow transcription corresponding to each of the 500-kV transmission maintenance outages is also provided in Appendix 2 (see case listings Exhibit 43, 53 and 63).

At the invitation of PSE&G, modifications to generation dispatch data, power flow simulation representation and transient stability data were submitted by Philadelphia Electric Company, Delmarva Power and Light Company, and Atlantic City Electric Company. In addition, General Public Utilities provided several data revisions. A description of these changes is summarized in Appendix 4.

Transient Stability Analysis

The transient stability analysis employed the TRANSTAB program to assess the stability of the system and the performance of the Hope Creek and Salem units. The major portion of the analysis involved the development of generator MW, MVAR and voltage limits for each of the three unit operating combinations, i.e. number of Hope Creek and Salem units running corresponding to the 40% of peak load level. The limits to unit operation refer to those constraints required to maintain stability following critical contingencies with the pre-contingency transmission system configured with all facilities in-service and with selected transmission lines and circuit breakers scheduled out of service for maintenance.

1. Machine Representation

The transient stability analysis was based on the most current and appropriate generator unit and unit step-up transformer data used by PJM. This data is defined by the following and appears in Appendix 6.

a. PJM Units

- . synchronous rotor data
- . excitation system data
- . governor system data

b. Individual Outside World Units - represented with synchronous rotor data.

c. Equivalent Outside World Units - buses without specific machine data available. A classical representation was developed based on a "unit machine" concept for which the number of unit machines on a bus would be a function of the total net MW generation (generation minus load)

on an equivalent bus divided by the MW size of the unit machine, i.e. 400 MW. For example, a bus having a net 2000 MW of generation has data developed for five machines based on a unit machine of 400 MW.

2. Generator Terminal Representation

The following generator terminal buses were simulated in detail, i.e. the unit MW and MVAR gross output and auxiliary load represented explicitly. These loads were represented on the appropriate generator terminal or 500-kV bus, or distributed between the two.

<u>Generator Name</u>	<u>Gross MW Output</u>	<u>Auxiliary Load</u>	
		<u>MW</u>	<u>(MVAR)</u>
Hope Creek No. 1	1100	33.0	(25.0)
Salem No. 1	1123	39.0	(29.0)
Salem No. 2	1162	39.0	(29.0)
Peach Bottom No. 2	1091	29.0	(14.1)
Keystone No. 1	880	33.5	(29.0)
Keystone No. 2	880	33.5	(29.0)
Conemaugh No. 1	880	26.0	(16.0)
Conemaugh No. 2	880	20.0	(14.0)
Limerick No. 1 (230 kV)	1093	36.5	(17.7)

All other PJM and outside world generators were represented by a net MW and MVAR output with no auxiliary loads simulated.

3. System Load Representation

The simulation of system load was:

- a. MW load represented by constant current model;
- b. MVAR load represented by constant impedance model.

4. Stability Simulations

Stability simulations were made for each of the three operating combinations with the Hope Creek and Salem units at full MW output. The system was tested with the following transmission configurations:

- . all transmission in-service
- . various 500-kV line maintenance outages
- . various Hope Creek 500-kV circuit breaker maintenance outages

for two types of fault conditions:

- . 3 ϕ fault with primary clearing of 3.5 cycles
- . 1 ϕ fault with breaker failure protection, ie. 3.5 cycles primary clearing plus an additional 4.5 cycles for a total back up clearing time of 8.0 cycles. A short circuit analysis was done in order to determine the impedances needed to simulate the unbalanced fault conditions.

It should be noted that the Power Vs. Rotor Angle curves in Appendix 3 are for either the Hope Creek or Salem units. These are representative of the response of the Salem No. 1 and 2 units when running. This is true for all cases except those that deal with the Hope Creek-Salem (5037) 500-kV line in terms of either an unscheduled or scheduled outage. With this line in-service, the Hope Creek and Salem 500-kV buses can be considered as one. With this line out-of-service or involved in a switching scenario, the Hope Creek and Salem 500-kV busses are electrically about 90 miles apart and this is evident as seen in the Rotor Angle Vs. Time curve of Exhibits 88 and 96.

a. Stability simulation for all transmission in-service:

- . fault at Hope Creek end of Hope Creek-Keeney (5015) 500 kV
- . fault at Hope Creek end of Hope Creek-New Freedom (5023) 500 kV
- . fault at Hope Creek end of Hope Creek-Salem (5037) 500 kV
- . fault at Salem end of Salem-Deans (5021) 500 kV
- . fault at Salem end of Salem-New Freedom (5024) 500 kV
- . fault at Peach Bottom end of Peach Bottom-Keeney (5014) 500 kV

The results of this analysis document only the most critical case, i.e. most limiting or restrictive MW, MVAR and voltage conditions for each fault tested. The minimum MVAR output of the Hope Creek and Salem units was determined with the units operating within voltage constraints on the generator terminal, 230-kV and 500-kV system buses. The voltage constraint was to maintain a pre-contingency voltage within +5% of nominal on generator terminal and system 230-kV buses and within +10% on 500-kV buses. This recognizes that the allowable voltage rise for a post-contingency condition for a 230-kV bus would be an additional 5%. Further, the allowance of the 500-kV voltages as high as 110% is conditioned upon post-contingency voltages on the 500-kV system not exceeding 110% following any single contingency.

If any simulation was unstable for a particular set of generator output conditions, the MVAR output was increased until stability was attained. If however a limitation was reached, either generator MVAR output, system or generator terminal bus voltage, and the simulation remained unstable, the Hope Creek and Salem MW output was reduced until stability was attained.

b. Stability simulations with 500-kV transmission maintenance outages:

The fault analysis procedure described in section 4a above was applied to power flow simulations of the 500-kV transmission maintenance outages. This included Hope Creek and Salem Switching Station outlets and lines emanating from the next station beyond, i.e. Deans and Keeney, as follows:

- . Hope Creek-Keeney (5015)
- . Hope Creek-New Freedom (5023)
- . Hope Creek-Salem (5037)
- . Salem-New Freedom (5024)
- . Salem-Deans (5021)
- . Keeney-Peach Bottom (5014)
- . Deans-Branchburg (5019)

The operating constraints with these scheduled outages were determined, with regard to generator MW and MVAR output, generator unit terminal voltage, and 230-kV and 500-kV system voltage conditions.

c. Stability simulations with Hope Creek 500-kV circuit breaker maintenance outages:

The analysis in this section was limited to a 3 ϕ fault condition cleared in primary time. The following tabulation indicates for each Hope Creek circuit breaker outage, the critical line faulted and the additional line outaged resulting from bus sectionalizing and isolation following primary clearing. It was determined that a minimum reactive output of from 250 to 275 MVAR from each of the Hope Creek and Salem units was required (see Exhibit 4).

Hope Creek 500-kV Circuit Breaker (CB) Maintenance Outage

<u>CB #</u>	<u>500-kV Faulted Line</u>		<u>Additional Line Outaged by Becoming Isolated</u>		<u>Remaining Hope Creek Outlet</u>
	<u>Name*</u>	<u>Desig.</u>	<u>Name</u>	<u>Desig.</u>	
50X	HC-KNY	5015	HC-NF	5023	HC-SLM
51X	HC-SLM	5037	HC-KNY	5015	HC-NF
52X	HC-KNY	5015	HC-SLM	5037	HC-NF
60X	HC-NF	5023	HC-KNY	5015	HC-SLM
61X	HC-SLM	5037	HC-KNY	5015	HC-NF

*Fault on HC end of line
 HC - Hope Creek
 NF - New Freedom
 SLM - Salem
 KNY - Keeney

d. Stability simulation for the 75% of peak load and 100% peak load condition:

The condition which results in the most critical maintenance outage case at the 40% of peak load level was also tested in the 75% and 100% of peak load level case. The purpose was to confirm that the operating restrictions that were determined for the 40% of peak load condition remained valid for the higher load level and greater PJM import conditions. The results of the 75% of peak load and 100% peak load

simulations are in the form of Power Vs. Rotor Angle and Rotor Angle Vs. Time curves and are in Appendix 4, Exhibits 103 and 104. These results can be compared with the same critical fault condition tested under the 40% of peak load analysis (see Exhibit 93). It is evident that the simulation for the 40% of peak load condition produced results which were more restrictive in terms of generating unit operation than for either the 75% of peak load or 100% peak load condition.

It should be noted that the MVAR output of the Hope Creek and Salem units was greater in both the 75% of peak load and 100% peak load cases than in the 40% of peak load level case. The higher MVAR output was needed to maintain a voltage on each of the generator terminal buses at 100%. A 225 MVAR output from each of the Hope Creek and Salem machines, as was the case in the 40% of peak load case, would have resulted in a terminal voltage below 100% for the higher load level simulations. The generator terminal bus voltage in the 40% of peak load case was 102%.

e. Stability simulation for transmission line reclosure

Three transient stability simulations were made to demonstrate the impact of reclosing a 500-kV line in the vicinity of the Hope Creek/Salem Generating Station. In each case, the particular line was assumed to be scheduled out of service prior to reclosure. The system was at a steady-state condition prior to line reclosure. These simulations were made prior to the determination of required MW reductions for 500-kV maintenance outage conditions. Therefore, they do not

correspond directly to those cases presented under the 500-kV transmission maintenance outage section (4b) as to generator MW output reductions. However, this does not affect the conclusions reached. The three 500-kV lines were:

- . Hope Creek-Salem (5037)
- . Salem-Deans (5021)
- . Hope Creek-Keeney (5015)

The Power Vs. Rotor Angle and Rotor Angle Vs. Time results indicate that none of the line reclosures had any appreciable impact on generator stability (see Exhibits 105, 106 and 107). It is evident that the magnitude of oscillation is a direct function of the criticalness of the facility being reclosed.

f. Stability simulation for transmission line tripping and reclosure

A stability simulation was made which imposed a three phase fault on the Hope Creek-Keeney (5015) 500-kV line at Hope Creek, cleared the fault in primary time, 3.5 cycles and then reclosed the line after a one second delay. Exhibit 108 shows the Power Vs. Rotor Angle and Rotor Angle Vs. Time curves for this simulation. The Salem No. 2 rotor angle oscillates with diminishing magnitude until attaining steady-state operation near the initial operating rotor angle.

The rotor angle returns along the power curve from its point of maximum swing, 109° ; which corresponds to .6 seconds after the line is tripped. The line is reclosed in an additional .4 seconds which corresponds to a point when the rotor angle

swings back to 72°. The power at this point, i.e. time t-line reclose, is approximately 1160 MW. The magnitude to which the power output rises at time t+ line reclose, is about 1420 MW. It is evident, from the power curve, that reclosing the line in less than 1.0 second results in a greater power output increase for time t+ line reclose. Allowed to go long enough without line reclosure, the rotor angle would reach a steady-state value and this condition then devolves to a simple line reclosure scenario which is discussed previously in section 4e. It is concluded that the pre-Hope Creek line reclosure delay on the Hope Creek-Keeney (5015) 500-kV circuit of 1.0 second remains acceptable after the Hope Creek generating unit is placed in service.

g. Stability simulation for generating unit tripping

Two simulations of the loss of the Hope Creek generating unit were made and the results are shown in Exhibits 109 and 110. Exhibit 109 shows the Power Vs. Rotor Angle and Rotor Angle Vs. Time curves for the Salem No. 2 unit and indicates that there is little impact resulting from simply tripping the Hope Creek unit, i.e. no fault. Further, the Rotor Angle Vs. Time curve for various 500-kV generating units shows only a minimal impact.

The second simulation applied a 3 ϕ fault on the 500-kV terminal of the Hope Creek generator step-up transformer. The fault, along with the Hope Creek generator, was cleared in primary time, 3.5 cycles. The results are shown in Exhibit 110 and indicates that there were no stability related problems.

h. Stability simulation for 1 ϕ fault with breaker failure protection

The analysis of a 1 ϕ fault with breaker failure protection focused on the three unit operating combination. However, a two unit case simulating the same contingency as in the three unit case is presented for comparison. It is evident after comparing the results that the most restrictive operating scenario is the condition of three unit operation and a 3 ϕ fault cleared in primary time.

To simulate the 1 ϕ fault condition, a short circuit analysis was performed to obtain data needed to calculate sequence impedances.

When considering the Hope Creek Switching Station arrangement three fault locations were considered. In each case following primary clearing, the fault remains for an additional 4.5 cycles and causes the additional loss of either;

- . a second 500-kV transmission path, or
- . the Hope Creek generating unit.


In the first case, a 1 ϕ fault was applied to the Hope Creek end of the Hope Creek-Salem (5037) 500-kV line. The three phases of the faulted line were cleared at the Salem terminal in primary time, 3.5 cycles. At Hope Creek, it was assumed that the circuit breaker 52X operated normally but that the pole of circuit breaker 60X corresponding to the faulted phase failed to operate. This allows the fault to continue for an additional 4.5 cycles.


At the end of 8 cycles, breaker failure protection time, circuit breaker 61X at Hope Creek and the appropriate circuit breakers at Keeney, in an additional 2 cycles, operate to isolate the fault. The result of this simulation is shown in Exhibit 111. This result can be compared to the two unit Hope Creek/Salem operating condition shown in Exhibit 112 which is not as severe with application of the same fault simulation. Further, this result can be judged as not as severe as the 40% of peak load case which simulated a 3 ϕ fault with primary clearing, see Exhibit 100.

The second case develops as a result of the application of a 1 ϕ fault on either the Hope Creek-Salem (5037) or Hope Creek-New Freedom (5023) 500-kV line at Hope Creek. In the case of the Hope Creek-Salem line, the pole of circuit breaker 52X, corresponding to the faulted phase failed to operate. This results in the tripping of the Hope Creek generating unit via operation of breaker fault protection and operation of circuit breaker 50X. This result is shown in Exhibit 113. Similarly, a 1 ϕ fault on the Hope Creek-New Freedom (5023) line results in the loss of that line, and failure of the 50X circuit breaker results in the loss of the Hope Creek generating unit with the operation of circuit breaker 52X (see Exhibit 114).

APPENDIX 1


GENERATOR CAPABILITY CURVES







1987 HOPE CREEK 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (SALEM NO. 1 AND NO. 2 OFF)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5015 HOPE CREEK - KEENEY OUT OF SERVICE
 40% OF PEAK LOAD


1332










1987 HOPE CREEK 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (SALEM NO. 1 AND NO. 2 OFF)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5014 KEENEY-PEACH BOTTOM OUT OF SERVICE
 40% OF PEAK LOAD







1987 HOPE CREEK 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (ONE SALEM UNIT RUNNING NO. 1 OR NO. 2)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5015 HOPE CREEK - KEENEY OUT OF SERVICE
 40% OF PEAK LOAD










1987 SALEM 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 RUNNING, SALEM 2 OFF)
 HC'S STEP-UP TRANSFORMER TAP 1.092
 ALL TRANSMISSION IN SERVICE
 OR 5037 HOPE CREEK - SALEM
 OR 5014 KEENEY - PEACH BOTTOM
 OR 5019 DEANS - BRANCHBURG
 OR CIRCUIT BREAKER 50X OR 52 X OUT OF SERVICE
 40% OF PEAK LOAD




1987 SALEM 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 RUNNING, SALEM 2 OFF)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5015 HOPE CREEK - KEENEY OUT OF SERVICE
 40% OF PEAK LOAD










1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 RUNNING, SALEM 1 OFF)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 ALL TRANSMISSION IN SERVICE
 OR 5037 HOPE CREEK - SALEM
 OR 5014 KEENEY - PEACH BOTTOM
 OR 5019 DEANS - BRANCBURG
 OR CIRCUIT BREAKER 50X OR 52 X OUT OF SERVICE
 40% OF PEAK LOAD













1987 HOPE CREEK 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (TWO SALEM UNITS RUNNING (NO. 1 AND NO. 2))
 HC/S STEP-UP TRANSFORMER TAP 1.092
 ALL TRANSMISSION IN SERVICE
 40% OF PEAK LOAD





1987 HOPE CREEK 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (TWO SALEM UNITS RUNNING NO. 1 AND NO. 2)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5015 HOPE CREEK - KEENEY OUT OF SERVICE
 40% OF PEAK LOAD























1987 SALEM 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 2 RUNNING)
 HC/S STEP-UP TRANSFORMER TAP 1.092
 5021 SALEM - DEANS OUT OF SERVICE
 40% OF PEAK LOAD





1987 SALEM 1 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 2 RUNNING)
 HC/S STEP-UP TRANSFORMER TAP 1.092

5023 HOPE CREEK - NEW FREEDOM
 OR CIRCUIT BREAKER 50X 60X OUT OF SERVICE
 40% OF PEAK LOAD












1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 1 RUNNING)
 HC'S STEP-UP TRANSFORMER TAP 1.092
 ALL TRANSMISSION IN SERVICE
 40% OF PEAK LOAD



1987 SALEM 2 OPERATING GUIDE
MINIMUM PERMISSIBLE MVAR GENERATION
(HOPE CREEK 1 AND SALEM 1 RUNNING)
HC S STEP-UP TRANSFORMER TAP 1.092
5015 HOPE CREEK - KEENEY OUT OF SERVICE
40% OF PEAK LOAD





1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 1 RUNNING)
 HC'S STEP-UP TRANSFORMER TAP 1.092
 5021 SALEM - DEANS OUT OF SERVICE
 40% OF PEAK LOAD




1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 1 RUNNING)
 HC/S STEP-UP TRANSFORMER TAP 1.092

5023 HOPE CREEK - NEW FREEDOM
 OR CIRCUIT BREAKER 50X 60X OUT OF SERVICE
 40% OF PEAK LOAD





1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 1 RUNNING)
 HC'S STEP-UP TRANSFORMER TAP 1.092
 5024 SALEM - NEW FREEDOM
 OR CIRCUIT BREAKER 51X, 52X OR 61X
 OUT OF SERVICE
 40% OF PEAK LOAD



1987 SALEM 2 OPERATING GUIDE
 MINIMUM PERMISSIBLE MVAR GENERATION
 (HOPE CREEK 1 AND SALEM 1 RUNNING)
 HC'S STEP-UP TRANSFORMER TAP 1.092
 5014 KEENEY - PEACH BOTTOM
 OR 5019 DEANS - BRANCBURG OUT OF SERVICE
 40% OF PEAK LOAD

APPENDIX 2

POWER FLOW SIMULATIONS

HOPE CREEK OPERATING GUIDE

SINGLE UNIT POWER FLOW CASE LISTING

HOPE CREEK NO. 1 IN-SERVICE SALEM NO. 1 AND 2 NOT RUNNING

<u>EXHIBIT NO.</u>	<u>CASE</u>	<u>DESCRIPTION</u>
45	LBASE	1987 40% SUMMER PEAK LOAD LEVEL PJM IMPORTS = 768 MW PS IMPORTS = 2000 MW NO EFORS (DISCRETE UNIT OUTAGES) - PJM ECONOMIC DISPATCH HOPE CREEK AT FULL MW OUTPUT AND -75 MVAR OUTPUT SALEM NO. 1 AND 2 NOT RUNNING PEACH BOTTOM NO. 3 AND SUSQUEHANNA NO. 2 OUT OF SERVICE BASE CASE - ALL TRANSMISSION IN SERVICE
46	LM1	AS BASE - ONE UNIT AT FULL MW AND 0 MVAR OUTPUT HOPE CREEK-KEENEY 500-KV CIRCUIT (5015) ON MAINTENANCE
47	LM2	AS BASE - ONE UNIT AT FULL MW AND -50 MVAR OUTPUT HOPE CREEK-NEW FREEDOM 500-KV CIRCUIT (5023) ON MAINTENANCE
48	LM3	AS BASE - ONE UNIT AT FULL MW AND 0 MVAR OUTPUT HOPE CREEK-SALEM 500-KV CIRCUIT (5037) ON MAINTENANCE
49	LM4	AS BASE - ONE UNIT AT FULL MW AND -50 MVAR OUTPUT SALEM-NEW FREEDOM 500-KV CIRCUIT (5024) ON MAINTENANCE
50	LM5	AS BASE - ONE UNIT AT FULL MW AND 0 MVAR OUTPUT SALEM-DEANS 500-KV CIRCUIT (5021) ON MAINTENANCE
51	LM6	AS BASE - ONE UNIT AT FULL MW AND -125 MVAR OUTPUT PEACH BOTTOM-KEENEY 500-KV CIRCUIT (5014) ON MAINTENANCE
52	LM7	AS BASE - ONE UNIT AT FULL MW AND 0 MVAR OUTPUT DEANS-BRANCHBURG 500-KV CIRCUIT (5019) ON MAINTENANCE

POWER FLOW SIMULATION - SYSTEM SUMMARY

AREA NAME	GENERATION		INTERCHANGE (EXPORTS)		AREA SYSTEM LOAD		AREA SYSTEM BUS LOAD		AREA SYSTEM LOSSES		AREA CHARGING	AREA STATIC	AREA UNUSED
	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MVAR	MVAR	MVAR
PUBLIC SERVICE ELECTRIC & GAS CO.	1004.	67.	-2127.	696.	3131.	-628.	3103.	301.	28.	-928.	1451.	0.	2363.
PHILADELPHIA ELECTRIC CO.	630.	13.	-1932.	-423.	2562.	436.	2526.	817.	36.	158.	485.	537.	1313.
JERSEY CENTRAL POWER & LIGHT	248.	160.	-1055.	207.	1303.	-48.	1284.	-10.	19.	165.	192.	202.	210.
ATLANTIC ELECTRIC	437.	76.	-156.	28.	593.	48.	587.	186.	7.	-2.	77.	135.	145.
DELMARVA POWER & LIGHT CO.	517.	194.	-193.	220.	710.	-26.	704.	167.	6.	-70.	141.	121.	770.

EASTERN PJM TOTAL	2836.	509.	-5463.	727.	8299.	-218.	8203.	1460.	96.	-677.	2347.	995.	4802.

PENNSYLVANIA ELECTRIC CO.	636.	280.	-67.	150.	703.	130.	672.	144.	32.	-14.	386.	0.	1020.
METROPOLITAN EDISON CO.	208.	91.	-414.	105.	622.	-14.	612.	35.	10.	-3.	115.	46.	108.
PENNSYLVANIA POWER & LIGHT CO.	2718.	-38.	877.	-254.	1841.	216.	1788.	441.	53.	205.	363.	429.	2290.
BALTIMORE GAS & ELECTRIC CO.	387.	346.	-1480.	106.	1867.	240.	1847.	244.	19.	-2.	204.	0.	39.
POTOMAC ELECTRIC CO.	2061.	207.	275.	420.	1786.	-212.	1761.	881.	25.	-528.	977.	563.	2586.

WESTERN PJM TOTAL	6010.	887.	-810.	526.	6820.	361.	6680.	1745.	139.	-342.	2044.	1038.	6042.

TOTAL PJM UNDERLYING	8846.	1396.	-6273.	1253.	15119.	143.	14884.	3205.	235.	-1019.	4391.	2033.	10844.


PJM 500KV	5928.	102.	5471.	556.	457.	-454.	383.	262.	73.	-716.	3283.	0.	2685.

TOTAL PJM SYSTEM	14774.	1498.	-801.	1809.	15575.	-311.	15267.	3467.	308.	-1735.	7674.	2033.	13529.

HOPE CREEK OPERATING GUIDE - 1 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 - 75 MVAR OUTPUT

TRANSMISSION CONDITIONS: 1BASE
 ALL 500-KV CIRCUITS IN SERVICE

1987 PJM 500 KV SYSTEM



230KV SUMMARY

BRANCHB	230	1.033V
DEAMS	230	1.031V
MEM FREE	230	1.020V
SMITHSB	230	1.010V
WHITPAIN	230	1.031V
ALBURYIS	230	1.061V
HOSENBAK	230	1.038V
LIMERICK	230	1.030V
SUSQHNA	230	1.035V
SUNBURY	230	1.061V
WESCOSVL	158	1.030V
KEYSTONE	230	1.039V
JUNIATA	230	1.038V
1 MILE I	230	1.035V
HUNTERTN	230	1.061V
PCH BT	230	1.009V
CONASTN	230	1.034V
BRIGHTON	230	1.032V
HAUGH C	230	1.033V
BURCH HL	230	1.069V
CHALK PT	230	1.040V


GEN TERM BUS

HOPE CREEK	.980V
SALEN G1	.970V
SALEN G2	.970V
PCH BT2	.960V
LIMERICK	230 1.030V
SUSQHNA	100 1.010V
CONERALGH01	.980V
KEYSTONE G1	.980V
CLIFF G1	500 1.014V

NOTES: 1. LINE 1 IS PM
2. LINE 2 IS MVAR

HOPE CREEK OPERATING GUIDE - 1 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 - 75 MVAR OUTPUT


TRANSMISSION CONDITIONS: IBASE
 ALL 500-KV CIRCUITS IN SERVICE



HOPE CREEK OPERATING GUIDE - 1 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT

TRANSMISSION CONDITIONS: LML
 HOPE CREEK-KEENEY 500-KV CIRCUIT
 (5015) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



230KV SUMMARY

BRANCHCOG	230	1.032V
DEANS	2	230 1.031V
NEW FREE	230	1.017V
SMITHBRG	230	1.009V
WHITPAIN	230	1.029V
ALBURYIS	230	1.039V
HOSENSAK	230	1.036V
LINERICK	230	1.030V
SUSQHNA	230	1.035V
SUNBURY	230	1.040V
WESCOSVL	138	1.036V
KEYSTONE	230	1.039V
JUNIATA	230	1.037V
3 MILE I	230	1.033V
HUNTERTN	230	1.040V
PCH BT	230	1.009V

CONASTM	230	1.032V
BRIGHTON	230	1.032V
HAUGH C	230	1.033V
BURCH HL	230	1.049V
CHALK PT	230	1.040V


GEN TERM BUS

HOPE CREEK	.947V
SALEM G1	.944V
SALEM G2	.944V
PCH BTG2	.960V
LINERICK	230 1.030V
SUSQHNA	100 1.020V
CONEMAUGHG1	.990V
KEYSTONE G1	.979V
CCLIF G1	500 1.014V

NOTES: 1. LINE 1 IS MW
2. LINE 2 IS MVAR


HOPE CREEK OPERATING GUIDE - 1 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 - 50 MVAR OUTPUT

TRANSMISSION CONDITIONS: 1M2
HOPE CREEK-NEW FREEDOM 500-KV
CIRCUIT (5023) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 1 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT


TRANSMISSION CONDITIONS: LM3
 HOPE CREEK-SALEM 500-KV CIRCUIT
 (5037) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 1 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 - 50 MVAR OUTPUT

TRANSMISSION CONDITIONS: 1M4
SALEM-NEW FREEDOM 500-KV CIRCUIT
(5024.) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 1 UNIT

1987 40% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 768 MW

PS IMPORTS = 2000 MW

NO EFORS - PJM ECO. DISPATCH


HC 1 AT FULL MW OUTPUT AND

0 MVAR OUTPUT

TRANSMISSION CONDITIONS: 1MS

SALEM-DEANS 500-KV CIRCUIT
(5021) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 1 UNIT

1987 40% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 768 MW

PS IMPORTS = 2000 MW

NO EFORS - PJM ECO. DISPATCH


HC 1 AT FULL MW OUTPUT AND

-125 MVAR OUTPUT

TRANSMISSION CONDITIONS: LM6

PEACH BOTTOM-KEENEY 500-KV CIRCUIT (5014) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 1 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HC 1 AT FULL MW OUTPUT AND
 - 75 MVAR OUTPUT

TRANSMISSION CONDITIONS: LM7
 DEANS-BRANCHBURG 500-KV CIRCUIT
 (5019) ON MAINTENANCE

HOPE CREEK OPERATING GUIDE

TWO UNIT POWER FLOW CASE LISTING

HOPE CREEK NO. 1 AND SALEM NO. 1 OR 2 IN-SERVICE

<u>EXHIBIT NO.</u>	<u>CASE</u>	<u>DESCRIPTION</u>
55	2BASE	1987 40% SUMMER PEAK LOAD LEVEL PJM IMPORTS = 768 MW PS IMPORTS = 2000 MW NO EFORS(DISCRETE UNIT OUTAGES) - PJM ECONOMIC DISPATCH HC/SALEM AT FULL MW OUTPUT AND 0 MVAR OUTPUT EACH PEACH BOTTOM NO. 3 AND SUSQUEHANNA NO. 2 OUT OF SERVICE BASE CASE - ALL TRANSMISSION IN SERVICE
56	2M1	AS BASE - TWO UNIT AT 150 MW REDUCTION AND 125 MVAR OUTPUT EACH HOPE CREEK-KEENEY 500-KV CIRCUIT (5015) ON MAINTENANCE.
57	2M2	AS BASE - TWO UNIT AT FULL MW AND 50 MVAR OUTPUT EACH HOPE CREEK-NEW FREEDOM 500-KV CIRCUIT (5023) ON MAINTENANCE
58	2M3	AS BASE - TWO UNIT AT FULL MW AND 0 MVAR OUTPUT EACH HOPE CREEK-SALEM 500-KV CIRCUIT (5037) ON MAINTENANCE
59	2M4	AS BASE - TWO UNIT AT FULL MW AND 50 MVAR OUTPUT EACH SALEM-NEW FREEDOM 500-KV CIRCUIT (5024) ON MAINTENANCE
60	2M5	AS BASE - TWO UNIT AT 200 MW REDUCTION AND 225 MVAR OUTPUT (EACH) SALEM-DEANS 500-KV CIRCUIT (5021) ON MAINTENANCE
61	2M6	AS BASE - TWO UNIT AT FULL MW AND 0 MVAR OUTPUT EACH PEACH BOTTOM-KEENEY 500-KV CIRCUIT (5014) ON MAINTENANCE
62	2M7	AS BASE - TWO UNIT AT FULL MW AND 0 MVAR OUTPUT EACH DEANS-BRANCHBURG 500-KV CIRCUIT (5019) ON MAINTENANCE

POWER FLOW SIMULATION - SYSTEM SUMMARY

AREA NAME	GENERATION		INTERCHANGE (EXPORTS)		AREA SYSTEM LOAD		AREA SYSTEM BUS LOAD		AREA SYSTEM LOSSES		AREA CHARGING	AREA STATIC	UNUSED VARGEN
	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MVAR	MVAR	MVAR
PUBLIC SERVICE ELECTRIC & GAS CO.	1120.	94.	-2012.	681.	3132.	-588.	3103.	301.	29.	-887.	1451.	0.	2466.
PHILADELPHIA ELECTRIC CO.	228.	47.	-2333.	-379.	2561.	426.	2526.	817.	35.	147.	482.	537.	1279.
JERSEY CENTRAL POWER & LIGHT	248.	165.	-1054.	229.	1302.	-64.	1284.	-10.	17.	149.	192.	202.	205.
ATLANTIC ELECTRIC	402.	81.	-192.	33.	594.	48.	587.	186.	7.	-2.	77.	134.	154.
DELHARVA POWER & LIGHT CO.	378.	239.	-332.	254.	710.	-15.	704.	167.	7.	-60.	140.	121.	708.

EASTERN PJM TOTAL	2376.	626.	-5923.	818.	8299.	-192.	8203.	1460.	95.	-653.	2342.	994.	4812.

PENNSYLVANIA ELECTRIC CO.	636.	267.	-66.	148.	702.	119.	672.	144.	31.	-25.	386.	0.	1033.
METROPOLITAN EDISON CO.	208.	88.	-413.	109.	621.	-21.	612.	35.	9.	-10.	115.	46.	111.
PENNSYLVANIA POWER & LIGHT CO.	2976.	-49.	1134.	-283.	1842.	233.	1788.	441.	54.	221.	363.	430.	2301.
BALTIMORE GAS & ELECTRIC CO.	250.	256.	-1611.	54.	1861.	201.	1847.	244.	14.	-40.	202.	0.	13.
POTOMAC ELECTRIC CO.	1238.	95.	-537.	523.	1775.	-429.	1761.	881.	13.	-745.	979.	563.	2915.

WESTERN PJM TOTAL	5308.	656.	-1493.	552.	6801.	104.	6680.	1745.	120.	-599.	2046.	1038.	6374.

TOTAL PJM UNDERLYING	7684.	1282.	-7416.	1370.	15100.	-88.	14884.	3205.	215.	-1252.	4388.	2032.	11186.

PJM 500KV	7090.	87.	6635.	409.	455.	-322.	383.	262.	72.	-583.	3275.	0.	2775.

TOTAL PJM SYSTEM	14774.	1368.	-781.	1778.	15555.	-410.	15267.	3467.	287.	-1835.	7663.	2032.	13962.

HOPE CREEK OPERATING GUIDE - 2 UNIT

1987 40% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 768 MW

PS IMPORTS = 2000 MW

NO EFORS - PJM ECO. DISPATCH


HCL/SAL2 AT FULL MW OUTPUT AND

0 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2BASE


ALL 500-KV CIRCUITS IN SERVICE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT (EACH)


TRANSMISSION CONDITIONS: 2BASE
ALL 500-KV CIRCUITS IN SERVICE



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT 150 MW REDUCTION AND
 125 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2M1
 HOPE CREEK-KEENEY 500-KV CIRCUIT
 (5015) ON MAINTENANCE


1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT FULL MW OUTPUT AND
 50 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2M2


**HOPE CREEK-NEW FREEDOM 500-KV
 CIRCUIT (5023) ON MAINTENANCE**



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCl/SAL2 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2M3


HOPE CREEK-SALEM 500-KV CIRCUIT
 (5037) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL1/SAL2 AT FULL MW OUTPUT AND
 50 MVAR OUTPUT (EACH)


TRANSMISSION CONDITIONS: 2M4
 SALEM-NEW FREEDOM 500-KV CIRCUIT
 (5024) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT 200 MW REDUCTION AND
 225 MVAR OUTPUT (EACH)


TRANSMISSION CONDITIONS: 2M5
SALEM-DEANS 500-KV CIRCUIT
(5021) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2M6
 PEACH BOTTOM-KEENEY 500-KV CIRCUIT
 (5014) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 2 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL2 AT FULL MW OUTPUT AND
 0 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 2M7

DEANS-BRANCHBURG 500-KV CIRCUIT
 (5019) ON MAINTENANCE

HOPE CREEK OPERATING GUIDE

THREE UNIT POWER FLOW CASE LISTING

HOPE CREEK NO. 1, SALEM NO. 1 AND NO. 2 IN-SERVICE

<u>EXHIBIT NO.</u>	<u>CASE</u>	<u>DESCRIPTION</u>
65	3BASE	1987 40% SUMMER PEAK LOAD LEVEL PJM IMPORTS = 768 MW PS IMPORTS = 2000 MW NO EFORS (DISCRETE UNIT OUTAGES) - PJM ECONOMIC DISPATCH HC/SLM 1 & 2 AT FULL MW AND 200 MVAR OUTPUT - EACH PEACH BOTTOM NO. 3 AND SUSQUEHANNA NO. 2 OUT OF SERVICE BASE CASE - ALL TRANSMISSION IN SERVICE
66	3M1	AS BASE - THREE UNIT AT 300 MW REDUCTION AND 125 MVAR OUTPUT EACH HOPE CREEK-KEENEY 500-KV CIRCUIT (5015) ON MAINTENANCE
67	3M2	AS BASE - THREE UNIT AT FULL MW AND 275 MVAR OUTPUT EACH HOPE CREEK-NEW FREEDOM 500-KV CIRCUIT (5023) ON MAINTENANCE
68	3M3	AS BASE - SALEM NO. 1 AND 2 AT 50 MW REDUCTION AND 225 MVAR OUTPUT EACH HOPE CREEK NO. 1 AT FULL MW OUTPUT AND 300 MVAR OUTPUT - HOPE CREEK-SALEM 500-KV CIRCUIT (5023) ON MAINTENANCE
69	3M4	AS BASE - THREE UNIT AT FULL MW AND 250 MVAR OUTPUT EACH SALEM-NEW FREEDOM 500-KV CIRCUIT (5024) ON MAINTENANCE
70	3M5	AS BASE - THREE UNIT AT 300 MW REDUCTION AND 200 MVAR OUTPUT EACH SALEM-DEANS 500-KV CIRCUIT (5021) ON MAINTENANCE
71	3M6	AS BASE - THREE UNIT AT FULL MW AND 225 MVAR OUTPUT EACH PEACH BOTTOM-KEENEY 500-KV CIRCUIT (5014) ON MAINTENANCE
72	3M7	AS BASE - THREE UNIT AT FULL MW AND 225 MVAR OUTPUT EACH DEANS-BRANCHBURG 500-KV CIRCUIT (5019) ON MAINTENANCE
74	3BASE-75	1987 75% SUMMER PEAK LOAD LEVEL PJM IMPORTS = 2901 MW PS IMPORTS = 3500 MW NO EFORS (DISCRETE UNIT OUTAGES) - PJM ECONOMIC DISPATCH HC/SLM 1 & 2 AT FULL MW AND 200 MVAR OUTPUT PEACH BOTTOM NO. 3 AND SUSQUEHANNA NO. 2 OUT OF SERVICE BASE CASE - ALL TRANSMISSION IN SERVICE
76	3BASE-100	1987 100% SUMMER PEAK LOAD LEVEL PJM IMPORTS = 2168 MW PS IMPORTS = 3900 MW NO EFORS (DISCRETE UNIT OUTAGES) - PJM ECONOMIC DISPATCH HC/SLM 1 & 2 AT FULL MW AND 200 MVAR OUTPUT PEACH BOTTOM NO. 3 AND SUSQUEHANNA NO. 2 OUT OF SERVICE BASE CASE - ALL TRANSMISSION IN SERVICE

POWER FLOW SIMULATION - SYSTEM SUMMARY

AREA NAME	GENERATION		INTERCHANGE (EXPORTS)		AREA SYSTEM LOAD		AREA SYSTEM BUS LOAD		AREA SYSTEM LOSSES		AREA CHARGING	AREA STATIC	AREA UNRAISED
	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MVAR	MVAR	MVAR
PUBLIC SERVICE ELECTRIC & GAS CO.	1004.	55.	-2132.	614.	3136.	-559.	3103.	301.	33.	-859.	1451.	0.	2375.
PHILADELPHIA ELECTRIC CO.	544.	-71.	-2012.	-450.	2556.	380.	2526.	817.	30.	102.	487.	539.	1271.
JERSEY CENTRAL POWER & LIGHT	247.	135.	-1055.	198.	1302.	-63.	1284.	-10.	17.	150.	193.	203.	235.
ATLANTIC ELECTRIC	280.	105.	-318.	52.	598.	52.	587.	186.	10.	1.	78.	134.	169.
DELMARVA POWER & LIGHT CO.	432.	151.	-278.	176.	710.	-25.	704.	167.	6.	-68.	143.	122.	796.

EASTERN PJM TOTAL	2507.	375.	-5794.	589.	8301.	-214.	8203.	1460.	97.	-674.	2351.	998.	4846.

PENNSYLVANIA ELECTRIC CO.	634.	257.	-69.	136.	703.	121.	672.	144.	31.	-23.	387.	0.	1043.
METROPOLITAN EDISON CO.	208.	77.	-413.	101.	621.	-24.	612.	35.	9.	-13.	116.	46.	122.
PENNSYLVANIA POWER & LIGHT CO.	2429.	-217.	608.	-319.	1829.	102.	1788.	441.	41.	92.	365.	432.	2469.
BALTIMORE GAS & ELECTRIC CO.	250.	254.	-1610.	61.	1860.	193.	1847.	244.	13.	-47.	284.	0.	15.
POTOMAC ELECTRIC CO.	1238.	71.	-536.	511.	1774.	-441.	1761.	881.	12.	-759.	980.	562.	2939.

WESTERN PJM TOTAL	4759.	442.	-2027.	490.	6786.	-48.	6688.	1745.	106.	-749.	2051.	1040.	6588.

TOTAL PJM UNDERLYING	7266.	817.	-7821.	1080.	15087.	-263.	14884.	3205.	203.	-1423.	4402.	2038.	11434.


PJM 500KV	7514.	397.	7060.	782.	454.	-385.	383.	262.	71.	-646.	3319.	0.	3065.

TOTAL PJM SYSTEM	14780.	1214.	-762.	1861.	15542.	-647.	15267.	3467.	274.	-2068.	7721.	2038.	14499.

HOPE CREEK OPERATING GUIDE - 3 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SAL1&2 AT FULL MW OUTPUT AND
 200 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3BASE
 ALL 500-KV CIRCUITS IN SERVICE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 3 UNIT

1987 40% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 768 MW

PS IMPORTS = 2000 MW


NO EFORS - PJM ECO. DISPATCH

HCL1/SAL1&2 AT FULL MW OUTPUT AND

200 MVAR OUTPUT (EACH)


TRANSMISSION CONDITIONS: 3BASE

ALL 500-KV CIRCUITS IN SERVICE



HOPE CREEK OPERATING GUIDE - 3 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL1/SAL1&2 AT 300 MW REDUCTION AND
 125 MVAR OUTPUT (EACH)


TRANSMISSION CONDITIONS: 3ML
HOPE CREEK-KEENEY 500-KV CIRCUIT
(5015) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 3 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SALL&2 AT FULL MW OUTPUT AND
 275 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3M2

HOPE CREEK-NEW FREEDOM 500-KV
 CIRCUIT (5023) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 3 UNIT

1987 40% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 768 MW

PS IMPORTS = 2000 MW

NO EFORS - PJM ECO. DISPATCH

SALEM AT 50 MW REDUCTION AND


225 MVAR OUTPUT (EACH)

HOPE CREEK 1 AT FULL MW OUTPUT AND

300 MVAR OUTPUT

TRANSMISSION CONDITIONS: 3MB


HOPE CREEK-SALEM 500-KV CIRCUIT
(5037) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 3 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL1/SAL1&2 AT FULL MW OUTPUT AND
 250 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3M4


**SALEM-NEW FREEDOM 500-KV CIRCUIT
 (5024) ON MAINTENANCE**



HOPE CREEK OPERATING GUIDE - 3 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SALL1&2 AT 300 MW REDUCTION AND
 200 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3MS
 SALEM-DEANS 500-KV CIRCUIT
 (5021) ON MAINTENANCE

1987 PJM 500 KV SYSTEM



230KV SUMMARY

BRANCHBRO	230	1.038V
DAVIS	2	230 1.036V
NEW FREE	230	1.040V
SMITHBRO	230	1.013V
WHITPAIN	230	1.037V
ALBURTIS	230	1.048V
HOSESIAK	230	1.044V
LIMERICK	230	1.030V
SUSQHNA	230	1.035V
SUNBURY	230	1.043V
WESCOSVL	138	1.046V
KEYSTONE	230	1.039V
JUNIATA	230	1.044V
3 MILE I	230	1.039V
HUNTERTON	230	1.042V
PCH BT	230	1.011V

CONASTN	230	1.035V
BRIGHTON	230	1.033V
HAUGH C	230	1.034V
BURCH HL	230	1.051V
CHALK PT	230	1.043V

GEN TERM BUS


HOPE CREEK	1.033V
SALEM G1	1.030V
SALEM G2	1.030V
PCH BTG2	.960V
LIMERICK	230 1.030V
SUSQHNA	100 1.005V
CONEMAUGHG1	.980V
KEYSTONE G1	.975V
CCLIF G1	500 1.007V

HOPE CRK	1.104	1.104 VOLTS
SALEM	1.104	1.104 VOLTS

NOTES: 1. LINE 1 IS MW
2. LINE 2 IS MW

HOPE CREEK OPERATING GUIDE - 3 UNIT
 1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SALL&2 AT FULL MW OUTPUT AND
 225 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3M6
 PEACH BOTTOM-KEENEY 500-KV
 CIRCUIT (5014) ON MAINTENANCE



HOPE CREEK OPERATING GUIDE - 3 UNIT
1987 40% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 768 MW
 PS IMPORTS = 2000 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL/SALL&2 AT FULL MW OUTPUT AND
 225 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3M7
 DEANS-BRANCHBURG 500-KV CIRCUIT
 (5019) ON MAINTENANCE

POWER FLOW SIMULATION - SYSTEM SUMMARY

AREA NAME	GENERATION		INTERCHANGE (EXPORTS)		AREA SYSTEM LOAD		AREA SYSTEM BUS LOAD		AREA SYSTEM LOSSES		AREA CHARGING	AREA STATIC	UNUSED VARGEN
	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MVAR	MVAR	MVAR
PUBLIC SERVICE ELECTRIC & GAS CO.	3920.	974.	-3927.	1103.	7847.	-129.	7757.	751.	90.	-63.	1431.	818.	1405.
PHILADELPHIA ELECTRIC CO.	4502.	1086.	-1811.	-313.	6313.	1399.	6181.	2000.	131.	1358.	478.	1968.	1632.
JERSEY CENTRAL POWER & LIGHT	1090.	281.	-2212.	45.	3302.	237.	3211.	-26.	91.	1043.	183.	781.	137.
ATLANTIC ELECTRIC	737.	313.	-775.	-100.	1512.	413.	1467.	465.	45.	268.	74.	321.	48.
DELMARVA POWER & LIGHT CO.	1705.	482.	-87.	90.	1792.	393.	1760.	417.	32.	264.	134.	288.	218.

EASTERN PJM TOTAL	11954.	3137.	-8812.	824.	20766.	2312.	20376.	3608.	389.	2870.	2301.	4174.	3439.

PENNSYLVANIA ELECTRIC CO.	1917.	477.	182.	72.	1735.	406.	1679.	360.	56.	194.	383.	149.	896.
METROPOLITAN EDISON CO.	258.	169.	-1305.	-46.	1563.	215.	1530.	87.	33.	242.	110.	115.	58.
PENNSYLVANIA POWER & LIGHT CO.	6012.	1242.	1418.	400.	4594.	842.	4469.	1103.	125.	1234.	354.	1494.	1833.
BALTIMORE GAS & ELECTRIC CO.	2010.	1039.	-2658.	-9.	4668.	1048.	4618.	610.	49.	441.	195.	0.	435.
POTOMAC ELECTRIC CO.	4529.	1363.	45.	5.	4484.	1358.	4403.	2202.	81.	546.	938.	1391.	1287.

WESTERN PJM TOTAL	14726.	4290.	-2317.	422.	17043.	3869.	16700.	4362.	344.	2657.	1981.	3148.	4509.

TOTAL PJM UNDERLYING	26680.	7427.	-11130.	1246.	37810.	6181.	37077.	7970.	733.	5526.	4282.	7323.	7948.

PJM 500KV	9521.	2630.	8960.	154.	561.	2476.	383.	262.	177.	2853.	3189.	638.	1132.

TOTAL PJM SYSTEM	36201.	10057.	-2170.	1400.	38371.	8657.	37460.	8232.	910.	8379.	7471.	7960.	9080.

HOPE CREEK OPERATING GUIDE - 3 UNIT

1987 100% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 2168 MW


PS IMPORTS = 3900 MW

NO EFORS - PJM ECO. DISPATCH

HCI/SAL1&2 AT FULL MW OUTPUT AND

TRANSMISSION CONDITIONS: 3BASE-100

ALL 500-KV CIRCUITS IN SERVICE



HOPE CREEK OPERATING GUIDE - 3 UNIT
 1987 100% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 2168 MW
 PS IMPORTS = 3900 MW
 NO EFORS - PJM ECO. DISPATCH
 HCL1/SALL1&2 AT FULL MW OUTPUT AND
 300 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3BASE-100
 ALL 500-KV CIRCUITS IN SERVICE

POWER FLOW SIMULATION - SYSTEM SUMMARY

AREA NAME	GENERATION		INTERCHANGE (EXPORTS)		AREA SYSTEM LOAD		AREA SYSTEM BUS LOAD		AREA SYSTEM LOSSES		AREA CHARGING	AREA STATIC	UNUSED VARGEN
	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MW	MVAR	MVAR	MVAR	MVAR
PUBLIC SERVICE ELECTRIC & GAS CO.	2349.	1359.	-3540.	814.	5089.	545.	5021.	1577.	68.	-230.	1422.	792.	924.
PHILADELPHIA ELECTRIC CO.	1039.	275.	-3786.	-383.	4825.	658.	4736.	1347.	89.	630.	467.	1316.	519.
JERSEY CENTRAL POWER & LIGHT	658.	212.	-1000.	155.	2458.	57.	2408.	12.	49.	510.	179.	472.	74.
ATLANTIC ELECTRIC	651.	156.	-472.	-1.	1123.	157.	1100.	239.	23.	123.	75.	204.	245.
DELMARVA POWER & LIGHT CO.	1468.	442.	118.	204.	1350.	238.	1320.	275.	30.	225.	135.	261.	230.

EASTERN PJM TOTAL	6165.	2444.	-9479.	789.	15644.	1655.	15304.	3449.	260.	1257.	2279.	3045.	1992.

PENNSYLVANIA ELECTRIC CO.	1366.	320.	62.	119.	1304.	209.	1259.	308.	44.	51.	304.	150.	971.
METROPOLITAN EDISON CO.	218.	196.	-943.	-4.	1181.	199.	1147.	107.	34.	216.	108.	124.	3.
PENNSYLVANIA POWER & LIGHT CO.	4713.	1109.	1243.	396.	3470.	713.	3352.	508.	118.	1041.	349.	836.	1394.
BALTIMORE GAS & ELECTRIC CO.	1313.	665.	-2197.	-166.	3518.	831.	3464.	515.	45.	319.	193.	0.	228.
POTOMAC ELECTRIC CO.	4016.	949.	648.	380.	3368.	569.	3303.	627.	65.	237.	955.	293.	1624.

WESTERN PJM TOTAL	11626.	3245.	-1206.	724.	12832.	2521.	12525.	2065.	307.	1865.	1990.	1403.	4222.

TOTAL PJM UNDERLYING	17791.	5690.	-10685.	1513.	28476.	4177.	27909.	5514.	566.	3122.	4268.	4448.	6213.

PJM 500KV	8341.	2397.	7787.	60.	554.	2337.	383.	262.	171.	2390.	3142.	315.	1365.

TOTAL PJM SYSTEM	26132.	8087.	-2898.	1573.	29030.	6514.	28292.	5776.	737.	5511.	7410.	4763.	7578.

HOPE CREEK OPERATING GUIDE - 3 UNIT

1987 75% SUMMER PEAK LOAD LEVEL

PJM IMPORTS = 2901 MW

PS IMPORTS = 3500 MW

NO EFORS - PJM ECO. DISPATCH


HCL/SAL1&2 AT FULL MW OUTPUT AND

300 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3BASE-75

ALL 500-KV CIRCUITS IN SERVICE

1987 PJM 500 KV SYSTEM



HOPE CREEK OPERATING GUIDE - 3 UNIT

1987 75% SUMMER PEAK LOAD LEVEL
 PJM IMPORTS = 2901 MW
 PS IMPORTS = 3500 MW
 NO EFORS - PJM ECO. DISPATCH
 HCl/SAL1&2 AT FULL MW OUTPUT AND
 300 MVAR OUTPUT (EACH)

TRANSMISSION CONDITIONS: 3BASE-75

ALL 500-KV CIRCUITS IN SERVICE



APPENDIX 3

POWER Vs. ROTOR ANGLE

AND


ROTOR ANGLE Vs. TIME CURVES

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 ALL IN CASE
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv




RO1AHK2

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - KEENEY
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv



Legend

- △ Hope Crk. No. 1
- × Tm





Legend

- △ Keystone No.2
- × Peach Bottom No.1
- Susquehanna No.1
- ⊗ Califf No.1
- ⊗ Hope Crk. No. 1


ROIMISD

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - N.FREEDOM
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk. - Keeney
 At Hope Crk 500kv




RO1M2HK2

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - SALEM
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk. - Keeney
 At Hope Crk 500kv



Legend

- △ Hope Crk. No. 1
- × Tm





Legend

- △ Keystone No. 2
- × Peach Bottom No.
- Susquehanna No. 1
- ⊠ Califf No. 1
- ⊞ Hope Crk. No. 1



ROIMJHK2

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: SALEM-HLFREEDOM
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv





RO1M4HK

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE-SALEM-DEANS
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv




ROIM5HK

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: KEENEY-P. BOTTOM
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Hope Crk 500kv




ROIM6SD

1987 SALEM/HOPE CRK. ONE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE : DEANS - BRANCHBURG
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv





Legend
 Δ Hope Crk. No. 1
 X Tm



Legend
 Δ Keystone No.2
 X Peach Bottom No.1
 □ Susquehanna No.1


RO1M7HK

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv




ROZAHK

1987 SALEM/HOPE CRK TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE-HOPE CRK-KEENEY
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv





Legend
 Δ Salem No. 2
 X Tm



Legend
 Δ Salem No. 2
 X Keystone No.2
 — Peach Bottom No.1
 ⊠ Susquehanna No.1
 ⊞ Cliff No.1
 X Hope Crk. No.1



R02MISD

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE:HOPE CRK.-NLFREEDOM
 Hope Crk. No.1 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Salem
 At Hope Crk 500kv




RD2M2HS

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE:HOPE CRK.-SALEM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv




RO2M3SD

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: SALEM-N.FREEDOM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Kearney
 At Hope Crk 500kv





Legend
 Δ Salem No. 2
 × Tm



Legend
 Δ Salem No. 2
 × Keystone No. 2
 □ Peach Bottom No. 1
 ▣ Susquehanna No. 1
 ⊠ Calif. No. 1
 × Hope Crk. No. 1


RO2M4HK

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: SALEM - DEANS
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk. - Keeney
 At Hope Crk 500kv




RO2M5HK

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE : KEENEY - P. BOTTOM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv





Legend
 Δ Salem No. 2
 × Tm



Legend
 Δ Salem No. 2
 × Keystone No.2
 □ Peach Bottom No
 ⊠ Susquehanna No.
 ⊞ Calif No.1
 * Hope Crk. No. 1



R02M6SD

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: DEANS-BRANCHBURG 500KV LINE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv





R02M7HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv





ROJAHK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE:HOPE CRK.—KEENEY
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem—Deans
 At Salem 500kv





ROJMSD

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE:SALEM - DEANS
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv





RO3M5HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. -N.FREEDOM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk 500kv




03M2HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - SALEM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv




RO3M3SD2

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: SALEM-N. FREEDOM
 Salem No. 2 Power vs. Angle
 Three Phase Line Fault Hope Crk. - Keesney
 At Hope Crk 500kv



Legend

- △ Salem No. 2
- × Tm




Legend


- △ Salem No. 2
- × Keystone No. 2
- Peach Bottom No. 1
- ⊗ Susquehanna No. 1
- ⊗ Califf No. 1
- * Hope Crk. No. 1

RO3M4HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE : KEENEY - P.BOTTOM
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Salem-Deans
 At Salem 500kv




Legend
 Δ Salem No. 2
 X Im



Legend
 Δ Salem No. 2
 X Keystone No. 2
 □ Peach Bottom No. 1
 ⊠ Susquehanna No. 1
 * Clifton No. 1
 * Hope Crk. No. 1


RO3M6SD

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: DEANS-BRANCHBURG 500KV LINE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv



Legend

- △ Salem No. 2
- × Tm





Legend

- △ Salem No. 2
- × Keystone No. 2
- Peach Bottom No. 1
- ⊗ Susquehanna No. 1
- ⊗ Cluff No. 1
- × Hope Crk. No. 1



RO3M7HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: CB 50X OR 60X
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk, Also Trip Hope Crk.-N.Freedom





RO3CB1HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: CB 51X, OR 52X, OR 61X
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk. - Keeney
 At Hope Crk. Also Trip Hope Crk. - Salem




RO3CB2HK

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem2 Power Vs. Rotor Angle
 Three Phase Line Fault Hope Crk. - Keeney
 At Hope Crk. 500kv
 75 % Load Level Base Case




R3A/K751

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv
 Hope Crk. Operating Guide 100% Load Level





Legend
 Δ Salem No. 2
 X Tm



Legend
 Δ Salem No. 2
 X Keystone No. 2
 □ Peach Bottom No. 1
 ⊠ Susquehanna No. 1
 ⊞ Clifton No. 1
 X Hope Crk. No. 1



R3AHK100

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - SALEM
 Salem No.2 Power vs. Angle
 No Fault; Hope Crk. - Salem Line Reclosed





RO3M3RCL

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE:SALEM - DEANS
 Salem No.2 Power vs. Angle
 No Fault ;Salem-Deans Line Reclosed




RO3M5RCL

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE: HOPE CRK. - KEENEY
 Salem No.2 Power vs. Angle
 Hope Crk. - Keeney Line Reclose




RO3M1RC

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Three Phase Line Fault Hope Crk.-Keeney
 At Hope Crk. 500kv
 Hope Crk.-Keeney Reclose After 1 Second



Legend

- Salem No. 2
- Tm





Legend

- Salem No. 2
- Keystone No. 2
- Peach Bottom No. 1
- Susquehanna No. 1
- △ Califf No. 1
- < Hope Crk. No. 1



FUHKRCL

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Hope Crk. No. 1 Tripped





ICTRIP

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No 2 Power vs Angle
 Three Phase Fault Hope Crk. No.1 Transformer
 At Hope Crk. 500 kV
 Hope Crk. No 1 Trip After 3.5 Cycle





HC1R1P1

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE-DEANS - BRANCHBURG
 Salem No.2 Power vs. Angle
 Single Phase Fault Hope Crk. - Salem
 At Hope Crk. STUCK BREAKER:CB 60X
 Also Trip Hope Crk. - Keeney





R3560M7T

1987 SALEM/HOPE CRK. TWO UNIT OPERATING GUIDE
 MAINTENANCE OUTAGE DEANS - BRANCHBURG
 Salem No.2 Power vs. Angle
 Single Phase Fault Hope Crk. - Salem
 At Hope Crk 500kV STUCK BREAKER-CB 60X
 Also Trip Hope Crk. - Keeney





R2560M7T

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Single Phase Fault Hope Crk. -New Freedom
 At Hope Crk. 500kv ; 50X Stuck Breaker
 Hope Crk. No.1 Trip After 4.5 Cycle



R3HN505B

1987 SALEM/HOPE CRK. THREE UNIT OPERATING GUIDE
 ALL IN CASE
 Salem No.2 Power vs. Angle
 Single Phase Fault Hope Crk.-Salem
 At Hope Crk. 500kv ; 52X Stuck Breaker
 Hope Crk. No.1 Trip After 4.5 Cycle



R3HSS25B

APPENDIX 4

SIMULATION MODIFICATIONS

PE, DPL, AND ACE

PE, DPL and ACE Data Modifications
Dispatch, Power Flow and Stability

The resulting operating curves were a result of running the Transtab stability program which required (1) a power flow simulation with specific operating conditions represented and (2) a data file representing generator characteristics.

At the request of PSE&G, PE, DPL and ACE submitted information which updated the following:

1. 1987 Hope Creek Unit No. 1 - MAAC Filing Power Flow Simulation and Dispatch Data
2. Generator stability data representation

The following is a summary of major data and representation changes suggested by PE, DPL and ACE.

Generator Dispatch

PE Changes of dispatch data for the following machines included MW, MVAR and heat rate information:

Conowingo 1-6
Conowingo 7
Eddystone 1
Eddystone 2
Richmond 1-8
Richmond 9
Schuykill 1
South wk AB 1 and 2
South wk DC 1
Barbadoes AB 1, 2 and 3
Barbadoes CD 1
Plymouth Meeting D
Richmond 13
Cromby DSL 2 1, 2 and
Muddy Run 1-8
Limerick 1
Peach Bottom 2

DPL

The following units were turned on in DPL as must run generation:

Dela City
Edgemore 3, 4 and 5
Indian River 1 and 3

The following units were removed from the generation schedule:

Edgemoor 1 and 2
Kellam 69

ACE

No changes to dispatch data.

Power Flow Simulation

PE

Numerous changes were submitted and incorporated into the power flow simulation which included:

1. line representation - impedance, charging, and ratings.
2. transformer representation - impedance, taps and voltage data.

Several specific and more noteworthy are:

1. Peach Bottom No. 2 auxiliary bus load representation.
2. Peach Bottom No. 2 minimum reactive limit changed to -175 MVAR and a generator terminal bus voltage regulated at .96 pu in order to maintain the 500-kV voltage at 1.06 pre-contingency and for a post-contingency condition to 1.075 pu maximum.

3. Limerick No. 1 (230 kV) auxiliary bus load representation.

4. Muddy Run units No. 1-8 revised from four units on a terminal bus to paired units (i.e. 1&2, 3&4, 5&6) modelled each through a step-up transformer to a separate 230-kV high side bus.

DPL No significant modifications were submitted.

ACE No significant modifications were submitted.

Stability Data

Modifications included rotor, excitation and governor data for the following units:

PE

- . Peach Bottom 2 & 3
- . Limerick 1
- . Eddystone 1 hp and lp
- . Eddystone 2 hp and lp
- . Schuykill 3
- . Conowingo 7
- . Seward
- . Shawville
- . Susquehanna 1

DPL

- . Edgemoor 3, 4 and 5
- . Vienna 8
- . Indian River 1, 2, 3 and 4
- . Del City 1, 2 and 3

ACE No significant changes

APPENDIX 5

SCOPE AND PROCEDURE

HOPE CREEK GENERATING STATION OPERATING GUIDE
(HOPE CREEK/SALEM)

SCOPE AND PROCEDURES

I. INTRODUCTION

This operating guide is for the operation of Hope Creek Unit No. 1, in conjunction with the operation of both Salem Units No. 1 and 2, due to their close electrical proximity.

The Hope Creek Transmission Project, consisting of 500-kV facility additions and rearrangements which integrated it with the 500-kV transmission of the Lower Delaware Valley Transmission Project, was completed and put into service in March, 1985.

II. SCOPE

This operating guide will provide the PSE&G System, Hope Creek Generating Station and Salem Generating Station Operators with guidance in operating these units based on stability considerations for various system conditions.

The operating guide will be prepared from results obtained from power flow analysis, economic generation dispatches, short circuit analysis, and transient stability analysis.

The analysis and subsequent results will focus on the following three Hope Creek/Salem unit operating combinations:

- a. Hope Creek No. 1, Salem Nos. 1 and 2 (3 unit)
- b. Hope Creek No. 1 and Salem No. 1 or 2 (2 unit)
- c. Hope Creek No. 1 (single unit)

The results are to be determined considering the following:

- a. Transient Stability
 - . stability with MAAC criteria tests
 - . stability with selected PJM 500-kV lines scheduled out for maintenance
 - . stability with selected Hope Creek circuit breakers scheduled out for maintenance
- b. Voltage limits - maintain voltages on generator terminal buses and bulk system high voltage buses within criteria.
- c. Minimum Excitation Limit - individual unit basis

III. PROCEDURES

A. Power Flow Simulations

Using an updated version of the 1987 Hope Creek MAAC Filing base case power flow simulations will be made for 100%, 75% and 40% of peak load conditions, to establish the voltage and power flow patterns for the vicinity of Hope Creek and Salem Generating Stations.

- . For the 100% load level, PJM will be dispatched economically, with an import of 3000 MW reserve economy purchase.
- . For the 75% load level PJM will be dispatched economically, with a 3600 MW reserve economy purchase.
- . For the 40% load level, all of PJM will be dispatched economically, with the actual PJM interchange a function of whether jointly owned units are normally on or off (i.e. Homer City and Seneca) for this load level.

At all load levels, the generating units will be dispatched without EFOR deration with unit unavailability to be accounted for by discrete unit outages, primarily on the 500-kV system. The most critical combination of 500-kV unit outages will be used to establish operating limits (i.e. one Peach Bottom unit and one Susquehanna unit). Discrete unit forced and maintenance outages for underlying units will be based on a distribution similar to that used in the 1986 PJM Maximization of Economic Imports (MEI) Study.

B. Transient Stability Analysis

The Transient Stability Analysis will determine the stability of the system and the performance of the new Hope Creek Unit at the 40% of peak load level. Also to be determined are the terminal voltage and minimum MVAR output requirements of the Hope Creek and Salem units needed to maintain stability for normal, scheduled and unscheduled transmission outage conditions and selected circuit breaker scheduled outage for a range of most probable system voltages.

The study results will document all assumptions regarding voltage and reactive constraints at key buses. Also, for analysis purposes, where voltages are near their limits, potential voltage rises due to generator or transmission line outages will be investigated. If the power flow analysis indicates that reactive output of major generating units are at or near their stated reactive capability limit, the case will be rerun with the limit modified to provide a margin on the unit's reactive output.

For those cases where transmission line maintenance outages may have a major effect on the PJM import limits, import levels will be modified if it is deemed that such a change would significantly impact the stability margin at the Hope Creek/Salem complex.

For those cases where Hope Creek/Salem units output reduction is required for stability considerations and the generation dispatch associated with such reductions would be expected to cause a major effect on the PJM import limits, import levels will be modified if it is further deemed that such redispatch would significantly impact the stability margin at the Hope Creek/Salem complex.

Critical cases will be tested under 75% and peak load level conditions to ensure unit and system stability under these load levels and PJM import levels.

1. Machine Representation

The transient stability analysis will be based on generator unit and unit transformer data used by PJM which is most current and appropriate and categorized as follows:

a. PJM Units

- . synchronous rotor data
- . excitation system data
- . governor system data

b. Individual Outside World Units - as above with at least synchronous rotor data.

- c. Equivalent Outside World Units - buses without specific machine data available. Develop a classical representation based on a "unit machine" concept for which the number of unit machines on a bus would be a function of the total net MW generation (generation minus load) on an equivalent bus divided by the MW size of the unit machine (i.e. a bus having a net 2000 MW of generation would have data developed for five machines based on a unit machine of 400 MW).

2. Generator Terminal Representation

The Hope Creek and Salem generator terminal buses will be represented explicitly with the unit MW and MVAR gross output and with auxiliary load represented. Station use at major generating stations electrically close to the Hope Creek/Salem complex will also be represented in this manner.

3. System Load Representation

The representation of system load will be:

- a. MW load constant current
- b. MVAR load constant impedance
- c. underlying system capacitors will be netted with load
- d. PJM 500-kV and 230-kV switched capacitors will be modelled explicitly. The capacitors will be switched on for the peak and 70% load levels and switched off for the 40% load level.

4. Stability Simulations

- a. Stability simulation with unscheduled transmission contingencies with Hope Creek and Salem units at full MW output for three-phase faults with primary clearing and single-phase faults with delayed clearing:
 - . fault at Hope Creek end of Hope Creek-Keeney (5015) 500-kV
 - . fault at Hope Creek end of Hope Creek-New Freedom (5023) 500-kV

- . fault at Hope Creek end of Hope Creek-Salem (5037) 500-kV
- . fault at Salem end of Salem-Deans (5021) 500-kV
- . fault at Salem end of Salem-New Freedom (5024) 500 kV

If any simulations are unstable:

- . MVAR output will be increased until stability is reached
- . MW output will be decreased only if MVAR and/or voltage limitations are exceeded

b. Stability simulations with scheduled transmission outages:

- . Redo the above fault analysis for conditions simulating 500-kV line maintenance outages for each of the Hope Creek and Salem Switching Station outlets and also for the maintenance outage of the Keeney-Peach Bottom 500-kV line and the Deans-Branchburg 500 kV line. Where appropriate, outages of more distant lines will be included in the analysis.

c. Stability simulations with the following Hope Creek 500kV circuit breaker scheduled out for maintenance:

Same procedure as "a".

Hope Creek 500 kV Breaker Maintenance Outage

<u>CB #</u>	<u>Faulted Line*</u>	<u>Desig.</u>	<u>Remaining Hope Creek Outlets</u>
60X	HC-NF	5023	HC-SLM
61X	HC-SLM	5037	HC-NF
50X	HC-KNY	5015	HC-SLM
	HC-SLM	5037	HC-NF & HC-KNY
51X	HC-SLM	5037	HC-NF
52X	HC-KNY	5015	HC-NF
	HC-NF	5023	HC-KNY & HC-SLM

*Fault on HC end of line.

IV. EXPECTED RESULTS

- a. The following exhibits will be prepared to demonstrate the transient performance of the Hope Creek and Salem units:

- . power versus rotor angle
- . rotor angle versus time (to 4 seconds)

Also, rotor angle versus time (to 4 seconds) exhibits for the following selected units will be provided to demonstrate system transient stability:

500-kV Peach Bottom
Susquehanna
Keystone/Conemaugh

230-kV Oyster Creek
Edge Moor

138-kV England

- b. Generating unit capability curves for Hope Creek No. 1 and Salem Nos. 1 and 2 will be prepared to show the unit operating limits for all probable system voltages.

JP/RAL:lh
8/7/85

APPENDIX 6

TRANSIENT STABILITY SIMULATION

MACHINE DATA

SYNCHRONOUS ROTOR DATA

BUS	NAME	XPRIND (PU)	XR (PU)	XD (PU)	XL (PU)	H MVA/MVA	AG	GG	TPRINDG	TORQUE (MM)	TERMINAL VOLTAGE MAGNITUDE	ANGLE	SPRING (PU)
396	EDDYSTG1	0.1307	0.7270	0.7330	0.0710	2.93	0.159	9.800	6.77	80.0	0.960	-8.88	0.8704
396	EDDYSTG1	0.1638	0.7030	0.7080	0.0780	18.72	0.013	8.060	4.30	80.0	0.960	-8.83	0.8910
397	EDDYSTG2	0.1154	0.7980	0.8370	0.0550	10.57	0.015	8.750	9.70	80.0	0.958	-7.92	0.8411
397	EDDYSTG2	0.1154	0.7980	0.8370	0.0550	10.57	0.015	8.750	9.70	80.0	0.958	-7.92	0.8411
343	CONO7-13	0.7700	1.4750	2.5250	0.5000	1.48	0.069	6.933	6.00	31.0	1.078	-8.12	1.0688
1117	IND RIV 1	0.1740	1.5420	1.5830	0.0710	4.12	0.037	7.520	6.73	30.0	1.021	-4.94	0.9607
1120	IND RIV 3	0.1300	0.7790	0.8170	0.0770	6.28	0.017	8.342	3.80	50.0	1.000	-5.44	0.7949
1086	DELA CITY 1	0.8750	5.0630	5.2500	0.3540	1.18	0.021	6.843	3.60	27.0	1.061	-3.53	0.8463
1087	DELA CITY 2	0.8750	5.0630	5.2500	0.3540	1.18	0.021	6.843	3.60	27.0	1.061	-3.53	0.8463
6	CCLIF G1 500	0.0355	0.1545	0.1650	0.0211	44.83	0.010	9.640	7.20	548.0	1.006	1.25	0.8275
7	CCLIF G2 500	0.0448	0.1635	0.1675	0.0236	33.57	0.020	7.400	5.95	488.0	1.006	0.94	0.8512
10	CONEMAUGHG1	0.0474	0.3211	0.3350	0.0294	7.39	0.021	8.047	4.20	262.0	0.978	15.12	0.8188
10	CONEMAUGHG1	0.0567	0.3374	0.3576	0.0303	28.97	0.024	8.130	8.60	238.0	0.978	15.12	0.8382
126	CONEMAUGHG2	0.0474	0.3211	0.3350	0.0294	7.39	0.021	8.047	4.20	262.0	0.978	15.12	0.8188
126	CONEMAUGHG2	0.0567	0.3374	0.3576	0.0303	28.97	0.024	8.130	8.60	238.0	0.978	15.12	0.8382
17	KEYSTONE G1	0.0544	0.3441	0.3459	0.0332	6.71	0.028	6.931	5.11	255.0	0.975	16.62	0.8619
17	KEYSTONE G1	0.0769	0.3304	0.3393	0.0384	19.38	0.009	8.524	6.85	245.0	0.975	16.62	0.8923
125	KEYSTONE G2	0.0544	0.3441	0.3459	0.0332	6.71	0.028	6.931	5.11	255.0	0.975	16.62	0.8618
125	KEYSTONE G2	0.0769	0.3304	0.3393	0.0384	19.38	0.009	8.524	6.85	245.0	0.975	16.62	0.8923
20	PCN BTG2	0.0281	0.1281	0.1359	0.0164	52.51	0.009	9.090	7.30	1093.0	0.960	5.52	0.7444
25	SALEM G1	0.0394	0.1590	0.1630	0.0192	44.15	0.013	9.360	6.12	1123.0	1.017	11.12	1.0362
26	SALEM G2	0.0312	0.1277	0.1344	0.0165	51.50	0.012	7.000	6.90	1162.0	1.016	11.43	0.9998
38	HOPE CREEK	0.0312	0.1277	0.1344	0.0165	46.30	0.012	7.000	6.90	1100.0	1.020	11.86	1.0044
53	ERIE SO. 115	0.0360	1.2200	1.2200	0.3090	4.82	0.020	8.080	6.40	14.0	1.034	7.10	1.0279
74	HOMER CTY 1G	0.0479	0.2587	0.2617	0.0295	20.12	0.035	7.799	5.60	300.0	1.016	13.63	0.8404
73	HOMER CTY G3	0.0357	0.2459	0.2549	0.0199	18.95	0.016	8.581	4.00	330.0	1.013	15.54	0.8525
99	SENECA GEN	0.0957	0.1714	0.2878	0.0689	31.57	0.020	8.080	9.50	-450.0	1.020	-14.47	1.2458
101	SENARD 115	0.1105	0.5990	0.6140	0.0790	11.65	0.030	7.850	6.45	60.0	1.039	8.52	0.9977
104	SHAMVIL G230	0.1247	0.7488	0.7879	0.0723	5.48	0.015	8.287	3.90	130.0	0.989	8.17	0.9123
104	SHAMVIL G230	0.1247	0.7488	0.7879	0.0723	5.48	0.015	8.287	3.90	130.0	0.989	8.17	0.9123
106	SHAMVILLE 18	0.1056	0.9200	0.9520	0.0600	6.08	0.012	8.614	5.60	60.0	1.025	5.47	1.0166
106	SHAMVILLE 18	0.1056	0.9200	0.9520	0.0600	6.08	0.012	8.614	5.60	60.0	1.025	5.47	1.0166
164	PORTLAND G115	1.1672	1.5580	1.6373	0.0882	2.48	0.020	7.620	5.60	31.5	1.050	-10.32	1.0318
164	PORTLAND G115	0.2530	1.2380	1.2900	0.1100	5.32	0.021	8.157	5.00	31.5	1.050	-10.32	1.0691
165	PORTLAND G230	0.1283	1.1000	1.1400	0.0700	3.63	0.022	8.591	5.60	72.5	1.030	-9.31	0.9465
165	PORTLAND G230	0.2127	1.0733	1.1267	0.0933	8.90	0.029	6.999	6.30	72.5	1.030	-9.31	0.9962
205	OYSTR CK GEN	0.0545	0.2371	0.2502	0.0305	33.92	0.018	6.860	5.70	620.0	0.983	0.58	0.8809
220	YARDS CK GEN	0.1552	0.2642	0.3944	0.1074	14.22	0.049	5.915	12.00	-411.0	1.028	-21.74	1.2198
236	BRUNNERS 100	0.0796	0.4280	0.4341	0.0486	12.71	0.043	6.243	4.40	123.0	0.999	-2.38	0.9291
237	BRUNNERS 2 100	0.0663	0.3640	0.3716	0.0487	14.10	0.013	10.437	5.40	125.0	0.999	-2.83	0.9423
238	BRUNNERS 3 100	0.0343	0.2104	0.2212	0.0238	21.82	0.054	5.394	4.00	359.0	0.999	-2.02	0.7954
283	MONTOUR1 100	0.0296	0.2170	0.2279	0.0179	21.34	0.021	7.617	4.20	350.0	0.982	5.94	0.8088
284	MONTOUR2 100	0.0291	0.2198	0.2388	0.0176	24.48	0.022	7.450	4.30	455.0	0.982	6.92	0.7537
289	HTH CRK1 100	0.1100	0.8344	0.8710	0.0544	5.40	0.058	3.710	5.90	83.0	1.018	-5.83	0.9524
290	HTH CRK2 100	0.1057	0.8704	0.9048	0.0510	5.41	0.059	3.710	6.20	83.0	0.994	-7.10	0.8814
327	SUSQUHNI 100	0.0328	0.1297	0.1359	0.0176	44.60	0.026	4.581	6.70	760.0	1.006	4.75	0.8025
342	LIN G1-22	0.0392	0.1330	0.1390	0.0190	44.81	0.018	7.950	6.10	1093.0	0.973	2.27	0.8703
395	CROSBY81	0.0752	0.7910	0.7910	0.0674	7.60	0.037	6.900	6.00	60.0	1.025	-7.27	0.9528
221	MUDDTRN1.2	0.0710	0.1455	0.2318	0.0323	13.42	0.038	0.078	7.00	-240.8	0.965	-18.48	0.9491
222	MUDDTRN3.4	0.0710	0.1455	0.2318	0.0323	13.42	0.038	0.078	7.00	-240.8	0.967	-17.88	0.9512

* BASE - 100 MVA AND MACHINE TERMINAL BUS VOLTAGE

SYNCHRONOUS ROTOR DATA

BUS	NAME	XPRIND (PU)	X _B (PU)	X _D (PU)	X _L (PU)	H MMS/MVA	AG	SG	YPRIND	TORQUE (MW)	TERMINAL VOLTAGE MAGNITUDE	ANGLE	EPRIND (PU)
223	HUDYRMS 6	0.0710	0.1453	0.2310	0.0323	13.42	0.030	0.070	7.00	-240.0	0.967	-17.94	0.9511
224	HUDYRMS 8	0.0710	0.1453	0.2310	0.0323	13.42	0.030	0.070	7.00	-240.0	0.967	-17.94	0.9511
575	BERGEN 130	0.0734	0.3001	0.4230	0.0734	12.96	0.017	0.730	4.04	75.0	1.032	-20.60	1.0660
575	BERGEN 130	0.0734	0.3001	0.4230	0.0734	12.96	0.017	0.730	4.04	75.0	1.032	-20.60	1.0660
504	BURLINGTN GEN	0.0850	0.5700	0.6270	0.0850	9.43	0.030	0.550	5.35	15.0	1.050	-14.70	1.1461
619	HUDSON G1	0.0449	0.3170	0.3210	0.0449	10.70	0.020	0.000	5.20	135.0	0.979	-20.00	0.8232
620	HUDSON G2	0.0471	0.2590	0.2620	0.0471	27.92	0.020	0.000	5.63	275.0	0.962	-16.16	0.5399
641	LINDEN GEN	0.0906	0.5000	0.6220	0.0906	7.77	0.009	10.000	7.30	64.5	1.050	-19.00	1.0005
641	LINDEN GEN	0.0906	0.5000	0.6220	0.0906	7.77	0.009	10.000	7.30	64.5	1.050	-19.00	1.0005
655	MERCER G1	0.0875	0.8200	0.8600	0.0844	8.53	0.017	0.730	5.90	67.5	0.992	-9.50	0.8023
655	MERCER G1	0.0875	0.8200	0.8600	0.0844	9.10	0.017	0.730	5.90	67.5	0.992	-9.50	0.8023
656	MERCER G2	0.0875	0.8200	0.8600	0.0844	8.53	0.017	0.730	5.90	67.5	0.992	-9.50	0.8023
656	MERCER G2	0.0875	0.8200	0.8600	0.0844	9.10	0.017	0.730	5.90	67.5	0.992	-9.50	0.8023
603	SEAHAMEN 130	0.1120	1.1050	1.1100	0.0	5.25	0.0	0.0	0.0	15.0	1.041	-19.04	1.0139
603	SEAHAMEN 130	0.1140	1.0140	1.0350	0.0	7.30	0.0	0.0	0.0	15.0	1.041	-19.04	1.0162
767	ZCRANESI 115	0.1272	0.7700	0.8125	0.0737	6.05	0.019	0.699	3.70	120.0	1.034	-5.57	1.1015
784	ZHAG G3 115	0.0520	0.2600	0.2700	0.0440	24.00	0.030	7.400	6.10	130.0	0.993	-0.57	1.0577
820	CHALK PT G01	0.0704	0.7521	0.7810	0.0442	9.90	0.020	0.500	5.00	79.5	1.045	-0.70	0.9700
820	CHALK PT G01	0.0704	0.7521	0.7810	0.0442	10.00	0.020	0.500	5.00	79.5	1.045	-0.70	0.9700
829	CHALK PT G02	0.0704	0.7521	0.7810	0.0442	9.90	0.020	0.500	5.00	79.5	1.045	-0.84	0.9712
829	CHALK PT G02	0.0704	0.7521	0.7810	0.0442	10.00	0.020	0.500	5.00	79.5	1.045	-0.84	0.9712
830	CHALK PT G03	0.0373	0.2504	0.2700	0.0215	17.79	0.020	0.500	4.00	111.0	1.045	-2.24	1.0401
831	CHALK PT G04	0.0373	0.2504	0.2700	0.0215	18.01	0.020	0.500	4.00	111.0	1.045	-2.15	0.8907
833	DICKERSON G01	0.1626	1.4435	1.5130	0.0870	2.50	0.020	9.000	5.40	35.0	1.015	-2.76	1.0363
833	DICKERSON G01	0.2503	1.2435	1.2957	0.1007	7.71	0.020	9.000	5.10	35.0	1.015	-2.76	1.0045
834	DICKERSON G02	0.1626	1.4435	1.5130	0.0870	2.50	0.020	9.000	5.40	35.0	1.015	-2.79	1.0360
834	DICKERSON G02	0.2503	1.2435	1.2957	0.1007	7.71	0.020	9.000	5.10	35.0	1.015	-2.79	1.0041
835	DICKERSON G03	0.1626	1.4435	1.5130	0.0870	2.50	0.020	9.000	5.40	35.0	1.015	-2.74	1.0355
835	DICKERSON G03	0.2503	1.2435	1.2957	0.1007	7.71	0.020	9.000	5.10	35.0	1.015	-2.74	1.0045
839	MORGANTH G01	0.0447	0.2573	0.2644	0.0257	22.46	0.020	0.500	3.90	179.0	1.026	-1.65	0.9590
840	MORGANTH G02	0.0447	0.2573	0.2644	0.0257	22.46	0.020	0.500	3.90	180.0	1.026	-1.59	0.9720
852	POTOMAC G-2	0.1920	1.1050	1.1600	0.0797	4.90	0.020	0.000	6.10	36.0	0.990	-3.93	0.9160
853	POTOMAC G-3	0.1299	1.1990	1.2561	0.0700	4.66	0.020	7.000	5.90	31.0	0.990	-2.97	0.9291
854	POTOMAC G-4	0.1299	1.1990	1.2561	0.0700	4.66	0.020	7.000	5.90	31.0	0.990	-3.85	0.9229
855	POTOMAC G-5	0.1299	1.1990	1.2561	0.0700	4.66	0.020	7.000	5.90	31.0	0.990	-4.65	0.9102
915	D/W 01 GEN	0.1700	1.3210	1.3070	0.1469	3.64	0.020	0.000	6.00	70.0	1.025	-5.82	0.9207
910	D/W 11KV-0	0.1700	1.3210	1.3070	0.1469	3.64	0.020	0.000	6.00	49.0	0.950	-5.13	0.7672
924	ENGLAND01	0.1040	1.0100	1.0400	0.0	6.37	0.0	0.0	0.0	70.0	1.056	-12.13	1.0645
925	ENGLAND02	0.1000	0.8200	0.8300	0.0	6.91	0.0	0.0	0.0	60.0	1.056	-12.94	1.0929
1090	EDGE MOOR 3	0.2290	1.6390	1.7110	0.0900	2.47	0.034	7.262	5.00	27.0	1.000	-5.82	1.0303
1099	EDGE HW 4	0.1290	0.7790	0.8090	0.0700	6.42	0.017	0.342	3.00	80.0	1.000	-6.15	1.0441
1121	EDGE HW 4	0.0710	0.3640	0.3840	0.0340	11.93	0.030	7.520	4.70	60.0	1.000	-5.70	0.9337
1100	EDGE HW 5	0.0570	0.3520	0.3550	0.0320	15.46	0.039	6.264	5.24	79.0	1.000	-7.63	1.0467
1197	OIALBRIS	0.1200	0.1200	0.1200	0.0	10.00	0.0	0.0	0.0	180.0	0.902	5.13	1.1109
1207	OIBELMCH	0.0362	0.2070	0.2170	0.0220	16.44	0.031	7.430	5.00	100.0	1.050	20.24	0.0400
1239	OIFTHART	0.0450	0.2660	0.2770	0.0270	20.25	0.006	13.190	3.00	545.0	1.050	18.69	0.0200
1239	OIFTHART	0.0450	0.2660	0.2770	0.0270	20.25	0.006	13.190	3.00	545.0	1.050	18.69	0.0200
1246	OIHARRIS	0.0459	0.2360	0.2390	0.0204	22.04	0.034	0.190	5.23	900.0	1.050	19.14	0.0414
1246	OIHARRIS	0.0459	0.2360	0.2390	0.0204	22.04	0.034	0.190	5.23	900.0	1.050	19.14	0.0414
1267	OIHITCHE	0.0700	0.0700	0.0700	0.0	11.50	0.0	0.0	0.0	205.0	0.995	9.20	1.0190

* BASE - 100 MVA AND MACHINE TERMINAL BUS VOLTAGE

SYNCHRONOUS ROTOR DATA

BUS	NAME	XPRIND (PU)	XQ (PU)	XD (PU)	XL (PU)	H MVA/MVA	AG	SG	TPRIND	TORQUE (MW)	TERMINAL VOLTAGE MAGNITUDE	ANGLE	SPRING (PU)
1333	04ASHTBL	0.0659	0.0659	0.0659	0.0	22.84	0.0	0.0	0.0	405.0	1.018	6.28	1.2170
1336	04AVOM	0.0562	0.0562	0.0562	0.0	25.57	0.0	0.0	0.0	352.0	1.007	2.73	1.1115
1447	AK 2 3 20	0.1139	0.7732	0.8168	0.0668	3.84	0.043	5.570	4.00	88.1	1.000	-30.79	1.0894
1447	AK 2 3 20	0.1593	0.7301	0.7566	0.0796	15.59	0.021	7.250	5.10	96.9	1.000	-30.79	1.1488
1448	AK 3 3 22	0.0445	0.2848	0.2941	0.0261	22.61	0.021	7.720	4.10	461.0	1.030	-20.44	1.0591
1451	AST 3 3 20	0.1139	0.7723	0.8168	0.0668	3.84	0.043	5.570	4.00	162.8	1.000	-29.43	1.0034
1451	AST 3 3 20	0.1593	0.7301	0.7566	0.0796	15.59	0.022	7.090	5.18	179.2	1.000	-29.43	1.0827
1452	AST 4 3 20	0.0965	0.6454	0.6430	0.0502	5.21	0.030	7.660	6.06	179.9	1.000	-29.64	1.0962
1452	AST 4 3 20	0.1638	0.7930	0.8192	0.1038	16.48	0.007	9.530	5.91	170.1	1.000	-29.64	1.2383
1452	AST 4 3 20	0.0965	0.6454	0.6430	0.0502	5.21	0.048	6.550	5.31	181.4	1.000	-29.57	0.9919
1453	AST 5 3 20	0.1638	0.7930	0.8192	0.1038	16.48	0.041	7.700	5.90	171.6	1.000	-29.57	1.0930
1531	RAV 1 3 20	0.1274	0.7453	0.7783	0.0731	3.39	0.017	7.680	3.60	176.0	1.000	-24.18	1.0263
1531	RAV 1 3 20	0.1364	0.6570	0.6734	0.0640	15.97	0.025	7.490	7.30	196.0	1.000	-24.18	1.0518
1247	01HATFLD	0.0510	0.2910	0.2940	0.0330	24.87	0.020	9.840	5.58	510.0	1.050	17.72	0.9048
1247	01HATFLD	0.0510	0.2910	0.2940	0.0330	24.87	0.020	9.840	5.58	495.0	1.050	17.72	0.9067
1247	01HATFLD	0.0510	0.2910	0.2940	0.0330	24.87	0.020	9.840	5.58	495.0	1.050	17.72	0.9067
1532	RAV 2 3 20	0.0623	0.0623	0.0623	0.0	15.45	0.0	0.0	0.0	378.0	1.000	-24.21	1.1421
1582	PT. JEFF2138	0.0400	0.0400	0.0400	0.0	50.00	0.0	0.0	0.0	947.0	1.018	-6.18	1.1769
1323	15BEAVR	0.0566	0.0566	0.0566	0.0	33.24	0.0	0.0	0.0	1695.0	1.015	19.53	1.0179
1335	04AVOM	0.0428	0.2364	0.2391	0.0285	25.57	0.012	6.990	5.17	650.0	1.000	6.44	1.0364
1341	04EASTLK	0.0331	0.2328	0.2421	0.0205	22.15	0.005	8.500	3.50	650.0	1.000	10.32	0.8748
1342	04EASTLK	0.0331	0.2328	0.2421	0.0205	22.15	0.005	8.500	3.50	611.0	1.025	5.10	1.0096
1430	04PERRY	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1205.0	1.010	11.42	1.1632
1663	ALBY STW3 13	0.0325	0.2535	0.2675	0.0188	19.04	0.017	9.160	5.08	388.0	1.000	-9.51	0.8979
1700	DUNKGEN33 13	0.0794	0.6250	0.6520	0.0428	18.97	0.019	8.620	5.50	218.0	1.000	26.70	0.8768
1701	DUNKGEN43 13	0.0794	0.6250	0.6520	0.0428	18.97	0.019	8.620	5.50	218.0	1.000	26.70	0.8768
1704	DUNK11583 13	0.0965	0.0965	0.0965	0.0	5.90	0.0	0.0	0.0	197.0	1.000	30.23	1.1009
1724	HNTLY23 3 23	0.0623	0.0623	0.0623	0.0	15.45	0.0	0.0	0.0	308.0	1.004	26.99	1.0208
1725	HNTLY6763 13	0.0794	0.6250	0.6520	0.0428	18.97	0.019	8.620	5.50	218.0	1.023	33.06	0.9660
1726	HNTLY6863 13	0.0794	0.6250	0.6520	0.0428	18.97	0.019	8.620	5.50	218.0	1.023	33.10	0.9662
1503	IND PT 23 22	0.0386	0.1750	0.1810	0.0340	46.20	0.023	7.400	6.66	804.0	1.030	-11.17	1.0601
1533	RAV 3 3 22	0.0724	0.3728	0.3758	0.0630	6.90	0.043	7.480	6.53	422.1	1.030	-20.35	1.1341
1533	RAV 3 3 22	0.0548	0.3128	0.3240	0.0500	41.10	0.043	7.480	9.47	457.2	1.030	-20.35	1.1547
1768	OSWEGO 33345	0.0700	0.0700	0.0700	0.0	11.96	0.0	0.0	0.0	840.0	1.055	32.45	1.1617
1768	OSWEGO 33345	0.0546	0.2174	0.2191	0.0232	27.30	0.020	10.010	5.23	840.0	1.055	32.45	1.1412
1835	9H PT 163 23	0.0736	0.2669	0.2839	0.0308	34.80	0.020	7.840	6.70	592.0	1.025	37.89	1.0249
1837	9H PT 73765	0.0311	0.1259	0.1326	0.0165	48.47	0.009	9.365	6.80	1000.0	1.038	36.04	0.9065
1844	BOWLINE 3 20	0.0471	0.2490	0.2540	0.0247	18.97	0.013	3.670	3.40	608.0	1.086	-0.01	0.9541
1879	AST6 GEN3 26	0.0390	0.1917	0.1927	0.0243	27.30	0.027	7.710	4.61	208.0	1.020	-30.36	1.0897
1849	BOWLINE205 20	0.0471	0.2490	0.2540	0.0247	18.97	0.013	3.670	3.40	608.0	1.050	0.68	0.8584
1890	MOSES 1 1115	0.0593	0.1238	0.4038	0.0423	15.18	0.028	8.460	5.00	488.0	1.029	28.95	0.9931
1891	MOSES 2 1230	0.0593	0.1238	0.4038	0.0423	15.18	0.028	8.460	5.00	488.0	1.030	30.40	1.0957
1894	NIAG11542115	0.0444	0.1874	0.1874	0.0314	25.62	0.026	8.450	5.08	487.0	1.052	28.68	1.1454
1916	SINMA1152115	0.0400	0.0400	0.0400	0.0	28.00	0.0	0.0	0.0	468.8	1.035	22.37	1.1237
1952	NFLD 1-22 13	0.1106	0.2934	0.4170	0.0851	21.38	0.040	6.820	11.00	193.2	1.043	-1.54	1.2239
1963	LAKEVIEW1 18	0.0300	0.0300	0.0300	0.0	63.00	0.0	0.0	0.0	1663.0	1.050	35.89	1.2663
1979	DANSKAMA2115	0.0623	0.0623	0.0623	0.0	15.45	0.0	0.0	0.0	332.8	1.020	-14.02	1.1125
1881	CHAT 7651765	0.0458	0.0458	0.0458	0.0	47.80	0.0	0.0	0.0	880.0	1.050	32.34	1.2147
2116	POSSLM	0.0623	0.0623	0.0623	0.0	15.45	0.0	0.0	0.0	30.0	1.000	-8.59	1.0253
2117	POSSLM	0.0623	0.0623	0.0623	0.0	15.45	0.0	0.0	0.0	290.0	1.000	-6.88	1.0877

* BASE - 100 MVA AND MACHINE TERMINAL BUS VOLTAGE

SYNCHRONOUS ROTOR DATA

BUS	NAME	XPRIND (PU)	XR (PU)	XD (PU)	XL (PU)	H MVA/MVA	AG	BB	TWRINGO	TORQUE (MW)	TERMINAL MAGNITUDE	VOLTAGE ANGLE	EPRIND (PU)
1662	FITZ 3451345	0.0400	0.1900	0.2020	0.0232	43.50	0.011	8.500	7.00	821.0	1.045	31.52	1.0128
1573	YORKTOWN	0.0752	0.7320	0.7320	0.0	7.60	0.0	0.0	0.0	66.0	1.003	-12.07	1.0525
1574	YORKTOWN	0.0752	0.7320	0.7320	0.0	7.60	0.0	0.0	0.0	101.0	1.000	-14.37	1.0083
2151	OZSANSFL	0.0177	0.0177	0.0177	0.0	61.64	0.0	0.0	0.0	2475.0	1.015	19.45	1.1868
2156	OZSANSIS	0.0205	0.0205	0.0205	0.0	84.60	0.0	0.0	0.0	1900.0	1.015	18.25	1.1403
2165	Q3DAV-DE	0.0440	0.0440	0.0440	0.0	46.10	0.0	0.0	0.0	904.0	1.015	6.56	1.1650
2172	BRUNSW 2	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	790.0	1.000	-2.12	1.0790
2207	MARSHALL	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	332.0	1.010	3.03	1.0287
2207	MARSHALL	0.0300	0.0300	0.0300	0.0	500.00	0.0	0.0	0.0	1320.0	1.010	3.03	1.1234
2210	OCONEE 2	0.0300	0.0300	0.0300	0.0	500.00	0.0	0.0	0.0	1400.0	1.000	8.32	1.1560
2210	OCONEE 2	0.0250	0.0250	0.0250	0.0	90.00	0.0	0.0	0.0	372.0	1.000	8.32	1.0183
2236	STUART	0.0050	0.0050	0.0050	0.0	1150.00	0.0	0.0	0.0	777.0	1.025	11.00	1.0428
2237	06CLIFTY	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	104.0	1.026	15.23	1.0195
2237	06CLIFTY	0.0050	0.0050	0.0050	0.0	1150.00	0.0	0.0	0.0	1654.0	1.026	15.23	1.0184
2285	19FERMI	0.0050	0.0050	0.0050	0.0	1150.00	0.0	0.0	0.0	983.7	1.025	8.64	1.0299
2285	19FERMI	0.0320	0.0320	0.0320	0.0	67.33	0.0	0.0	0.0	109.3	1.025	8.64	1.0283
2290	17SC 67	0.0400	0.0400	0.0400	0.0	46.36	0.0	0.0	0.0	780.0	1.030	7.08	1.2136
2340	05JE AND	0.0187	0.0187	0.0187	0.0	91.22	0.0	0.0	0.0	1700.0	0.900	10.47	1.1078
1803	GILB 3451345	0.0225	0.0542	0.0042	0.0142	74.40	0.020	7.070	15.00	996.0	1.035	2.04	1.1065
1805	IND PT 33 22	0.0306	0.1750	0.1810	0.0340	46.20	0.023	7.400	6.66	1033.0	1.030	-10.37	1.1032
1892	NIAG 2301230	0.0400	0.0400	0.0400	0.0	50.00	0.0	0.0	0.0	974.0	1.035	28.58	1.2189
1893	NIAG11SE2115	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	650.0	1.052	26.89	1.2212
2349	05JE AND	0.0300	0.0300	0.0300	0.0	80.00	0.0	0.0	0.0	18.0	1.013	15.19	1.0129
2349	05JE AND	0.0050	0.0050	0.0050	0.0	1150.00	0.0	0.0	0.0	162.0	1.013	15.19	1.0129
2353	OSKAPFER	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	700.0	1.000	16.72	1.1221
2354	OSKAPFER	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	700.0	0.975	17.47	1.0423
2361	OSHOUNTH	0.0350	0.0350	0.0350	0.0	80.00	0.0	0.0	0.0	130.0	0.980	20.70	0.9659
2361	OSHOUNTH	0.0050	0.0050	0.0050	0.0	1150.00	0.0	0.0	0.0	1170.0	0.980	20.70	0.9622
2002	ROSETON 1345	0.0590	0.2600	0.2796	0.0434	19.47	0.017	7.600	4.00	1200.0	1.020	-4.12	0.9369
2379	OSTANER	0.0400	0.0400	0.0400	0.0	20.00	0.0	0.0	0.0	552.0	1.010	9.44	0.9506
2016	BATH COU	0.0300	0.0300	0.0300	0.0	63.00	0.0	0.0	0.0	1040.0	1.050	15.50	1.1910
2032	CHESTERP	0.0357	0.2130	0.2220	0.0240	24.45	0.020	8.200	4.00	991.0	1.009	-4.57	0.8011
2099	NOR ANNA	0.0432	0.1550	0.1590	0.0219	32.80	0.013	9.450	6.00	616.4	1.043	2.41	0.9090
2099	NOR ANNA	0.0432	0.1550	0.1590	0.0219	32.80	0.013	9.450	6.00	616.4	1.043	2.41	0.9890
2099	NOR ANNA	0.0433	0.1570	0.1600	0.0231	41.50	0.013	9.250	5.90	635.1	1.043	2.41	0.9856
1501	SLEERY 23	0.0435	0.1753	0.1805	0.0221	24.10	0.020	7.500	6.71	775.0	1.017	-5.77	1.0532
1502	SLEERY 50	0.0435	0.1753	0.1805	0.0221	24.10	0.020	7.500	6.71	775.0	1.035	-3.47	0.9366
2010	RAN RVR 1150	0.0734	0.3395	0.3530	0.0561	10.17	0.024	7.513	4.73	38.0	1.025	-16.10	1.0405
2164	03BAYSHO	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	590.0	0.995	0.52	1.0872
2171	BRUNSW 1	0.0300	0.0300	0.0300	0.0	52.00	0.0	0.0	0.0	790.0	1.000	-1.90	1.0527
2178	RAYO	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	720.0	1.020	4.22	0.9971
2178	ROB 030	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	660.0	1.020	-9.46	1.1417
2179	ROK SE	0.0200	0.0200	0.0200	0.0	120.00	0.0	0.0	0.0	2495.0	1.020	4.53	1.2077
2202	BELENS C	0.0200	0.0200	0.0200	0.0	120.00	0.0	0.0	0.0	2200.0	1.010	3.70	1.1918
2203	CATAMBA	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1145.0	1.010	0.36	1.2630
2206	JOCASSEE	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	610.0	1.001	8.13	1.1182
2208	MCBUIRE	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1280.0	1.010	1.81	1.2047
2209	MCBUIRE	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1100.0	1.042	4.72	1.2093
2211	OCONEE 5	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	860.0	1.040	8.77	1.1665
2210	A.H.WILL	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	500.0	1.030	-16.00	1.1727

* BASE - 100 MVA AND MACHINE TERMINAL BUS VOLTAGE

SYNCHRONOUS ROTOR DATA

BUS	NAME	X/RIPD (PU)	X _D (PU)	X _D (PU)	X _L (PU)	H MVA/MVA	AG	BG	TPRIPD	TORQUE (MW)	TERMINAL MAGNITUDE	VOLTAGE ANGLE	EPRIPD (PU)
2221	SURMER	0.0400	0.0400	0.0400	0.0	50.00	0.0	0.0	0.0	900.0	1.040	-3.50	1.1201
2223	WATEREE	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	700.0	1.030	-7.17	1.1432
2230	MINYAM	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	800.0	1.040	-9.97	1.1211
2236	OKYGER	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1020.0	1.001	13.07	1.1784
2248	16CHESMC	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	562.0	1.008	8.11	1.1079
2283	18LUOING	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1510.0	1.049	16.56	1.1502
2286	19TOMR12	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1500.0	1.030	8.64	1.2600
2287	19MCP34	0.0350	0.0350	0.0350	0.0	60.00	0.0	0.0	0.0	1300.0	1.030	7.95	1.2493
2326	05DC COO	0.0397	0.0397	0.0397	0.0	51.60	0.0	0.0	0.0	420.0	1.000	7.75	0.9871
2326	05DC COO	0.0397	0.0397	0.0397	0.0	99.70	0.0	0.0	0.0	630.0	1.000	7.75	0.9914
2327	05DC COO	0.0320	0.0320	0.0320	0.0	67.00	0.0	0.0	0.0	1050.0	1.030	6.75	1.1336
2339	05FM BAK	0.0390	0.0390	0.0390	0.0	28.50	0.0	0.0	0.0	850.0	1.010	17.17	1.0580
2341	05SAVIN	0.0170	0.0170	0.0170	0.0	104.00	0.0	0.0	0.0	2600.0	0.980	20.75	1.0878
2296	KAMPER 1	0.0450	0.0450	0.0450	0.0	45.00	0.0	0.0	0.0	420.0	1.009	14.00	1.1104
2380	05TID0	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	500.0	1.004	16.01	1.1090
2381	05TID0	0.0500	0.0500	0.0500	0.0	40.00	0.0	0.0	0.0	600.0	1.010	16.19	1.0540
1203	01ARMSTR	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	300.0	1.005	8.40	1.0768
1626	MILLIKEN2115	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	221.8	1.052	12.36	1.1169
1732	HUNTLING 13	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	273.0	1.007	28.17	1.1104
1786	ROTRON 13115	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	200.0	1.000	-6.06	1.1571
1856	LOVETT 13118	0.0600	0.0600	0.0600	0.0	15.00	0.0	0.0	0.0	371.0	1.020	-17.15	1.0900
1964	L3JP PS 1230	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	200.0	1.030	31.17	1.0201
1965	L3JP PS 1230	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	200.0	1.030	31.17	1.0201
2022	BREMO	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	201.0	1.000	10.53	1.0054
2076	KERR	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	200.0	1.000	-2.98	1.0020
2182	SUT 230	0.0600	0.0600	0.0600	0.0	15.00	0.0	0.0	0.0	371.0	1.000	-5.86	1.0535
2191	ASH SE	0.0600	0.0600	0.0600	0.0	15.00	0.0	0.0	0.0	392.0	1.010	1.64	1.1019
2200	ALLEN	0.0600	0.0600	0.0600	0.0	15.00	0.0	0.0	0.0	408.0	1.041	-2.33	1.1801
2201	ALLEN 23	0.0500	0.0500	0.0500	0.0	20.00	0.0	0.0	0.0	472.0	1.006	-0.02	1.1299
2205	HARTWELL	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	300.0	1.000	3.37	1.1225
2219	CANADY	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	300.0	1.030	-15.39	1.0953
2220	FAIRPIEL	0.0500	0.0500	0.0500	0.0	15.00	0.0	0.0	0.0	400.0	1.041	-3.39	1.2020
2222	URGUMART	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	200.0	1.020	-11.28	1.1039
2229	CLARK HL	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	300.0	1.009	-4.61	1.0299
2316	OSBREED	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	300.0	1.049	12.69	1.0525
2363	OSRUSKING	0.0500	0.0500	0.0500	0.0	20.00	0.0	0.0	0.0	468.0	1.000	12.21	1.0961
2370	OSROCKPR	0.0600	0.0600	0.0600	0.0	15.00	0.0	0.0	0.0	390.0	1.015	16.35	1.0413
2376	05SPKAI	0.0700	0.0700	0.0700	0.0	10.00	0.0	0.0	0.0	350.0	1.054	13.36	1.0078

* BASE - 100 MVA AND MACHINE TERMINAL BUS VOLTAGE

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	KA	TA	VAMAX	VAMIN	KE	TE	TSE	AEX	BEX
396	EDDYSTG1	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
396	EDDYSTG1	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
397	EDDYSTG2	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.044	0.566	1.000	0.001600	1.465
397	EDDYSTG2	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.044	0.566	1.000	0.001600	1.465
343	CCW97-13	6	NO-C-ACT	0.05	0.0	4.00	0.0	1.000	1.918	0.0	0.005200	1.555
1117	IND RIV 1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1120	IND RIV 3	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1086	DELA CITY 1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1087	DELA CITY 2	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	CCLIF G1 500	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.037	0.278	0.952	0.005000	1.178
7	CCLIF G2 500	5	MAGN-AMP	400.00	0.02	6.08	-6.08	1.000	0.960	1.000	0.014200	1.600
10	CONEMAUGHG1	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.061	0.640	1.045	0.000100	2.460
10	CONEMAUGHG1	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.065	0.640	1.496	0.000100	2.605
126	CONEMAUGHG2	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.061	0.690	1.045	0.000100	2.460
126	CONEMAUGHG2	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.065	0.640	1.496	0.000100	2.605
17	KEYSTONE G1	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
17	KEYSTONE G1	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
125	KEYSTONE G2	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
125	KEYSTONE G2	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
20	PCH 8T82	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.064	0.665	1.378	0.000094	2.580
25	SALEM G1	5	MAGN-AMP	400.00	0.02	9.55	-9.55	-1.000	1.000	1.000	0.059000	1.100
26	SALEM G2	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.061	0.577	1.000	0.000105	2.430
38	HOPE CREEK	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.060	0.569	1.000	0.059000	1.100
55	ERIE SQ. 115	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
74	HOMER CTY 18	5	MAGN-AMP	400.00	0.02	7.55	-7.55	1.000	0.790	1.000	0.342785	0.595
73	HOMER CTY G3	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.063	0.626	1.020	0.000100	2.650
99	SENECA GEN	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
101	SEWARD 115	5	MAGN-AMP	150.00	0.15	3.50	-3.50	1.000	0.0	1.000	0.0	0.0
104	SHAMVIL G230	5	MAGN-AMP	150.00	0.15	5.50	-5.50	1.000	0.0	1.000	0.0	0.0
104	SHAMVIL G230	5	MAGN-AMP	150.00	0.15	5.50	-5.50	1.000	0.0	1.000	0.0	0.0
106	SHAMVILLE 18	5	MAGN-AMP	150.00	0.15	4.40	-4.40	1.000	0.0	1.000	0.0	0.0
106	SHAMVILLE 18	5	MAGN-AMP	150.00	0.15	4.40	-4.40	1.000	0.0	1.000	0.0	0.0
164	PORTLND G115	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.567	0.350	0.001643	1.663
164	PORTLND G115	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.059	0.668	0.350	0.001643	1.958
165	PORTLND G230	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.559	0.350	0.001643	1.638
165	PORTLND G230	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.567	0.350	0.001643	1.661
205	OYSTR CK GEN	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.027	0.253	1.000	0.005828	1.083
220	YARDS CK GEN	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.050	0.565	1.000	0.001643	1.654
236	BRUNNER1 100	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.176	0.984	1.000	0.003900	1.605
237	BRUNNER2 100	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.173	0.975	1.000	0.003900	1.590
238	BRUNNER3 100	5	MAGN-AMP	80.50	0.06	1.00	-1.00	-0.045	0.518	1.000	0.001600	1.498
283	MONTOUR1 100	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.043	0.484	0.968	0.001600	1.424
284	MONTOUR2 100	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.042	0.472	0.968	0.001600	1.390
289	MTN CRK1 100	3	AMPLDYNE	39.00	0.20	1.00	-1.00	-0.057	0.639	0.350	0.001600	1.870
290	MTN CRK2 100	3	AMPLDYNE	41.50	0.20	1.00	-1.00	-0.056	0.635	0.350	0.001600	1.850
327	SUSQUEH1 100	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.047	0.525	1.320	0.001600	1.522
342	LIM G1-22	5	MAGN-AMP	400.00	0.02	1.00	-1.00	-0.059	0.559	1.260	0.000147	2.374
385	CROFTYG1	5	MAGN-AMP	25.00	0.02	1.00	-1.00	-0.045	0.500	0.340	0.001600	1.445
221	MUDDYRN1.2	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
222	MUDDYRN3.4	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	KA	TA	VAMAX	VAMIN	KE	TE	TSE	AEX	BEX
223	MUDDYRNS.6	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
224	MUDDYRNS.8	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
575	BERGEN 138	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
575	BERGEN 138	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
584	BURLINGTN GEN	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
619	HUDSON G1	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.555
620	HUDSON G2	5	MAGN-AMP	400.00	0.02	8.20	-8.20	1.000	1.300	1.000	0.059000	1.000
641	LINDEN GEN	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
641	LINDEN GEN	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
655	MERCER G1	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
655	MERCER G1	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
656	MERCER G2	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
656	MERCER G2	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
683	SEWAREN 138	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
683	SEWAREN 138	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
767	ZCRANEGL 115	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.044	0.519	0.350	0.001600	1.522
786	ZHAG G3 115	5	MAGN-AMP	400.00	0.05	3.50	-3.50	-0.170	0.950	1.000	0.003900	1.560
828	CHALK PT G11	5	MAGN-AMP	39.00	0.28	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
828	CHALK PT G11	5	MAGN-AMP	39.00	0.28	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
829	CHALK PT G12	5	MAGN-AMP	39.00	0.28	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
829	CHALK PT G12	5	MAGN-AMP	39.00	0.28	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
830	CHALK PT G13	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.062	0.589	1.020	0.000097	2.501
831	CHALK PT G14	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.062	0.589	1.020	0.000097	2.501
833	DICKERSH G11	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
833	DICKERSH G11	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
834	DICKERSH G12	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
834	DICKERSH G12	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
835	DICKERSH G13	3	MAGN-AMP	34.50	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
835	DICKERSH G13	3	MAGN-AMP	34.50	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.465
839	DICKERSH G13	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
839	DICKERSH G13	3	AMPLDYNE	34.25	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
839	MORGANTH G11	5	MAGN-AMP	40.00	0.02	7.30	-7.30	1.000	0.800	1.000	0.120000	0.855
840	MORGANTH G12	5	MAGN-AMP	40.00	0.02	7.30	-7.30	1.000	0.800	1.000	0.120000	0.855
852	POTOMAC G-2	6	NO-C-ACT	0.05	0.0	1.00	0.0	0.051	0.500	1.000	0.001050	1.465
853	POTOMAC G-3	6	NO-C-ACT	0.05	0.0	1.00	0.0	0.051	0.500	1.000	0.001050	1.465
854	POTOMAC G-4	6	NO-C-ACT	0.05	0.0	1.00	0.0	0.051	0.500	1.000	0.001050	1.465
855	POTOMAC G-5	6	NO-C-ACT	0.05	0.0	1.00	0.0	0.051	0.500	1.000	0.001050	1.465
915	D/W #1 GEN	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
918	D/W 11KV-0	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
924	ENGLAND#1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
925	ENGLAND#2	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1098	EDGE #00R 3	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.465
1099	EDGE #W 4	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.044	0.500	1.000	0.001600	1.460
1121	IND RIV 4	3	AMPLDYNE	400.00	0.01	11.10	-2.60	1.000	0.410	0.160	2.150000	0.270
1160	EDGE #W 5	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1207	OIEELTON	0	ROTARECT	500.00	0.01	6.40	-6.40	1.000	0.250	0.0	0.537000	0.120
1239	OIFTHART	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.044	0.514	1.000	0.001200	1.250
1239	OIFTHART	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.044	0.514	1.000	0.001200	1.250
1246	OIHARRIS	5	MAGN-AMP	400.00	0.02	8.45	-8.45	1.000	1.535	1.000	0.167000	0.432
1246	OIHARRIS	5	MAGN-AMP	400.00	0.02	8.45	-8.45	1.000	1.535	1.000	0.167000	0.432
1447	AK 2 3 20	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.050	0.570	0.350	0.001700	1.660
1447	AK 2 3 20	5	MAGN-AMP	25.00	0.20	1.00	-1.00	-0.050	0.570	0.350	0.001700	1.660

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	KA	TA	VAMAX	VAMIN	KE	TE	TSE	AEX	BEX
1448	AK 3	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.570	0.350	0.017500	1.290
1451	AST 3	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.570	0.200	0.001900	1.610
1451	AST 3	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.520	0.200	0.001500	1.540
1452	AST 4	3	MAGN-AMP	150.00	0.20	2.40	-2.40	0.290	0.800	0.500	0.000874	1.990
1452	AST 4	3	MAGN-AMP	150.00	0.20	2.72	-2.72	0.240	0.830	0.500	0.002365	1.630
1453	AST 5	3	MAGN-AMP	150.00	0.20	2.40	-2.40	0.350	0.760	0.500	0.000460	2.270
1453	AST 5	3	MAGN-AMP	150.00	0.20	2.72	-2.72	0.260	0.830	0.500	0.001700	1.670
1531	RAV 1	3	MAGN-AMP	41.00	0.10	1.00	-1.00	-0.050	0.540	1.000	0.001500	1.540
1531	RAV 1	3	MAGN-AMP	55.00	0.10	1.00	-1.00	-0.050	0.540	1.000	0.001290	1.640
1247	01HATFLD	5	MAGN-AMP	400.00	0.02	6.45	-6.45	1.000	0.733	1.000	0.218000	0.313
1247	01HATFLD	5	MAGN-AMP	400.00	0.02	6.45	-6.45	1.000	0.733	1.000	0.218000	0.313
1247	01HATFLD	5	MAGN-AMP	400.00	0.02	6.45	-6.45	1.000	0.733	1.000	0.218000	0.313
1335	04AVCN	5	MAGN-AMP	400.00	0.02	8.81	-8.81	1.000	0.940	1.000	0.167000	0.700
1341	04EASTLK	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.055	0.253	0.617	0.005800	1.060
1342	04EASTLK	5	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.055	0.253	0.617	0.005800	1.060
1663	ALBY STM3	13	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.060	0.500	0.350	0.001636	2.016
1700	DUNKGENH3	13	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.500	0.350	0.001636	1.666
1701	DUNKGENH3	13	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.500	0.350	0.001636	1.666
1725	HNTLY67G3	13	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.500	0.350	0.001636	1.666
1726	HNTLY68G3	13	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.050	0.500	0.350	0.001636	1.666
1503	IND PT 23	22	MAGN-AMP	400.00	0.02	11.10	-11.10	1.000	1.430	1.000	0.003900	1.555
1533	RAV 3	3	MAGN-AMP	160.00	0.22	3.00	-3.00	0.257	0.422	0.280	0.001600	1.670
1533	RAV 3	3	MAGN-AMP	160.00	0.22	3.00	-3.00	0.205	0.422	0.280	0.001600	1.670
1768	OSWEGO 33345	5	MAGN-AMP	400.00	0.03	5.90	-5.90	1.000	0.770	1.000	0.094400	0.825
1835	9H PT 163	23	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.050	0.500	1.000	0.001111	1.473
1837	9H PT 73765	5	MAGN-AMP	400.00	0.03	7.85	-7.85	1.000	1.190	1.000	0.021916	1.532
1844	DOMLINE 3	20	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.044	0.500	1.030	0.001600	1.455
1879	AST6 GEN3	26	AMPLDYNE	400.00	0.03	5.90	0.0	1.000	0.733	1.000	0.092100	0.837
1845	SCHLIN203	20	MAGN-AMP	50.00	0.02	1.00	-1.00	-0.044	0.500	1.030	0.001600	1.455
1890	MOSES 1	1115	AMPLDYNE	16.50	0.20	1.00	-1.00	-0.037	0.250	1.000	0.005800	1.150
1891	MOSES 2	1230	AMPLDYNE	16.50	0.20	1.00	-1.00	-0.037	0.250	1.000	0.005800	1.150
1894	MIAB115M2115	3	AMPLDYNE	23.10	0.20	1.00	-1.00	-0.044	0.500	0.350	0.001600	1.000
1952	NPLD 1+22	13	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.050	0.379	1.000	0.005370	1.613
1882	FITZ 3451345	5	MAGN-AMP	50.00	0.20	1.00	-1.00	0.052	0.570	1.594	0.001700	1.260
1573	YORKTOWN	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1574	YORKTOWN	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1863	GILB 3451345	3	AMPLDYNE	50.00	0.06	1.00	-1.00	-0.044	0.327	1.000	0.005800	1.060
1885	IND PT 33	22	MAGN-AMP	400.00	0.02	11.10	-11.10	1.000	1.430	1.000	0.003900	1.555
2002	ROSETON 1345	3	AMPLDYNE	50.00	0.02	1.00	-1.00	-0.053	0.500	0.350	0.005800	1.200
2032	CHESTERP	5	MAGN-AMP	50.00	0.06	1.00	-1.00	-0.044	0.500	1.000	0.001630	1.593
2099	NOR ANNA	5	MAGN-AMP	400.00	0.03	7.89	-7.89	1.000	1.110	1.000	0.051000	1.137
2099	NOR ANNA	5	MAGN-AMP	400.00	0.03	7.89	-7.89	1.000	1.110	1.000	0.051000	1.137
2099	NOR ANNA	5	MAGN-AMP	400.00	0.03	7.45	-7.45	1.000	1.230	1.000	0.040200	1.204
1541	SURRY 23	5	MAGN-AMP	400.00	0.02	6.89	-6.89	1.000	0.940	1.000	0.016230	1.411
1542	SURRY 50	5	MAGN-AMP	400.00	0.02	6.89	-6.89	1.000	0.940	1.000	0.016230	1.411
2010	RAR RVR 1150	3	AMPLDYNE	25.00	0.20	1.00	-1.00	-0.060	0.677	0.350	0.001643	1.985

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	HJ	KG	KQ1	KQ2	TQ	KP	KI	BMS	VAG
396	EDDYSTG1	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
396	EDDYSTG1	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
397	EDDYSTG2	3	AMPLDYNE	0.091	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
397	EDDYSTG2	3	AMPLDYNE	0.091	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
343	CONIG7-13	6	NO-C-ACT	0.0	1.000	0.0	0.0	20.00	0.0	0.0	1.0000	0.0
1117	IND RIV 1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1129	IND RIV 3	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1086	DELA CITY 1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1087	DELA CITY 2	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	CCLIF G1 500	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
7	CCLIF G2 500	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
10	CONEMAUGHG1	5	MAGN-AMP	0.097	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
10	CONEMAUGHG1	5	MAGN-AMP	0.097	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
126	CONEMAUGHG2	5	MAGN-AMP	0.097	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
126	CONEMAUGHG2	5	MAGN-AMP	0.097	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17	KEYSTONE G1	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17	KEYSTONE G1	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125	KEYSTONE G2	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125	KEYSTONE G2	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20	PCN BTG2	5	MAGN-AMP	0.070	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
25	SALEM G1	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.00	0.0	0.0	1.0000	0.0
26	SALEM G2	5	MAGN-AMP	0.092	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
38	HOPE CREEK	5	MAGN-AMP	0.091	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
55	ERIE SO. 113	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
74	HOWER CTY 18	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
73	HOWER CTY G3	5	MAGN-AMP	0.090	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
49	SENECA GEN	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
101	SEWARD 115	5	MAGN-AMP	0.001	1.000	0.0	0.0	1.00	0.0	0.0	0.0	0.0
104	SHANVIL G230	5	MAGN-AMP	0.001	1.000	0.0	0.0	1.00	0.0	0.0	0.0	0.0
104	SHANVIL G230	5	MAGN-AMP	0.001	1.000	0.0	0.0	1.00	0.0	0.0	0.0	0.0
106	SHANVILLE 18	5	MAGN-AMP	0.001	1.000	0.0	0.0	1.00	0.0	0.0	0.0	0.0
106	SHANVILLE 18	5	MAGN-AMP	0.001	1.000	0.0	0.0	1.00	0.0	0.0	0.0	0.0
164	PORTLAND G115	3	AMPLDYNE	0.259	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
164	PORTLAND G115	3	AMPLDYNE	0.305	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
165	PORTLAND G230	3	AMPLDYNE	0.089	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
165	PORTLAND G230	3	AMPLDYNE	0.091	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
205	OYSTR CK GEN	5	MAGN-AMP	0.041	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
220	YARDS CK GEN	5	MAGN-AMP	0.090	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
236	BRUNNER1 100	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.01	0.0	0.0	0.0	0.0
237	BRUNNER2 100	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.01	0.0	0.0	0.0	0.0
236	BRUNNER3 100	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.01	0.0	0.0	0.0	0.0
283	MONTGOM1 100	5	MAGN-AMP	0.081	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
284	MONTGOM2 100	5	MAGN-AMP	0.078	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
289	MTH CRK1 100	3	AMPLDYNE	0.150	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
290	MTH CRK2 100	3	AMPLDYNE	0.156	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
327	SUSQUHMI 100	5	MAGN-AMP	0.069	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
342	LIN G1-22	5	MAGN-AMP	0.070	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
385	CROFTS1	5	MAGN-AMP	0.230	1.000	101.00	0.0	0.06	0.0	0.0	0.0	0.0
221	MUDDYRN1.2	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
222	MUDDYRN3.4	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	KU	KG	KQ1	KQ2	TQ	KP	KI	SPD	VAD
223	MUDDYRNS.6	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
224	MUDDYRNS.2	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
575	BERGEN 138	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
575	BERGEN 138	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
584	BURLINGTN GEN	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
619	HUOSON G1	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
620	HUOSON G2	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
641	LINDEN GEN	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
641	LINDEN GEN	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
655	MERCER G1	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
655	MERCER G1	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
656	MERCER G2	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
656	MERCER G2	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
663	SEWAREN 138	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
663	SEWAREN 138	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
767	ZCRANEGL 115	3	AMPLDYNE	0.239	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
786	ZHAG G3 115	5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
828	CHALK PT G#1	5	MAGN-AMP	0.051	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
828	CHALK PT G#1	5	MAGN-AMP	0.051	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
829	CHALK PT G#2	5	MAGN-AMP	0.051	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
829	CHALK PT G#2	5	MAGN-AMP	0.051	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
830	CHALK PT G#3	5	MAGN-AMP	0.092	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
831	CHALK PT G#4	5	MAGN-AMP	0.092	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
833	DICKERSN G#1	3	AMPLDYNE	0.157	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
833	DICKERSN G#1	3	AMPLDYNE	0.168	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
834	DICKERSN G#2	3	AMPLDYNE	0.157	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
834	DICKERSN G#2	3	AMPLDYNE	0.168	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
835	DICKERSN G#3	5	MAGN-AMP	0.055	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
835	DICKERSN G#3	3	AMPLDYNE	0.168	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
839	MORGANTN G#1	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
840	MORGANTN G#2	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
852	POTOMAC G-2	6	NO-C-ACT	0.0	1.000	0.0	0.0	20.00	0.0	0.0	1.0000	0.0
853	POTOMAC G-3	6	NO-C-ACT	0.0	1.000	0.0	0.0	20.00	0.0	0.0	1.0000	0.0
854	POTOMAC G-4	6	NO-C-ACT	0.0	1.000	0.0	0.0	20.00	0.0	0.0	1.0000	0.0
855	POTOMAC G-5	6	NO-C-ACT	0.0	1.000	0.0	0.0	20.00	0.0	0.0	1.0000	0.0
915	O/W G1 GEN	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
918	O/W 11KV-0	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
924	ENGLAND#1	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
925	ENGLAND#2	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1096	EDGE MR 3	3	AMPLDYNE	0.230	1.000	0.0	0.0	0.06	0.0	0.0	0.0	0.0
1099	EDGE MR 4	5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1121	IND RIV 4	3	AMPLDYNE	0.094	1.000	0.0	0.0	0.01	0.0	0.0	1.0000	0.0
1100	EDGE MR 5	1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1207	OIBELNOM	8	ROTARECT	0.035	1.000	0.0	0.0	0.01	0.2500	0.9000	1.0000	0.0
1239	OIFTHART	5	MAGN-AMP	0.082	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
1239	OIFTHART	5	MAGN-AMP	0.082	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
1246	OIHARRIS	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
1246	OIHARRIS	5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	0.0	1.0000	0.0
1447	AK 2 3 20	5	MAGN-AMP	0.260	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1447	AK 2 3 20	5	MAGN-AMP	0.237	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0

EXCITATION SYSTEM DATA

MACHINE	NAME	TYPE	NAME	MJ	K0	K01	K02	T0	KP	KI	SMO	VAG
1448	AK 3	3 22	3	AMPLDYNE	0.004	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1451	AST 3	3 20	3	AMPLDYNE	0.255	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1451	AST 3	3 20	3	AMPLDYNE	0.415	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1452	AST 4	3 20	5	MAGN-AMP	0.100	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1452	AST 4	3 20	5	MAGN-AMP	0.100	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1453	AST 5	3 20	5	MAGN-AMP	0.100	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1453	AST 5	3 20	5	MAGN-AMP	0.100	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1531	RAV 1	3 20	5	MAGN-AMP	0.087	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1531	RAV 1	3 20	5	MAGN-AMP	0.086	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1247	01HATFLD		5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1247	01HATFLD		5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1247	01HATFLD		5	MAGN-AMP	0.040	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1335	04AVON		5	MAGN-AMP	0.030	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1341	04EASTLK		5	MAGN-AMP	0.087	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1342	04EASTLK		5	MAGN-AMP	0.087	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1663	A1BY 5TH3 13		3	AMPLDYNE	0.229	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1700	DUNKGEN33 13		3	AMPLDYNE	0.229	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1701	DUNKGEN43 13		3	AMPLDYNE	0.229	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1725	HNTL767G3 13		3	AMPLDYNE	0.229	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1726	HNTL760G3 13		3	AMPLDYNE	0.229	1.000	0.0	0.0	0.06	0.0	0.0	0.0
1503	IND PT 23 22		5	MAGN-AMP	0.030	1.000	101.00	0.0	0.0	0.0	0.0	0.0
1533	RAV 3	3 22	5	MAGN-AMP	0.043	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1533	RAV 3	3 22	5	MAGN-AMP	0.043	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1760	OSWEGO 33345		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1835	9H PT 183 23		5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1837	9H PT 73765		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1844	BOWLINE 3 20		5	MAGN-AMP	0.089	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1879	AST6 GEN3 26		3	AMPLDYNE	0.060	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1845	BOWLIN203 20		5	MAGN-AMP	0.089	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1890	MOSES 1 1115		3	AMPLDYNE	0.060	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1891	MOSES 2 1230		3	AMPLDYNE	0.060	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1894	NIAG115M2115		3	AMPLDYNE	0.060	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1952	NFLD 1+22 13		5	MAGN-AMP	0.061	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1882	FITZ 3451345		5	MAGN-AMP	0.058	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1573	YORKTOWN		1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1574	YORKTOWN		1	FLUXLINK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1603	GILB 3451345		3	AMPLDYNE	0.052	1.000	0.0	0.0	0.0	0.0	0.0	0.0
1685	IND PT 33 22		5	MAGN-AMP	0.030	1.000	101.00	0.0	0.0	0.0	0.0	0.0
2002	ROSETON 1345		3	AMPLDYNE	0.050	1.000	0.0	0.0	0.0	0.0	0.0	0.0
2032	CHESTERP		5	MAGN-AMP	0.080	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
2099	MOR ANNA		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
2099	MOR ANNA		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
2099	MOR ANNA		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1541	SURRY 23		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
1542	SURRY 50		5	MAGN-AMP	0.060	1.000	0.0	0.0	0.0	0.0	1.0000	0.0
2010	RAV RVR 1150		3	AMPLDYNE	0.100	1.000	0.0	0.06	0.0	0.0	0.0	0.0

GOVERNOR SYSTEM DATA

BUS	NAME	TYPE	NAME	L/FR	THAX	T3	T4	0	T3	TC	T5	012
396	EDDYSTG1	2	GOVERNOR	0.4458	160.00	0.0	2.86	2.22	0.20	0.39	13.10	0.0
396	EDDYSTG1	2	GOVERNOR	0.5600	201.00	0.0	2.86	-2.80	0.20	0.39	13.10	0.0
397	EDDYSTG2	2	GOVERNOR	0.5570	196.00	0.0	2.29	2.78	0.20	0.36	13.10	0.0
397	EDDYSTG2	2	GOVERNOR	0.5570	196.00	0.0	2.29	2.78	0.20	0.36	13.10	0.0
343	CONO7-13	2	GOVERNOR	0.3330	44.00	11.00	-2.00	0.40	13.57	0.50	1.00	0.0
6	CCLIF G1 500	2	GOVERNOR	2.9400	913.00	0.0	0.90	14.42	0.20	0.79	3.25	0.0
10	CONEMALSHG1	2	GOVERNOR	1.4591	457.00	0.0	4.45	7.69	0.20	0.42	8.00	54.16
10	CONEMALSHG1	2	GOVERNOR	1.3469	423.00	0.0	0.0	6.98	0.20	0.42	8.00	-71.92
126	CONEMALSHG2	2	GOVERNOR	1.4591	457.00	0.0	4.45	7.69	0.20	0.42	8.00	54.16
126	CONEMALSHG2	2	GOVERNOR	1.3469	423.00	0.0	0.0	6.98	0.20	0.42	8.00	-71.92
17	KEYSTONE G1	2	GOVERNOR	1.5441	273.00	0.0	5.08	7.39	0.20	0.42	8.00	100.00
17	KEYSTONE G1	2	GOVERNOR	1.4426	252.00	0.0	0.0	7.11	0.20	0.42	8.00	-100.94
125	KEYSTONE G2	2	GOVERNOR	1.5441	273.00	0.0	5.08	7.39	0.20	0.42	8.00	100.00
125	KEYSTONE G2	2	GOVERNOR	1.4426	252.00	0.0	0.0	7.11	0.20	0.42	8.00	-100.94
20	PCM STG2	2	GOVERNOR	3.9000	1150.00	0.0	0.0	17.92	0.01	0.02	0.77	0.0
25	SALEM G1	2	GOVERNOR	2.6000	1170.00	0.0	1.76	18.90	0.10	0.18	6.00	0.0
26	SALEM G2	2	GOVERNOR	4.0300	1209.00	0.0	1.83	18.90	0.10	0.18	6.00	0.0
38	HOPE CREEK	2	GOVERNOR	2.6000	1100.00	0.0	1.76	18.90	0.10	0.18	6.00	0.0
74	HOMER CTY 1G	2	GOVERNOR	1.8320	325.00	0.0	3.17	10.50	0.04	0.38	10.00	0.0
73	HOMER CTY G3	2	GOVERNOR	2.1000	350.00	0.0	1.45	11.33	0.07	0.20	5.00	0.0
99	SENECA GEN	2	GOVERNOR	1.4664	-450.00	12.50	-2.50	15.00	10000.00	10000.00	10000.00	0.0
101	SEWARD 115	2	GOVERNOR	0.6467	70.00	0.0	1.40	1.33	0.20	0.13	5.00	0.0
104	SHAMVIL G230	2	GOVERNOR	0.5500	170.10	0.0	1.40	2.33	0.20	0.13	5.00	0.0
104	SHAMVIL G230	2	GOVERNOR	0.5500	170.10	0.0	1.40	2.33	0.20	0.13	5.00	0.0
106	SHAMVILLE 18	2	GOVERNOR	0.3333	70.00	0.0	1.40	1.08	0.20	0.13	5.00	0.0
106	SHAMVILLE 18	2	GOVERNOR	0.3333	70.00	0.0	1.40	1.08	0.20	0.13	5.00	0.0
164	PORTLND G115	2	GOVERNOR	0.2500	40.00	0.0	4.69	1.42	0.20	0.13	5.00	16.33
164	PORTLND G115	2	GOVERNOR	0.2500	40.00	0.0	0.0	1.42	0.20	0.13	5.00	-20.75
165	PORTLND G230	2	GOVERNOR	0.3883	80.00	0.0	6.11	2.10	0.20	0.13	5.00	18.97
165	PORTLND G230	2	GOVERNOR	0.3883	80.00	0.0	0.0	2.10	0.20	0.13	5.00	-25.24
205	OYSTR CK GEN	2	GOVERNOR	2.1400	670.01	0.0	3.30	10.67	0.20	0.20	10.00	0.0
220	YARDS CK GEN	2	GOVERNOR	1.2543	-419.00	18.50	-3.70	14.00	10000.00	10000.00	10000.00	0.0
234	BRUNNER1 100	2	GOVERNOR	1.1100	150.00	0.0	3.20	5.00	0.20	0.13	10.00	0.0
237	BRUNNER2 100	2	GOVERNOR	1.2350	165.00	0.0	3.10	6.70	0.20	0.20	10.00	0.0
238	BRUNNER3 100	2	GOVERNOR	2.5100	470.00	0.0	1.45	13.10	0.30	0.25	6.40	0.0
283	MONTOUR1 100	2	GOVERNOR	2.4100	400.00	0.0	2.54	12.80	0.20	0.20	8.00	0.0
284	MONTOUR2 100	2	GOVERNOR	2.4500	480.00	0.0	2.54	13.60	0.20	0.20	8.00	0.0
289	MTN CRK1 100	2	GOVERNOR	0.4420	100.00	0.0	0.0	2.60	0.20	0.08	0.05	0.0
290	MTN CRK2 100	2	GOVERNOR	0.4420	100.00	0.0	0.0	2.60	0.20	0.08	0.05	0.0
327	SUSQUEH1 100	2	GOVERNOR	3.6500	1101.00	0.0	3.04	18.33	0.30	0.20	9.50	0.0
348	LIR G1-22	2	GOVERNOR	3.6800	1265.00	0.0	0.0	18.40	0.01	0.02	9.50	0.0
348	CROWBYG1	2	GOVERNOR	0.4000	143.00	0.0	1.50	2.39	0.20	0.15	5.10	0.0
221	MUDDYRNS.2	2	GOVERNOR	0.4000	220.00	11.15	-2.23	15.20	229.64	0.80	1.12	0.0
222	MUDDYRNS.4	2	GOVERNOR	0.4000	220.00	11.15	-2.23	15.20	229.64	0.80	1.12	0.0
223	MUDDYRNS.6	2	GOVERNOR	0.4000	220.00	11.15	-2.23	15.20	229.64	0.80	1.12	0.0
224	MUDDYRNS.8	2	GOVERNOR	0.4000	220.00	11.15	-2.23	15.20	229.64	0.80	-1.12	0.0
575	BERGEN 138	2	GOVERNOR	0.9000	110.00	0.0	1.50	3.00	0.30	0.10	5.00	0.0
575	BERGEN 138	2	GOVERNOR	0.9000	110.00	0.0	1.50	3.00	0.30	0.10	5.00	0.0
584	BURLINGTN GEN	2	GOVERNOR	0.6900	25.00	0.0	1.25	0.75	0.20	0.13	5.00	0.0
619	MUDSON G1	2	GOVERNOR	1.3300	178.00	0.0	1.60	2.66	0.10	0.18	6.00	0.0

GOVERNOR SYSTEM DATA

BUS	NAME	TYPE	NAME	L/FR	TMAX	T3	T4	D	T3	TC	T3	012
620	HUDSON #2	2	GOVERNOR	2.0600	350.00	0.0	1.60	7.00	0.10	0.18	6.00	0.0
641	LINDEN GEN	2	GOVERNOR	0.8800	70.00	0.0	0.63	1.66	0.25	0.12	2.52	0.0
641	LINDEN GEN	2	GOVERNOR	0.8800	70.00	0.0	0.63	1.66	0.25	0.12	2.52	0.0
655	MERCER G1	2	GOVERNOR	0.4950	70.88	0.0	1.50	1.13	0.0	0.10	5.00	0.0
655	MERCER G1	2	GOVERNOR	0.4950	70.88	0.0	1.50	1.13	0.0	0.10	5.00	0.0
656	MERCER G2	2	GOVERNOR	0.4950	70.88	0.0	1.50	1.13	0.0	0.10	5.00	0.0
656	MERCER G2	2	GOVERNOR	0.4950	70.88	0.0	1.50	1.13	0.0	0.10	5.00	0.0
767	ZCRANE#1 115	2	GOVERNOR	0.6400	192.00	0.0	1.45	3.20	0.20	0.13	5.00	0.0
828	CHALK PT G#1	2	GOVERNOR	0.5500	165.00	0.0	1.25	2.75	0.20	0.13	5.00	53.55
828	CHALK PT G#1	2	GOVERNOR	0.5500	165.00	0.0	1.25	2.75	0.20	0.13	5.00	-53.55
829	CHALK PT G#2	2	GOVERNOR	0.5500	165.00	0.0	1.25	2.75	0.20	0.13	5.00	53.55
829	CHALK PT G#2	2	GOVERNOR	0.5500	165.00	0.0	1.25	2.75	0.20	0.13	5.00	-53.55
830	CHALK PT G#3	2	GOVERNOR	2.0100	601.00	0.0	1.50	2.00	0.30	0.10	5.00	0.0
831	CHALK PT G#4	2	GOVERNOR	2.0000	600.00	0.0	1.50	6.20	0.30	0.10	5.00	0.0
833	DICKERSON G#1	2	GOVERNOR	0.3030	91.00	0.0	1.25	1.52	0.20	0.13	5.00	24.93
833	DICKERSON G#1	2	GOVERNOR	0.3030	91.00	0.0	1.25	1.52	0.20	0.13	5.00	-21.65
834	DICKERSON G#2	2	GOVERNOR	0.3050	91.00	0.0	1.25	1.53	0.20	0.13	5.00	24.93
834	DICKERSON G#2	2	GOVERNOR	0.3050	92.00	0.0	1.25	1.53	0.20	0.13	5.00	-21.65
835	DICKERSON G#3	2	GOVERNOR	0.3050	89.00	0.0	1.25	1.53	0.20	0.13	5.00	0.0
835	DICKERSON G#3	2	GOVERNOR	0.3050	92.00	0.0	1.25	1.53	0.20	0.13	5.00	-21.65
839	MORGANTH G#1	2	GOVERNOR	1.8530	555.00	0.0	1.50	9.27	0.30	0.10	5.00	0.0
840	MORGANTH G#2	2	GOVERNOR	1.8530	555.00	0.0	1.50	9.27	0.30	0.10	5.00	0.0
852	POTOAC G-2	2	GOVERNOR	0.3170	45.00	0.0	0.0	0.60	0.20	0.08	0.05	0.0
853	POTOAC G-3	2	GOVERNOR	0.3170	45.00	0.0	1.25	0.53	0.20	0.13	5.00	0.0
854	POTOAC G-4	2	GOVERNOR	0.3170	45.00	0.0	1.25	0.53	0.20	0.13	5.00	0.0
855	POTOAC G-5	2	GOVERNOR	0.3170	45.00	0.0	1.25	0.53	0.20	0.13	5.00	0.0
1090	EDGE MOOR 3	2	GOVERNOR	0.2500	75.00	0.0	3.00	1.25	0.30	0.30	10.00	0.0
1099	EDGE HW 4	2	GOVERNOR	0.5000	150.00	0.0	3.00	2.50	0.30	0.30	10.00	0.0
1121	IND RIV 4	2	GOVERNOR	1.2630	320.00	0.0	1.25	6.42	0.15	0.12	5.00	0.0
1207	01BELMCH	2	GOVERNOR	3.3300	1000.00	0.0	2.42	16.75	0.18	0.20	8.00	0.0
1239	01FTMAST	2	GOVERNOR	1.8000	550.50	0.0	1.48	8.90	0.20	0.23	5.27	0.0
1239	01FTMAST	2	GOVERNOR	1.8000	550.50	0.0	1.48	8.90	0.20	0.23	5.27	0.0
1244	01HARRIS	2	GOVERNOR	3.0000	900.00	0.0	2.42	15.00	0.18	0.20	8.00	0.0
1244	01HARRIS	2	GOVERNOR	3.0000	900.00	0.0	2.42	15.00	0.18	0.20	8.00	0.0
1447	AK 2 3 20	2	GOVERNOR	0.3000	162.00	0.0	4.29	1.50	0.20	0.15	8.50	46.17
1447	AK 2 3 20	2	GOVERNOR	0.3500	181.00	0.0	0.0	1.65	0.20	0.15	8.50	-25.02
1448	AK 3 3 22	2	GOVERNOR	1.6400	556.00	0.0	2.38	7.70	0.20	0.15	8.50	0.0
1451	AST 3 3 20	2	GOVERNOR	0.6000	175.00	0.0	4.29	2.90	0.20	0.15	8.50	46.17
1451	AST 3 3 20	2	GOVERNOR	0.6500	195.00	0.0	0.0	3.20	0.20	0.15	8.50	-25.02
1531	RAV 1 3 20	2	GOVERNOR	0.5000	190.00	0.0	3.84	2.94	0.20	0.15	8.50	42.03
1531	RAV 1 3 20	2	GOVERNOR	0.6550	221.00	0.0	0.0	3.28	0.20	0.15	20.00	-30.90
1247	01HATFLD	2	GOVERNOR	1.6700	503.00	0.0	2.93	8.34	0.18	0.20	10.00	0.0
1247	01HATFLD	2	GOVERNOR	1.6700	503.00	0.0	2.93	8.34	0.18	0.20	10.00	0.0
1247	01HATFLD	2	GOVERNOR	1.6700	503.00	0.0	2.93	8.34	0.18	0.20	10.00	0.0
1335	04AVON	2	GOVERNOR	2.1700	600.00	0.0	3.60	10.64	0.04	0.05	12.00	0.0
1341	04EASTLK	2	GOVERNOR	2.1700	650.00	0.0	3.60	10.64	0.07	0.05	14.00	0.0
1342	04EASTLK	2	GOVERNOR	2.1400	650.00	0.0	3.60	10.70	0.07	0.05	14.00	0.0
1643	ALBY STYS 13	2	GOVERNOR	1.4700	120.00	0.0	0.0	7.37	2.00	0.13	4.50	0.0
1700	DUNKGEN#3 13	2	GOVERNOR	0.7000	251.00	0.0	1.97	3.50	0.30	0.20	5.99	0.0
1701	DUNKGEN#3 13	2	GOVERNOR	0.7000	251.00	0.0	2.04	3.50	0.30	0.20	5.99	0.0

GOVERNOR SYSTEM DATA

BUS	NAME	TYPE	NAME	L/FR	THAX	T3	T4	0	TS	TC	TS	012
1725	HNTLY6703 13	2	GOVERNOR	0.7000	251.00	0.0	1.97	3.50	0.30	0.20	5.99	0.0
1726	HNTLY6803 13	2	GOVERNOR	0.7000	251.00	0.0	2.04	3.50	0.30	0.20	5.99	0.0
1503	IND PT 13 22	2	GOVERNOR	2.8800	1079.00	0.0	1.69	14.40	0.20	0.20	6.50	0.0
1533	RAV 3 3 22	2	GOVERNOR	1.4100	450.00	0.0	5.62	7.04	0.20	0.24	9.84	89.90
1533	RAV 3 3 22	2	GOVERNOR	1.5300	500.00	0.0	0.0	7.62	0.20	0.24	9.84	-40.70
1766	OSWEGO 33345	2	GOVERNOR	5.6000	1700.00	0.0	1.54	28.00	0.15	1.80	6.00	0.0
1835	99 PT 163 23	2	GOVERNOR	1.9730	641.00	0.0	1.59	9.87	0.20	0.20	5.00	0.0
1837	99 PT 73765	2	GOVERNOR	3.3330	1210.00	0.0	2.16	16.67	0.15	1.80	6.00	0.0
1844	BOWLINE 3 20	2	GOVERNOR	2.0000	622.00	0.0	1.40	10.00	0.20	0.15	5.00	0.0
1845	BOWLINE203 20	2	GOVERNOR	2.0000	622.00	0.0	1.40	10.00	0.20	0.15	5.00	0.0
1952	NFLD 1+22 13	2	GOVERNOR	0.6730	260.00	9.65	-1.93	1.37	74.40	0.20	0.96	0.0
1885	IND PT 33 22	2	GOVERNOR	3.4400	1075.00	0.0	1.69	17.72	0.20	0.20	6.50	0.0
2032	CHESTERF	2	GOVERNOR	3.4300	1050.00	0.0	2.08	17.12	0.20	0.0	8.00	0.0
2099	NOR ANNA	2	GOVERNOR	2.0600	985.00	0.0	1.64	10.28	0.10	0.0	6.00	0.0
2099	NOR ANNA	2	GOVERNOR	2.0500	985.00	0.0	1.64	10.28	0.10	0.0	6.00	0.0
2099	NOR ANNA	2	GOVERNOR	2.1200	993.00	0.0	2.04	10.59	0.15	0.0	6.00	0.0
1541	SURRY 23	2	GOVERNOR	2.8500	855.00	0.0	1.62	14.25	0.04	0.0	6.00	0.0
1542	SURRY 50	2	GOVERNOR	2.5900	800.00	0.0	1.62	12.92	0.04	0.0	6.00	0.0
2810	RAR RVR 1150	2	GOVERNOR	1.2232	40.00	0.0	1.58	1.84	0.20	0.13	5.00	0.0