

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and Gas Company
Salem Unit 2

Docket No. 50-311
License No. DPR-75

As a result of the inspection conducted on March 24, 1987 - April 20, 1987, and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR 2, Appendix C (Enforcement Policy 1986), the following violation was identified:

- A. Technical Specification Surveillance Requirement 4.9.7 requires that the overload cutoff which prevents crane travel with loads in excess of 2500 pounds over fuel assemblies be demonstrated operable within 7 days prior to crane use and at least once per 7 days thereafter during crane operation.

Contrary to the above, on November 17, 1986 and on February 26, 1987, the overload cutoff surveillance test was not conducted to demonstrate operability within 7 days prior to crane use in operations over the spent fuel pool.

This is a Severity Level IV violation (Supplement 1) applicable to DRP-75.

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric and Gas Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8705060321 870429
PDR ADOCK 05000272
Q PDR