

02 JUN 1987

Docket Nos. 50-272
50-311

Public Service Electric and Gas Company
ATTN: Mr. Corbin A. McNeill, Jr.
Senior Vice President - Nuclear
P. O. Box 236
Hancocks Bridge, New Jersey 08038

Gentlemen:

Subject: Combined Inspection 50-272/87-12 and 50-311/87-15

This refers to the routine resident safety inspection by Mr. T. Kenny and Mrs. K. Gibson, of this office, on April 21, 1987 to May 18, 1987, at the Salem Nuclear Generating Station, Hancocks Bridge, New Jersey. The inspection consisted of document reviews, interviews, and observation of activities. The findings were discussed with Mr. J. M. Zupko, Jr. of your staff.

Within the scope of this inspection, one licensee identified violation occurred involving missed surveillance tests on diesel generators. This event is discussed in Section 7 of the attached report. In accordance with 10CFR2, Appendix C, a notice of violation was not issued.

This letter also acknowledges receipt of your response dated April 30, 1987, to the violation cited in Inspection Report 50-311/87-03. Your corrective actions have been reviewed and found acceptable as discussed in Section 2 of the attached report.

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

~~Original~~ Signed By:

Robert M. Gallo, Chief
Projects Branch No. 2
Division of Reactor Projects

Enclosure: NRC Combined Report 50-272/87-12 and 50-311/87-15

8706090174 870602
PDR ADOCK 05000272
Q PDR

IED
11

OFFICIAL RECORD COPY

CIR SALEM 87-12/15 - 0001.0.0
05/22/87

Public Service Electric and
Gas Company

2

02 JUN 1987

cc w/encl:

S. E. Miltenberger, Vice President - Nuclear Operations
J. M. Zupko, Jr., General Manager - Salem Operations
B. A. Preston, Manager, Licensing and Regulation
J. H. MacKinnon, General Manager - Nuclear Safety Review
M. J. Wetterhahn, Esquire
R. Fryling, Jr., Esquire
T. S. Shaw, Jr., Vice President - Production, Delmarva Power
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center
NRC Resident Inspector
State of New Jersey

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
DRP Section Chief
Robert J. Bores, DRSS

RLA
RI:DRP
Norrholm/rhl

5/29/87

RI:DRP
Gallo

6/2/87

OFFICIAL RECORD COPY

CIR SALEM 87-12/15 - 0002.0.0
05/22/87