



Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 08038

Salem Generating Station

January 26, 1988


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

SALEM GENERATING STATION
LICENSE NO. DPR-70
DOCKET NO. 50-272
UNIT NO. 1
LICENSEE EVENT REPORT SUPPLEMENT 87-017-02

This Supplemental Licensee Event Report is being submitted pursuant to the requirements of 10CFR 50.73(c). This report addresses the results of investigations relating to the potential effects of a steam release on equipment adjacent to the Steam Driven Auxiliary Feedwater Pump enclosure. As identified in the LER, the operability of this equipment would not have been effected during the postulated steam release. The categorization of the LER has been downgraded to an informational LER from the category associated with Nuclear Regulatory Commission 10CFR 50.73(a)(2)(v).

Sincerely yours,


J. M. Zupko, Jr.
General Manager-
Salem Operations

MJP:pc

Distribution

8802100054 880126
PDR ADOCK 05000272
S PDR

IE22
||