

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)

Form Approved OMB No. 2040-0004 Approval expires 12-31-87

NAME PSE&G-SALEM GENERATING STATION
 ADDRESS 90 PARK PLAZA
NEWARK NJ 07101

(2-16) NJ0005622
 PERMIT NUMBER

(17-19) 87A A
 DISCHARGE NUMBER

F - FINAL
 SEWAGE TREATMENT DSN487A

FACILITY PSE&G - SALEM GENERATING STN
 LOCATION Hancocks Bridge, NJ 08038
 ATTN: GEN MGR-ENV AFF

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
88	05	01		88	05	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

MAJOR (SUBR 6) SALEM
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1.65	2.31		*****	*****	*****	1	2/31	GRAB
	PERMIT REQUIREMENT	0.97 30DA AVG	REPORT DAILY MAX	KG/ DAY	*****	*****	*****	****	ONCE/ MONTH	GRAB
PH	SAMPLE MEASUREMENT	*****	*****		6.90	*****	7.70	0	26/31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	MINIMUM	*****	MAXIMUM	5U	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	N/A	N/A		26.00	26.00	26.00	0	1/31	COMPOS
	PERMIT REQUIREMENT	REPORT 30 DA AV	REPORT DLY MAX	KG/ DAY	30 30 DA AV	45 07 DA AV	100 DLY MAX		ONCE/ MONTH	COMPOS
OIL AND GREASE FREON EXTR-GRAV METH 00556 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	N/A	N/A		*****	1.80	1.80	0	1/31	GRAB
	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MAX	KG/ DAY	*****	REPORT 30DA AVG	10 7DA GEO	MG/L	ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OF THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.006	0.02		*****	*****	*****	0	31/31	GRAB
	PERMIT REQUIREMENT	0.2 30DA AVG	REPORT DAILY MAX	MG/D	*****	*****	*****	****	DAILY	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	30.98	240.00	0	2/31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	200 30DA GEO	400 7DA GEO	*/ 100ML	ONCE/ MONTH	GRAB
BOD, 5-DAY PERCENT REMOVAL 81010 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****		79.05	*****	*****	1	2/31	CALC
	PERMIT REQUIREMENT	*****	*****	****	87.5 MONTH MN	*****	*****	PER- CENT	ONCE/ MONTH	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
J. Trejo
Radiation Protection/
Chemistry Manager
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

John Trejo
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 609 339-4399
 DATE
 88 06 10
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SEWAGE TREATMENT PLANT WASTE WATER - DSN487A

8808040374 880722
 PDR ADUCK 05000272
 R FDC