

January 1989

Docket Nos. 50-272/311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

DISTRIBUTION
Docket File
NRC PDR & LPDR
PDI-2 Reading
SVarga/BBoger
WButler/MO'Brien
JStone/MThadani
OGC
EJordan/BGrimes
DLasher
ACRS (10)

Dear Mr. Miltenberger:

SUBJECT: SAFETY EVALUATION REPORT FOR GENERIC LETTER 83-28, ITEM 2.1 (PART 2)
(VENDOR INTERFACE PROGRAMS - RTS COMPONENTS)
TAC NOS. 52876 AND 52877

RE: SALEM GENERATING STATION, UNITS 1 AND 2

Public Service Electric and Gas (licensee) was required by Generic Letter 83-28 Item 2.1 (Part 2) to confirm that they have established an interface with either the NSSS or with the vendors of each of the components of their Reactor Trip System (RTS). The response should also confirm that this interface program includes periodic communication between licensee/applicant and the vendor and a system of positive feedback which confirms receipt by the licensee/applicant of transmittals of technical information. The licensee has responded and our review finds the licensee's responses to Generic Letter 83-28 Item 2.1 (Part 2) to be acceptable. The enclosed SER documents our findings. We therefore consider Part 2 of Item 2.1 to be closed by this action. Generic Letter 83-28 Item 2.1 (Parts 1 and 2) are closed by this action since Part 1 of this item has been closed by a previous SER.

Sincerely,

/s/

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: w/enclosure
See next page

[MIL LTR]

gm
PDI-2/PM
JStone:mr
1/6/89

PDI-2/D
WButler
1/6/88 *WB*

DF01
1/1

8901180076 890106
PDR ADOCK 05000272
P FDC

A/A3
ca



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 6, 1989

Docket Nos. 50-272/311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: SAFETY EVALUATION REPORT FOR GENERIC LETTER 83-28, ITEM 2.1 (PART 2)
(VENDOR INTERFACE PROGRAMS - RTS COMPONENTS)
TAC NOS. 52876 AND 52877

RE: SALEM GENERATING STATION, UNITS 1 AND 2

Public Service Electric and Gas (licensee) was required by Generic Letter 83-28 Item 2.1 (Part 2) to confirm that they have established an interface with either the NSSS or with the vendors of each of the components of their Reactor Trip System (RTS). The response should also confirm that this interface program includes periodic communication between licensee/applicant and the vendor and a system of positive feedback which confirms receipt by the licensee/applicant of transmittals of technical information. The licensee has responded and our review finds the licensee's responses to Generic Letter 83-28 Item 2.1 (Part 2) to be acceptable. The enclosed SER documents our findings. We therefore consider Part 2 of Item 2.1 to be closed by this action. Generic Letter 83-28 Item 2.1 (Parts 1 and 2) are closed by this action since Part 1 of this item has been closed by a previous SER.

Sincerely,

A handwritten signature in cursive script that reads "James C. Stone".

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: w/enclosure
See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. K. Miller
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Robert Traee, Mayor
Lower Alloways Creek Township
Municipal Hall
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Richard W. Borchardt, Resident Inspector
Salem Nuclear Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, NJ 08625

Delmarva Power & Light Company
c/o Jack Urban
General Manager, Fuel Supply
800 King Street
P.O. Box 231
Wilmington, DE 19899

Mr. David M. Scott, Chief
Bureau of Nuclear Engineering
Department of Environmental Protection
State of New Jersey
CN 411
Trenton, NJ 08625