

ENCLOSURE 2

REVISED PAGES - UNIT NO. 1
TECHNICAL SPECIFICATIONS

8902150381 890209
PDR ADOCK 05000272
P PIC

ALTERNATE INSPECTION SAMPLING PLAN
FOR SALEM UNIT 1

The following alternate action may be taken in place of that required by Technical Specification Table 4.4-2 when the results of the initial sample requires that an additional sample or samples must be inspected and the condition for which the added inspection is required is limited to Row 1 and/or Row 2 tubes. When examination results fall into a C-2 or C-3 Supplemental Sample Category, pursuant to Technical Specification Table 4.4-2 as a result of Row 1 and/or Row 2 U-bend defective or degraded tubes, additional samples may be limited to Rows 1 and 2. The results of the examination of the Row 1 and Row 2 tubes will be exempt from the additional sampling requirements of Technical Specification Table 4.4-2.