

March 10, 1989

Docket Nos. 50-272/311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

| DISTRIBUTION w/enclosure | |
|--------------------------|-------------|
| NRC PDR | Local PDR |
| PDI-2 Rdg. | GLainas |
| BBoger | WButler |
| MO'Brien | JStone |
| MThadani | OGC |
| EJordan | BGrimes |
| ACRS (10) | DLasher |
| AToalston | Docket File |

Dear Mr. Miltenberger:

SUBJECT: SAFETY EVALUATION REPORT FOR GENERIC LETTER 83-28, ITEM 4.5.2
(REACTOR TRIP SYSTEM RELIABILITY-ON-LINE TESTING)
(TAC NOS. 54021 AND 54022)

RE: SALEM GENERATING STATION, UNITS 1 AND 2

Public Service Electric and Gas Company was requested by Generic Letter (GL) 83-28, Item 4.5.2, to confirm that Salem 1 and 2 were designed to permit periodic on-line testing of the Reactor Trip System; and if not, to justify not making modifications to permit such testing. The enclosed SER documents our concurrence with the findings in our contractor's report (EG&G-NTA-7460), which concludes that your response to GL 83-28, Item 4.5.2 is acceptable. We, therefore, consider this item closed by this action.

Sincerely,

/s/

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation Report

cc w/enclosure:
See next page

Previously concurred*

PDI-2/LA*
MO'Brien
03/10/89

JA PDI-2/PM
JStone:mr
3/10/89

PDI-2/D
WButler
3/10/89

LB [MILTENBERGER1]

8903200368 890310
PDR ADOCK 05000272
PDC

DFol
11
A/A 3
ce



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 10, 1989

Docket Nos. 50-272/311

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: SAFETY EVALUATION REPORT FOR GENERIC LETTER 83-28, ITEM 4.5.2
(REACTOR TRIP SYSTEM RELIABILITY-ON-LINE TESTING)
(TAC NOS. 54021 AND 54022)

RE: SALEM GENERATING STATION, UNITS 1 AND 2

Public Service Electric and Gas Company was requested by Generic Letter (GL) 83-28, Item 4.5.2, to confirm that Salem 1 and 2 were designed to permit periodic on-line testing of the Reactor Trip System; and if not, to justify not making modifications to permit such testing. The enclosed SER documents our concurrence with the findings in our contractor's report (EG&G-NTA-7460), which concludes that your response to GL 83-28, Item 4.5.2 is acceptable. We, therefore, consider this item closed by this action.

Sincerely,

A handwritten signature in cursive script that reads "James C. Stone".

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation Report

cc w/enclosure:
See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Conner and Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. K. Miller
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Bruce A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Robert Traee, Mayor
Lower Alloways Creek Township
Municipal Hall
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Kathy Halvey Gibson, Resident Inspector
Salem Nuclear Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Richard F. Engel
Deputy Attorney General
Department of Law and Public Safety
CN-112
State House Annex
Trenton, NJ 08625

Delmarva Power & Light Company
c/o Jack Urban
General Manager, Fuel Supply
800 King Street
P.O. Box 231
Wilmington, DE 19899

Mr. David M. Scott, Chief
Bureau of Nuclear Engineering
Department of Environmental Protection
State of New Jersey
CN 411
Trenton, NJ 08625