NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: N Y N M P 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT: (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 2 0 (7)	EVENT DATE: 0 1 0 4 7 8 (8)	REPORT DATE: 0 1 1 3 7 8 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During reverse flow operations, delta temperature of the discharge

0 3 water exceeded specification 2.1.5 of the Environmental Technical

0 4 Specifications. The allowed 50 degrees F delta temperature was

0 5 exceeded by values of 0.5 to 2.6 degrees F during the period two

0 6 through six hours after reversal. This condition resulted in minimal

0 7 safety implications.

0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	H F (11)	E (12)	X (13)	X X X X X X (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 8	—	0 0 1	/	0 4	T	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
Z (18)	X (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	X 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Gate C, the circulating water discharge gate to the discharge tunnel,

1 1 failed to close completely. This permitted warm discharge water to mix

1 2 with the inlet water raising the temperature of the inlet water.

1 3 Gate C will be investigated during the next refueling outage to

1 4 determine why it hangs up.

1 5	FACILITY STATUS: E (28)	% POWER: 0 8 6 (29)	OTHER STATUS (30): NA	METHOD OF DISCOVERY: A (31)	DISCOVERY DESCRIPTION (32): Reverse Flow Operations

1 6	ACTIVITY RELEASED: Z (33)	CONTENT OF RELEASE: Z (34)	AMOUNT OF ACTIVITY (35): NA	LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES

1 7	NUMBER: 0 0 0 (37)	TYPE: Z (38)	DESCRIPTION (39): NA

PERSONNEL INJURIES

1 8	NUMBER: 0 0 0 (40)	DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE: Z (42)	DESCRIPTION: NA

PUBLICITY

2 0	ISSUED: N (44)	DESCRIPTION (45): NA	NRC USE ONLY

NAME OF PREPARER D.K. MacVittie PHONE: 315-343-2110 1558

GPO 917-926