

OPERATING DATA REPORT

CORRECTED COPY

Docket No. 50-311
 Date 3-10-89
 Telephone 935-6000
 Extension 4451

Completed by Pell White

Operating Status

- | | | |
|--|---------------|-------|
| 1. Unit Name | Salem No. 2 | Notes |
| 2. Reporting Period | February 1989 | |
| 3. Licensed Thermal Power (Mwt) | 3411 | |
| 4. Nameplate Rating (Gross MWe) | 1170 | |
| 5. Design Electrical Rating (Net MWe) | 1115 | |
| 6. Maximum Dependable Capacity (Gross MWe) | 1149 | |
| 7. Maximum Dependable Capacity (Net MWe) | 1106 | |
| 8. If Changes Occur in Capacity Ratings (items 3 through 7) since Last Report, Give Reason | N/A | |
-
9. Power Level to Which Restricted, if any (Net MWe) N/A
-
10. Reasons for Restrictions, if any N/A

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
11. Hours in Reporting Period	672	1416	* 64705
12. No. of Hrs. Reactor was Critical	590.5	1129.9	39485.7
13. Reactor Reserve Shutdown Hrs.	0	0	0
14. Hours Generator On-Line	568.3	1023.7	38146.3
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1708567.2	3221244	67886341
17. Gross Elec. Energy Generated (MWH)	558165	1051345	38935645
18. Net Elec. Energy Generated (MWH)	532113	1011469	36986774
19. Unit Service Factor	84.6	72.3	* 58.3
20. Unit Availability Factor	84.6	72.3	* 58.3
21. Unit Capacity Factor (using MDC Net)	71.6	64.6	* 51.7
22. Unit Capacity Factor (using DER Net)	71.0	64.0	* 51.3
23. Unit Forced Outage Rate	15.4	27.7	28.8
24. Shutdowns scheduled over next 6 months (type, date and duration of each)	N/A		

25. If shutdown at end of Report Period, Estimated Date of Startup:

N/A

8-1-7.R2

8905030069 890421
 PDR ADOCK 05000311
 R PDC