



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 12, 2018

Mr. Richard D. Bologna
Site Vice President
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Mail Stop A-BV-SSB
P.O. Box 4, Route 168
Shippingport, PA 15077

SUBJECT: REQUEST TO EXTEND ENFORCEMENT DISCRETION PROVIDED IN
ENFORCEMENT GUIDANCE MEMORANDUM 15-002 FOR
TORNADO-GENERATED MISSILE PROTECTION NON CONFORMANCES
IDENTIFIED IN RESPONSE TO REGULATORY ISSUE SUMMARY 2015-06,
"TORNADO MISSILE PROTECTION" (EPID: L-2018-LLL-0008)

Dear Mr. Bologna:

By letter dated March 15, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18078A058), FirstEnergy Nuclear Operating Company, requested the U.S. Nuclear Regulatory Commission (NRC, the Commission) to extend the expiration date for the period of enforcement for Beaver Valley Power Station, Units 1 and 2, (BVPS), from June 10, 2018, to June 10, 2020, in accordance with information provided in Enforcement Guidance Memorandum (EGM) 15-002, Revision 1, "Enforcement Discretion for Tornado Generated Missile Protection Non-Compliance," dated February 7, 2017 (ADAMS Accession No. ML16355A286).

Subsequently, the NRC staff has reviewed your letter in accordance with Commission direction as provided in EGM 15-002, Revision 1, and staff guidance provided in NRC Interim Staff Guidance, DSS-ISG-2016-01, Revision 1, "Clarification of Licensee Actions in Receipt of Enforcement Discretion [per EGM 15-002]." dated November 2017 (ADAMS Accession No. ML17128A344).

The NRC staff reviewed the information that you have provided and finds that the compensatory measures taken are consistent with EGM 15-002, Revision 1, and with interim staff guidance found in DSS-ISG-2016-01, Revision 1. Specifically, the staff found that BVPS has sufficiently described and evaluated the following six items described in DSS-ISG-2016-01, Rev. 1, and Appendix B: nonconformances applicable to the EGM, prompt compensatory actions, long-term compensatory actions, assessment of compensatory measures, need for additional enforcement discretion time, and timeline for restoring licensing basis compliance. The NRC staff has concluded that the actions taken by BVPS can be effectively implemented and justify extension of the enforcement discretion date to June 10, 2020, because BVPS has sufficiently described and documented compensatory measures for identified nonconforming structures, systems, and components (SSCs), provided assurance that compensatory measures will be effective and maintained through the extended period for enforcement discretion, and described

an implementable plan for restoring SSCs to compliance within the extended period for enforcement discretion. Therefore, the request to extend enforcement discretion is granted. If you are unable to meet the extended EGM expiration date, you are requested to contact the NRC staff at least 90 days in advance. Please contact Greg Casto at (301) 415-0565.

Sincerely,

/RA/

Russell N. Felts, Deputy Director
Division of Risk Assessment
Office of Nuclear Reactor Regulation

Docket Nos. 50-334, 50-412

SUBJECT: REQUEST TO EXTEND ENFORCEMENT DISCRETION PROVIDED IN ENFORCEMENT GUIDANCE MEMORANDUM 15-002 FOR TORNADO-GENERATED MISSILE PROTECTION NON-CONFORMANCES IDENTIFIED IN RESPONSE TO REGULATORY ISSUE SUMMARY 2015-06, "TORNADO MISSILE PROTECTION" (EPID: L-2018-LLL-0008) DATED APRIL 12, 2018

DISTRIBUTION:

Public	
RidsAcrs_MailCTR Resource	RidsNrrDssScpb Resource
RidsNrrDorLpl1 Resource	RidsRgn1MailCenter Resource
RidsNrrPMBeaverValley Resource	RidsOeMailCenter Resource
RidsNrrDra Resource	JTobin, NRR
GCasto, NRR	JRobinson, NRR
LBaer, OGC	GGulla, OE
JHickey, NRR	RGuzman, NRR
AWu, NRR	MPatterson, NRR
JPeralta, OE	RDenning, NRR
MFranovich, NRR	RKuntz, NRR

ADAMS Accession No. ML18094A536

*Concurrence by e-mail

OFFICE	DRA/APLB	DRA/APLB	DSS/SCP/BC	DRA/APLB/BC	NRR/DRA
NAME	AWu	MPatterson*	RDennig*	GCasto	RFelts
DATE	04/04/2018	04/10/2018	03/28/2018	04/10/2018	04 /12 / 2018

OFFICIAL RECORD COPY