



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 12, 2018

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Office (CNO)
Exelon Nuclear
Dresden Nuclear Power Station
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: REQUEST TO EXTEND ENFORCEMENT DISCRETION PROVIDED IN
ENFORCEMENT GUIDANCE MEMORANDUM 15-002 FOR
TORNADO-GENERATED MISSILE PROTECTION NON CONFORMANCES
IDENTIFIED IN RESPONSE TO REGULATORY ISSUE SUMMARY 2015-06,
"TORNADO MISSILE PROTECTION" (EPID: L-2018-LLL-0006)

Dear Mr. Hanson:

By letter dated March 13, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18082A081), Exelon Generating Company, LLC, requested the U.S. Nuclear Regulatory Commission (NRC, the Commission) to extend the expiration date for the period of enforcement for Dresden Nuclear Power Plant, Units 2 and 3, (DNPS), from June 10, 2018, to June 10, 2020, in accordance with information provided in Enforcement Guidance Memorandum (EGM) 15-002, Revision 1, "Enforcement Discretion for Tornado Generated Missile Protection Non-Compliance," dated February 7, 2017 (ADAMS Accession No. ML16355A286).

Subsequently, the NRC staff has reviewed your letter in accordance with Commission direction as provided in EGM 15-002, Revision 1, and staff guidance provided in NRC Interim Staff Guidance, DSS-ISG-2016-01, Revision 1, "Clarification of Licensee Actions in Receipt of Enforcement Discretion [per EGM 15-002]." dated November 2017 (ADAMS Accession No. ML17128A344).

The NRC staff reviewed the information that you have provided and finds that the compensatory measures taken are consistent with EGM 15-002, Revision 1, and with interim staff guidance found in DSS-ISG-2016-01, Revision 1. Specifically, the staff found that DNPS has sufficiently described and evaluated the following six items described in DSS-ISG-2016-01, Rev. 1, Appendix B: nonconformances applicable to the EGM, prompt compensatory actions, long-term compensatory actions, assessment of compensatory measures, need for additional enforcement discretion time, and timeline for restoring licensing basis compliance. The NRC staff has concluded that the actions taken by DNPS can be effectively implemented and justify extension of the enforcement discretion date to June 10, 2020, because DNPS has sufficiently described and documented compensatory measures for identified nonconforming structures, systems, and components (SSCs), provided assurance that compensatory measures will be effective and maintained through the extended period for enforcement discretion, and described

an implementable plan for restoring SSCs to compliance within the extended period for enforcement discretion. Therefore, the request to extend enforcement discretion is granted. If you are unable to meet the extended EGM expiration date, you are requested to contact the NRC staff at least 90 days in advance. Please contact Greg Casto at (301) 415-0565.

Sincerely,

/RA/

Russell N. Felts, Deputy Director
Division of Risk Assessment
Office of Nuclear Reactor Regulation

Docket Nos. 50-237, 50-249

SUBJECT: REQUEST TO EXTEND ENFORCEMENT DISCRETION PROVIDED IN ENFORCEMENT GUIDANCE MEMORANDUM 15-002 FOR TORNADO-GENERATED MISSILE PROTECTION NON-CONFORMANCES IDENTIFIED IN RESPONSE TO REGULATORY ISSUE SUMMARY 2015-06, "TORNADO MISSILE PROTECTION" (EPID: L-2018-LLL-0006) DATED APRIL 12, 2018

DISTRIBUTION:

Public	
RidsAcrs_MailCTR Resource	RidsNrrDssScpb Resource
RidsNrrDorl Resource	RidsNrrDra Resource
RidsNrrDorlLpl3 Resource	RidsRgn3MailCenter Resource
RidsNrrPMDresden Resource	RidsOeMailCenter Resource
GCasto, NRR	RHaskell, NRR
JHickey, NRR	BPurnell, NRR
AWu, NRR	JRobinson, NRR
MPatterson, NRR	RDennig, NRR
JPeralta, OE	LBaer, OGC
MFranovich, NRR	GGulla, OE
RKuntz, NRR	

ADAMS Accession No. ML18094A796

*Concurrence by e-mail

OFFICE	DRA/APLB	DRA/APLB	DSS/SCP/B/BC	DRA/APLB/BC	DRA
NAME	AWu	MPatterson*	RDennig*	GCasto	RFelts
DATE	04/04/2018	04/10/2018	03/28/2018	04/10/2018	04/ 12 /2018

OFFICIAL RECORD COPY