

July 24, 1991

Docket No. 50-272

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: CLOSEOUT OF BULLETIN 90-01, "LOSS OF FILL-OIL IN TRANSMITTERS
MANUFACTURED BY ROSEMOUNT", SALEM NUCLEAR GENERATING STATION, UNIT
NO. 1 (TAC NO. 76605)

Your letter dated July 18, 1990, responded to Bulletin 90-01 for the Salem and Hope Creek Nuclear Generating Stations. Your response stated that Salem Unit 1 does not have any Rosemount transmitters, from the manufacturing lots identified by Rosemount as having a high failure rate due to loss of fill-oil, installed in either safety-related systems or systems installed in accordance with 10 CFR 50.62 (ATWS Rule). Your confirmation provides an adequate basis to consider NRC's review of your response for Salem Unit 1 to be complete. Further NRC review at Salem Unit 1, if any, will be performed by inspection or audit.

Sincerely,

/S/

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDI-2 Reading
SVarga

JCalvo
WButler
MO'Brien(2)
JStone

OGC
EJordan, 3701
ACRS(10)
RBlough, RGN-I

JWhite, RGN-I
NBLe, 14B-20
RPerch, 8H-3

OFC	:PDI-2/LA	:PDI-2/PM	:PDI-2/D	:
NAME	:MO'BRIEN	:JSTONE:tlc	:WBUTLER	:
DATE	:07/24/91	:07/24/91	:07/24/91	:

OFFICIAL RECORD COPY
Document Name: TAC 76605

9107310171 910724
PDR ADOCK 05000272
Q PDR

NRC FILE CENTER COPY

AO-1
JFO
1/0



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 24, 1991

Docket No. 50-272

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric and Gas
Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: CLOSEOUT OF BULLETIN 90-01, "LOSS OF FILL-OIL IN TRANSMITTERS
MANUFACTURED BY ROSEMOUNT", SALEM NUCLEAR GENERATING STATION, UNIT
NO. 1 (TAC NO. 76605)

Your letter dated July 18, 1990, responded to Bulletin 90-01 for the Salem and Hope Creek Nuclear Generating Stations. Your response stated that Salem Unit 1 does not have any Rosemount transmitters, from the manufacturing lots identified by Rosemount as having a high failure rate due to loss of fill-oil, installed in either safety-related systems or systems installed in accordance with 10 CFR 50.62 (ATWS Rule). Your confirmation provides an adequate basis to consider NRC's review of your response for Salem Unit 1 to be complete. Further NRC review at Salem Unit 1, if any, will be performed by inspection or audit.

Sincerely,

A handwritten signature in black ink, reading "James C. Stone". The signature is written in a cursive style with a large, stylized "J" and "S".

James C. Stone, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Company

Salem Nuclear Generating Station

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street NW
Washington, DC 20005-3502

Richard B. McGlynn, Commission
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, NJ 07102

Richard Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, NJ 07101

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Calvin A. Vondra
General Manager - Salem Operations
Salem Generating Station
P.O. Box 236
Hancocks Bridge, NJ 08038

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Mr. S. LaBruna
Vice President - Nuclear Operations
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Mr. Frank X. Thomson, Jr., Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Thomas P. Johnson, Senior Resident
Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Mr. David Wersan
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection
CN 415
Trenton, NJ 08625-0415

Mr. Scott B. Ungerer
MGR. - Joint Generation Projects
Atlantic Electric Company
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, NJ 08232

Maryland People's Counsel
American Building, 9th Floor
231 East Baltimore Street
Baltimore, Maryland 21202

Mr. Jack Urban
General Manager, Fuels Department
Delmarva Power & Light Company
800 King Street
Wilmington, DE 19899

Mr. J. T. Robb, Director
Joint Owners Affairs
Philadelphia Electric Company
955 Chesterbrook Blvd., 51A-13
Wayne, PA 19087

Public Service Commission of Maryland
Engineering Division
ATTN: Chief Engineer
231 E. Baltimore Street
Baltimore, MD 21202-3486