



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038  
Salem Generating Station

November 13, 1992

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Dear Sir:

MONTHLY OPERATING REPORT  
SALEM NO. 2  
DOCKET NO. 50-311

In compliance with Section 6.9.1.6, Reporting Requirements for the Salem Technical Specifications, the original copy of the monthly operating reports for the month of October 1992 are being sent to you.

Average Daily Unit Power Level  
Operating Data Report  
Unit Shutdowns and Power Reductions  
Safety Related Maintenance  
10CFR50.59 Evaluations  
Operating Summary  
Refueling Information

Sincerely yours,



General Manager -  
Salem Operations

RH:pc

cc: Mr. Thomas T. Martin  
Regional Administrator USNRC  
Region I  
631 Park Avenue  
King of Prussia, PA 19046

Enclosures

8-1-7.R4

The Energy People  
9211240047 921031  
PDR ADDCK 05000311  
R PDR

0002

AVERAGE DAILY UNIT POWER LEVEL

Docket No.: 50-311  
Unit Name: Salem #2  
Date: 11/10/92  
Telephone: 339-2122

Completed by: Mark Shedlock

Month October 1992

Day Average Daily Power Level  
(MWe-NET)

Day Average Daily Power Level  
(MWe-NET)

1 1090  
2 1090  
3 1034  
4 1084  
5 1031  
6 1107  
7 1111  
8 1122  
9 1122  
10 1116  
11 1115  
12 1115  
13 1110  
14 1117  
15 1112  
16 1120

17 1120  
18 1112  
19 1085  
20 1110  
21 1122  
22 1120  
23 1120  
24 1116  
25 1116  
26 1116  
27 1128  
28 1093  
29 1124  
30 1118  
31 1118

OPERATING DATA REPORT

Docket No: 50-311  
 Date: 11/10/92  
 Telephone: 339-2122

Completed by: Mark Shedlock

Operating Status

1. Unit Name	<u>Salem No. 2</u>	<u>Notes</u>
2. Reporting Period	<u>October</u>	<u>1992</u>
3. Licensed Thermal Power (MWt)	<u>3411</u>	
4. Nameplate Rating (Gross MWe)	<u>1170</u>	
5. Design Electrical Rating (Net MWe)	<u>1115</u>	
6. Maximum Dependable Capacity (Gross MWe)	<u>1149</u>	
7. Maximum Dependable Capacity (Net MWe)	<u>1106</u>	
8. If Changes Occur in Capacity Ratings (items 3 through 7) since Last Report, Give Reason	<u>N/A</u>	

9. Power Level to Which Restricted, if any (Net MWe) N/A

10. Reasons for Restrictions, if any N/A

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
11. Hours in Reporting Period	<u>745</u>	<u>7320</u>	<u>96889</u>
12. No. of Hrs. Rx. was Critical	<u>745</u>	<u>3685.5</u>	<u>62301.6</u>
13. Reactor Reserve Shutdown Hrs.	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>745</u>	<u>3256.8</u>	<u>60155.6</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2522004.0</u>	<u>10311556.8</u>	<u>140423278.6</u>
17. Gross Elec. Energy Generated (MWH)	<u>857540</u>	<u>3393510</u>	<u>63120558</u>
18. Net Elec. Energy Gen. (MWH)	<u>824583</u>	<u>3194826</u>	<u>60063111</u>
19. Unit Service Factor	<u>100</u>	<u>44.5</u>	<u>62.1</u>
20. Unit Availability Factor	<u>100</u>	<u>44.5</u>	<u>62.1</u>
21. Unit Capacity Factor (using MDC Net)	<u>100.1</u>	<u>39.5</u>	<u>56.1</u>
22. Unit Capacity Factor (using DER Net)	<u>99.3</u>	<u>39.1</u>	<u>55.6</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>21.3</u>	<u>23.2</u>

24. Shutdowns scheduled over next 6 months (type, date and duration of each)

Refueling outage scheduled to start 03/29/93 and last 55 days.

25. If shutdown at end of Report Period, Estimated Date of Startup:

N/A

UNIT SHUTDOWN AND POWER REDUCTIONS  
REPORT MONTH OCTOBER 1992

DOCKET NO.: 50-311  
 UNIT NAME: Salem #2  
 DATE: 11/10/92  
 COMPLETED BY: Mark Shedlock  
 TELEPHONE: 339-2122

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR	LICENSE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason  
 A-Equipment Failure (explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Continuation of  
 Previous Outage  
 5-Load Reduction  
 9-Other

<sup>4</sup>  
 Exhibit G - Instructions  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report (LER) File  
 (NUREG-0161)

<sup>5</sup>  
 Exhibit 1 - Same  
 Source

SAFETY RELATED MAINTENANCE  
MONTH: - OCTOBER 1992

DOCKET NO: 50-311  
UNIT NAME: SALEM 2  
DATE: NOVEMBER 10, 1992  
COMPLETED BY: J. FEST  
TELEPHONE: (609) 339-2904

WO NO	UNIT	EQUIPMENT IDENTIFICATION
881103132	2	RADIATION MONITORING FAILURE DESCRIPTION: ENCLOSURE SUPPLY WILL NOT STAY OPEN - INVESTIGATE.
921029089	2	21 SERVICE WATER ROOM COOLER FAILURE DESCRIPTION: ROOM COOLER INLET VALVE PANEL VALVE AIR LEAK - REPAIR

10CFR50.59 EVALUATIONS  
MONTH: - OCTOBER 1992

DOCKET NO: 50-311  
UNIT NAME: SALEM 2  
DATE: NOVEMBER 10, 1992  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

-----  
The following items were evaluated in accordance with the provisions of the Code of Federal Regulations 10CFR50.59. The Station Operations Review Committee has reviewed and concurs with these evaluations.  
-----

ITEM

SUMMARY

2EC-3098 Pkg. 1

"Rosemount Transmitter Upgrade" - The purpose of this change is to: 1) Replace 30 Rosemount electronic pressure and differential pressure transmitters with equivalent Series H transmitters. 2) Upgrade 16 Rosemount electronics transmitters to Type "R" output. 3) Install new electrical quick-disconnects at the transmitters. 4) Modify tubing at the transmitters for proper arrangement of valving. There is no change to instrument process variable spans. The new or modified transmitters are equal to or better than the previous instruments under all conditions. There is no impact on the margin of safety as defined in the basis for any Technical Specification. (SORC 92-108)

2SC-2267 Pkg. 3

"SEC Circuit - Service Water Pump Start Test Switch Installation" - The purpose of this change is to provide a Key Lock Test Switch in service water pump breaker cubicle 2B8D for 24 primary service water pump, located in the 4KV Vital Bus Switchgear Room. This switch will be placed in the test position during Full Flow Test Surveillance of the service water pumps in Bay 4, to ensure that two service water pumps aligned to the plant will start upon receipt of an SEC initiation signal during all SEC Mode Operation conditions, thus avoiding a situation in which only a single pump aligned to the plant is started. The switch is not required when full flow testing is completed on the pumps located in Bay 2. This proposal does not reduce the margin of safety as defined in the basis for any Technical Specification. The only Technical Specification for the Service Water system states that "At least two independent service water loops shall be operable". Since the installation of a key lock test switch to provide an added degree of personnel safety

10CFR50.59 EVALUATIONS  
MONTH: - OCTOBER 1992

DOCKET NO: 50-311  
UNIT NAME: SALEM 2  
DATE: NOVEMBER 10, 1992  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

-----  
The following items were evaluated in accordance with the provisions of the Code of Federal Regulations 10CFR50.59. The Station Operations Review Committee has reviewed and concurs with these evaluations.  
-----

ITEM

SUMMARY

-----  
during performance of existing test procedures does not affect the subject Technical Specification requirement, the margin of safety as defined in the basis for any Technical Specification is not reduced. (SORC 92-110)

SALEM GENERATING STATION  
MONTHLY OPERATING SUMMARY - UNIT 2  
OCTOBER 1992

SALEM UNIT NO. 2

The Unit began the period operating at full power, and with the exception of a brief load reduction to support Hope Creek switching, continued to operate at full power throughout the remainder of the period.



REFUELING INFORMATION  
MONTH: - OCTOBER 1992

DOCKET NO: 50-311  
UNIT NAME: SALEM 2  
DATE: NOVEMBER 10, 1992  
COMPLETED BY: J. FEST  
TELEPHONE: (609) 339-2904

MONTH OCTOBER 1992

1. Refueling information has changed from last month:  
YES \_\_\_\_\_ NO X
2. Scheduled date for next refueling: MARCH 27, 1993
3. Scheduled date for restart following refueling: MAY 21, 1993
4. a) Will Technical Specification changes or other license amendments be required?:  
YES \_\_\_\_\_ NO \_\_\_\_\_  
NOT DETERMINED TO DATE X
- b) Has the reload fuel design been reviewed by the Station Operating Review Committee?:  
YES \_\_\_\_\_ NO X  
If no, when is it scheduled?: FEBRUARY 1993
5. Scheduled date(s) for submitting proposed licensing action:  
N/A
6. Important licensing considerations associated with refueling:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
7. Number of Fuel Assemblies:
  - a. Incore 193
  - b. In Spent Fuel Storage 408
8. Present licensed spent fuel storage capacity: 1170  
Future spent fuel storage capacity: 1170
9. Date of last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity: March 2003