

PSEG Nuclear LLC  
P.O. Box 236, Hancocks Bridge, New Jersey 08038-0236



Technical Specification 6.9.1.5.b

LR-N18-0020

APR 10 2018

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington DC 20555-001

Hope Creek Generating Station  
Renewed Facility Operating License No. NPF-57  
Docket No. 50-354

Subject: Technical Specification 6.9.1.5.b  
2017 Annual Report of SRV Challenges

This report is being submitted in accordance with Hope Creek Technical Specification 6.9.1.5.b, which requires the documentation of all challenges to main steam line safety/relief valves (SRVs) be provided on an annual basis.

For 2017, the SRVs were not challenged by any over pressurization events or transients that would have required the valves to respond automatically.

There are no regulatory commitments contained in this letter.

If you have any questions or require additional information, please contact Ms. Alysse K. Ochoa at 856-339-2742.

Sincerely,

A handwritten signature in black ink, appearing to read "E. Casulli", written over a white background.

Edward T. Casulli  
Plant Manager  
Hope Creek Generating Station

ako

cc: Mr. David Lew, Acting Regional Administrator - NRC Region 1  
Ms. Carleen Parker, Project Manager - USNRC  
Mr. Justin Hawkins, USNRC Senior Resident Inspector - Hope Creek  
Mr. Patrick Mulligan, Manager IV, NJBNE  
Mr. Lee Marabella, Corporate Commitment Tracking Coordinator  
Mr. Thomas MacEwen, Hope Creek Commitment Tracking Coordinator