



**PSEG**

Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Salem Generating Station

May 14, 1993

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Sir:

MONTHLY OPERATING REPORT  
SALEM NO. 1  
DOCKET NO. 50-272

In compliance with Section 6.9.1.6, Reporting Requirements for the Salem Technical Specifications, the original copy of the monthly operating reports for the month of April 1993 are being sent to you.

Average Daily Unit Power Level  
Operating Data Report  
Unit Shutdowns and Power Reductions  
Safety Related Maintenance  
10CFR50.59 Evaluations  
Operating Summary  
Refueling Information

Sincerely yours,

General Manager -  
Salem Operations

RH:pc

cc: Mr. Thomas T. Martin  
Regional Administrator USNRC  
Region I  
631 Park Avenue  
King of Prussia, PA 19046

Enclosures

8-1-7.R4

The Energy People  
9305200063 930430  
PDR ADOCK 05000272  
R PDR

200006

IR2A  
11

ERAGE DAILY UNIT POWER LEVEL

Docket No.: 50-272  
Unit Name: Salem #1  
Date: 5/10/93  
Telephone: 339-2122

Completed by: Mark Shedlock

Month April 1993

Day Average Daily Power Level  
(MWe-NET)

Day Average Daily Power Level  
(MWe-NET)

1	<u>1125</u>
2	<u>1073</u>
3	<u>1013</u>
4	<u>883</u>
5	<u>1004</u>
6	<u>985</u>
7	<u>757</u>
8	<u>831</u>
9	<u>766</u>
10	<u>776</u>
11	<u>760</u>
12	<u>769</u>
13	<u>822</u>
14	<u>902</u>
15	<u>815</u>
16	<u>914</u>

17	<u>850</u>
18	<u>675</u>
19	<u>682</u>
20	<u>890</u>
21	<u>651</u>
22	<u>724</u>
23	<u>593</u>
24	<u>649</u>
25	<u>917</u>
26	<u>1045</u>
27	<u>1024</u>
28	<u>1093</u>
29	<u>1023</u>
30	<u>783</u>
31	<u>          </u>

OPERATING DATA REPORT

Completed by: Mark Shedlock

Docket No: 50-272  
 Date: 05/10/93  
 Telephone: 339-2122

Operating Status

1. Unit Name	<u>Salem No. 1</u>	<u>Notes</u>
2. Reporting Period	<u>April 1993</u>	
3. Licensed Thermal Power (MWt)	<u>3411</u>	
4. Nameplate Rating (Gross MWe)	<u>1170</u>	
5. Design Electrical Rating (Net MWe)	<u>1115</u>	
6. Maximum Dependable Capacity (Gross MWe)	<u>1149</u>	
7. Maximum Dependable Capacity (Net MWe)	<u>1106</u>	
8. If Changes Occur in Capacity Ratings (items 3 through 7) since Last Report, Give Reason <u>N/A</u>		

2

9. Power Level to Which Restricted, if any (Net MWe) N/A

10. Reasons for Restrictions, if any N/A

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
12. Hours in Reporting Period	<u>719</u>	<u>2879</u>	<u>138816</u>
12. No. of Hrs. Rx. was Critical	<u>719</u>	<u>2622.91</u>	<u>91804.89</u>
13. Reactor Reserve Shutdown Hrs.	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>719</u>	<u>2537.35</u>	<u>88677.76</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1958695.2</u>	<u>7944417.6</u>	<u>280143026.0</u>
17. Gross Elec. Energy Generated (MWH)	<u>649580</u>	<u>2666710</u>	<u>93040700</u>
18. Net Elec. Energy Gen. (MWH)	<u>618040</u>	<u>2541922</u>	<u>88613581</u>
19. Unit Service Factor	<u>100</u>	<u>88.1</u>	<u>63.9</u>
20. Unit Availability Factor	<u>100</u>	<u>88.1</u>	<u>63.9</u>
21. Unit Capacity Factor (using MDC Net)	<u>77.7</u>	<u>79.8</u>	<u>57.7</u>
22. Unit Capacity Factor (using DER Net)	<u>77.1</u>	<u>79.2</u>	<u>57.3</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>11.9</u>	<u>21.2</u>

24. Shutdowns scheduled over next 6 months (type, date and duration of each)  
Refueling, 10-02-93 approximately 72 days.

25. If shutdown at end of Report Period, Estimated Date of Startup:  
N/A

UNIT SHUTDOWN AND POWER REDUCTIONS  
REPORT MONTH APRIL 1993

DOCKET NO.: 50-272  
UNIT NAME: Salem #1  
DATE: 05/10/93  
COMPLETED BY: Mark Shedlock  
TELEPHONE: 339-2122

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR	LICENSE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
0032	03/31/93	F	6.22	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0033	04/01/93	F	4.67	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0064	04/02/93	F	9.90	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0034	04/03/93	F	1.17	B	5	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0035	04/04/93	F	2.83	B	5	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0037	04/04/93	F	22.17	B	4	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0036	04/05/93	F	6.28	B	5	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0040	04/06/93	F	57.80	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0038	04/07/93	F	7.0	B	5	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0039	04/07/93	F	0.78	B	5	-----	HF	DEMINX	FEEDWATER CHEMISTRY
0041	04/08/93	F	117.98	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0065	04/08/93	F	49.83	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS

1  
F: Forced  
S: Scheduled

2  
Reason  
A-Equipment Failure (explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Continuation of Previous Outage  
5-Load Reduction  
9-Other

4  
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
Exhibit 1 - Same Source

UNIT SHUTDOWN AND POWER REDUCTIONS  
REPORT MONTH APRIL 1993

DOCKET NO.: 50-272  
UNIT NAME: Salem #1  
DATE: 05/10/93  
COMPLETED BY: Mark Shedlock  
TELEPHONE: 339-2122

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR	LICENSE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
0066	04/11/93	F	4.93	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0042	04/13/93	F	19.68	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0043	04/14/93	F	15.17	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0044	04/14/93	F	39.38	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0045	04/16/93	F	17.25	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0046	04/17/93	F	4.25	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0047	04/17/93	F	1.50	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0048	04/17/93	F	4.0	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0049	04/17/93	F	3.48	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0050	04/17/93	F	3.48	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0051	04/17/93	F	7.33	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0067	04/17/93	F	0.17	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS

1  
F: Forced  
S: Scheduled

2  
Reason  
A-Equipment Failure (explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Continuation of Previous Outage  
5-Load Reduction  
9-Other

4  
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
Exhibit 1 - Same Source

UNIT SHUTDOWN AND POWER REDUCTIONS  
REPORT MONTH APRIL 1993

DOCKET NO.: 50-272  
UNIT NAME: Salem #1  
DATE: 05/10/93  
COMPLETED BY: Mark Shedlock  
TELEPHONE: 339-2122

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR	LICENSE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
0052	04/18/93	F	1.85	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0053	04/18/93	F	108.37	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0068	04/19/93	F	3.95	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0069	04/19/93	F	3.20	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0070	04/20/93	F	4.70	B	5	-----	HF	PUMPXX	CONDENSER TUBE/WATER BOX CLEANING
0054	04/22/93	F	5.80	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0055	04/22/93	F	57.75	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0056	04/26/93	F	2.82	A	5	-----	HF	PUMPXX	INTAKE SYS. PROBLEMS OTHER THAN TRVL SCREENS
0057	04/27/93	F	4.43	A	4	-----			
0058	04/27/93	F	2.25	A	4	-----			
0059	04/27/93	F	.058	A	4	-----			
0060	04/27/93	F	1.95	A	4	-----			

<sup>1</sup>  
F: Forced  
S: Scheduled

<sup>2</sup>  
Reason  
A-Equipment Failure (explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

<sup>3</sup>  
Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Continuation of Previous Outage  
5-Load Reduction  
9-Other

<sup>4</sup>  
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup>  
Exhibit 1 - Same Source

UNIT SHUTDOWN AND POWER REDUCTIONS  
 REPORT MONTH APRIL 1993

DOCKET NO.: 50-272  
 UNIT NAME: Salem #1  
 DATE: 05/10/93  
 COMPLETED BY: Mark Shedlock  
 TELEPHONE: 339-2122

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR	LICENSE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
0061	04/27/93	F	4.22	A	4	-----	HF	PUMPXX	INTAKE SYSTEM PROBLEMS
0071	04/29/93	F	2.02	A	5	-----	HF	PUMPXX	CIRCULATING WATER PUMPS
0062	04/29/93	F	4.93	D	5	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.
0063	04/30/93	F	3.0	D	4	-----	HF	PUMPXX	STM UNITS THERMAL DISCHARGE LIMIT ENVIRON.

1  
 F: Forced  
 S: Scheduled

2  
 Reason  
 A-Equipment Failure (explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Continuation of Previous Outage  
 5-Load Reduction  
 9-Other

4  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
 Exhibit 1 - Same Source

SAFETY RELATED MAINTENANCE  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

WO NO	UNIT	EQUIPMENT IDENTIFICATION
911104153	1	11 CHILLED WATER PUMP FAILURE DESCRIPTION: 11 CHILLED WATER PUMP LEAKING OIL - REPAIR AS REQUIRED
930105141	1	856 AMSAC FAILURE DESCRIPTION: 856 AMSAC DEFECTIVE POWER SUPPLY - REPLACE
930316127	1	VALVE 12SW38 FAILURE DESCRIPTION: FAILED PERFORMANCE TEST - OPEN AND INSPECT



10CFR50.59 EVALUATIONS  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609) 339-2904

-----  
The following items were evaluated in accordance with the provisions of the Code of Federal Regulations 10CFR50.59. The Station Operations Review Committee has reviewed and concurs with these evaluations.  
-----

ITEM

SUMMARY

-----  
A. Design Change Packages (DCPs)

1EC-3208 Pkg 1

"Salem Fire Damper Upgrade" - The design scope for the fire damper project provides for the upgrading of Salem Unit 1 and Unit 2 fire dampers to meet the fire protection license conditions. Numerous plant HVAC System fire dampers and ductwork require rating upgrades; numerous fire dampers will be replaced with upgraded components, some existing fire dampers will be modified to obtain the required rating, some new fire dampers will be installed in the established fire barrier and some existing dampers and ductwork will be fire wrapped to obtain necessary ratings. The design scope for this package includes the replacement, relocation, and/or modification of existing fire dampers to the Unit 1's Auxiliary Building Ventilation (ABV) System. The function, basic configuration and operation of the system will not be altered and the codes, standards, qualification and design criteria of the original system will apply. The margin of safety is not reduced because the modifications are enhancing the Fire Protection System to meet the criteria of 10CFR50 Appendix R. (SORC 93-029)

1SC-2164 Pkgs 1-3

"Installation of Synchronizing Permissive Devices for No. 1 Unit Emergency Diesel Generator" - This change will provide permissives to allow the operator to synchronize the Diesel Generators (D/G) with their associated vital busses. The permissives will be enabled during a specific closing phase angle range, slip limit (F limit), and voltage range. The permissive will be blocked when out of these specific ranges. In addition, the syncro closer check relay will permit dead bus closure of the diesel generator breaker. These change packages will consist of the modification of the Design Generator Control Panels to add syncro close check relays, auxiliary relays, test switches and green indicating lights, in order to accomplish the above changes. The implementation

10CFR50.59 EVALUATIONS  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609) 339-2904

(cont'd)

ITEM	SUMMARY
1SC-2163 Pkg 1	<p>of this package will not reduce the margin of safety as defined in the basis for any Technical Specification. Failure of the synchronizing permissive circuit will not render the D/G inoperable or affect the limiting conditions for station operations. Existing surveillance and operating procedures include manual synchronizing of the D/G. (SORC 93-029)</p>
1SC-2163 Pkg 1	<p>"Installation of Synchronizing Permissive Devices to Main Generator" - This change will provide a permissive to allow the operator to synchronize the Main Generator to the power grid. The permissive will be enabled during a specific closing phase angle range, slip limit (F limit), and voltage range. The permissive will be blocked when out of these specific ranges. This change package will consist of (1) the modification of the Unit 1 Control Console to add a green light and keylock switch, (2) the modification to Relay Rack [R2] to add a syncrocloser check relay, test switch, and (3) the modifications to Relay Cabinet R11-4 to add four auxiliary relays. Three new cables will be required. The implementation of this DCP will not reduce the margin of safety as defined in the basis for any Technical Specification. Failure of the synchronizing permissive circuit will not render the main generator inoperable or affect the limiting conditions for station operations. Existing surveillance and operating procedures include manual synchronizing of the D/G. (SORC 93-029)</p>
1EC-3226 Pkg 1	<p>"Unit 1 - Auxiliary Feedwater and Steam Generator Blowdown Modifications" - This design change package replaces the internals of the steam generator blowdown containment isolation valves (11-14GB4) with new plug and trim that is hardfaced with Stellite over the full surface of the plug and seat; it also replaced the GB4 actuators with equivalent component. The design change further replaces the AF23 valves with Edward 4-inch Univalve Y-Pattern Stop Check, Fig. No. D36268T1. The proposed change does not alter the original design intent or modes of operation</p>

(cont'd)

ITEM	SUMMARY
1EC-3209 Pkg 1	<p>or function for which both systems are currently analyzed. Therefore, the margin of safety basis for the Technical Specifications will not be reduced. (SORC 93-029)</p>
1EC-3209 Pkg 1	<p>"Galtronics Page-Party System Modifications" - This change package will upgrade the single page-party system presently in use at Salem Generating Station to a multiple party line system, with line 1 being dedicated to the Unit 1 Control Room, line 2 dedicated to the Unit 2 Control Room and party lines 3, 4 and 5 utilized throughout the Salem plant. This DCP does not reduce the margin of safety as defined in the basis for any Technical Specification because the reliability of the communication system will be improved. The quality of the equipment is also being improved by replacing mechanical switch hooks with proximity sensors. (SORC 93-029)</p>
5EC-3029 Pkg 1	<p>"Automated Accountability Computer System" - An Automated Accountability Computer System is to be installed in the Secondary Alarm Station (SAS) in the basement of the Security Center. The new computer is to interface with five new card readers, located in the badge issue area, the Salem Security Computer and the local terminal/printer stations that are to be installed in the SAS and in the Salem and Hope Creek Technical Support Centers. The Technical Specifications were reviewed and it was found that there are no applicable sections that reference the emergency plan, security computer or the accountability system. Therefore, there is no reduction in the margin of safety as defined in the basis for any Technical Specification. (SORC 93-029)</p>
1EC-3208 Pkg 3	<p>"Salem Fire Damper Upgrade" - The design scope for this package includes the replacement, relocation, addition and/or deletion of existing fire dampers to Unit 1's Diesel Fuel Oil Storage Area Ventilation (DFSAV) Subsystem of the Diesel Generator Area Ventilation (DGV) System. The function, basic configuration and operation of the</p>

10CFR50.59 EVALUATIONS  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

(cont'd)

ITEM	SUMMARY
1EC-3189 Pkg 1	<p>system will not be altered and the codes, standards, qualifications and design criteria of the original system will apply. The design parameters for the modifications to the ductwork, CO<sup>2</sup> piping and electrical cable and conduit envelope the existing design requirements. There is no change to the margin of safety as defined in the basis for any Technical Specification. (SORC 93-029)</p>
1EC-3189 Pkg 1	<p>"Installation of Unit Heaters in 1C Battery Room" - Convection heaters will be installed in the 1C battery room at el. 64'-0". These heaters will be of an explosion proof, NEC Code Class I, Division I and Group B design. The local Non-1E lighting panel A11A will be modified to provide power supplies for these heaters. This modification does not reduce the margin of safety as defined in the basis for any Technical Specification. (SORC 93-031)</p>
1EC-3208 Pkg 7	<p>"Salem Fire Damper Upgrade" - The design scope for this package includes the addition of a new fire damper and modification of an existing fire dampers in the Control Area Air Conditioning System (CAACS) Subsystem of the Control Area Ventilation (CAV) System. The function, basic configuration and operation of the system will not be altered and the codes, standards, qualification and design criteria of the original system will apply. The basis for the Technical Specifications does not address the fire protection features. Since replaced or modified fire dampers associated with the CAAC system perform no safety related functions; these modifications do not affect a safety related system which is required for safe shutdown. There is no reduction in the margin of safety as defined in the basis for any Technical Specification. (SORC 93-033)</p>
1SC-2296 Pkg 1	<p>"Travelling Screen Blowdown Piping Installation and Waterbox Modifications" - This DCP proposes to Modify Unit 1 and 2 circulation water travelling screens by installing 2" stainless steel blowdown</p>

(cont'd)

ITEM	SUMMARY
	<p>lines, associated shutoff valves and supports from the three spray wash headers located on 11A, 11B, 12A, 12B, 13A, 21A, 21B, 22A, 22B, 23A, and 23B travelling screens in the Circulating Water Intake Structure (CWIS). The blowdown piping, valves and supports will also be installed on the two spare travelling screens. This DCP will also modify Unit 1 condenser waterboxes by installing patches on corroded external stiffeners, adding extensions to existing external stiffeners and attaching five new stiffeners on both sides of each inlet waterbox. The addition of blowdown piping has no effect on the margins of safety that are the basis for the Technical Specifications. (SORC 93-033)</p>
1EC-3193 Pkg 1	<p>"Oil Water Separator System" - This change package will upgrade Salem Generating Station, Units 1 &amp; 2, Oil-Water Separator System to ensure the effluents being discharged into the river via drainage system through manhole #15 meet the regulatory limits mandated by state statutes. The proposed change does not reduce the margin of safety as defined in the basis for any Technical Specification as the Oil/Water Separator system is not specifically covered by the Technical Specifications. Also, the proposed change only improves the existing Oil/Water Separator system. (SORC 93-036)</p>
1EC-3225 Pkg 1	<p>"RG 1.97 EQ Valve Limit Switch and Solenoid Modifications" - This design change package modifies the existing power, wiring and electrical protective devices of Environmentally Qualified (EQ) solenoids and valve position limit switches to provide electrical separation from Non-Environmentally Qualified (Non-EQ) solenoids and valve position limit switches. The proposed change does not reduce the margin of safety as defined in the basis for any Technical Specification. (SORC 93-036)</p>
1EC-3099 Pkg 1	<p>"Replacement of Rosemount Electronic Transmitters" - This modification replaces 55 Rosemount electronic transmitters with new transmitters having improved performance under harsh</p>

10CFR50.59 EVALUATIONS  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

(cont'd)

ITEM	SUMMARY
1EC-3208 Pkg 6	<p>environmental conditions. The new transmitters are seismically and environmentally qualified for the installed locations. The tubing and valving arrangements will be standardized for all transmitters of the same type. Where space is available, differential pressure transmitters will be equipped with calibration volume chambers. These chambers allow calibration with pneumatic signals without the incursion of air into the transmitters or impulse tubing. The modification also replaces the electronics assemblies on 16 Rosemount transmitters in accumulator level (8) and pressure (8) service. Each of the 73 transmitters affected by this modification will be equipped with a qualified electrical connector to facilitate maintenance. The new or modified transmitters are equal to or better than the previous instruments under all conditions. There is no reduction in the margin of safety as defined in the basis for any Technical Specification. (SORC 93-038)</p>
B. Procedures and Revisions	<p>"Salem Fire Damper Upgrade" - The design scope for this package includes the replacement, relocation, and/or modification of existing fire dampers to the Unit 1's Switchgear and Penetration Area Ventilation (SPAV) System. The function, basic configuration and operation of the system will not be altered and the codes, standards, qualification and design criteria of the original system will apply. The basis for the Technical Specifications does not address the fire protection features. since replaced or modified fire dampers associated with the SPAV system perform no safety related functions; these modifications do not affect a safety related system which is required for safe shutdown. There is no reduction in the margin of safety as defined in the basis for any Technical Specification. (SORC 93-038)</p>
NC.NA-AP.ZZ-0015(Q)	<p>"Safety Tagging Program" Rev. 1 - The purpose of this revision is to provide clarification for when more than one (1) supervisor performs tagging</p>

10CFR50.59 EVALUATIONS  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609)339-2904

(cont'd)

-----  
ITEM

SUMMARY  
-----

verification prior to performing the work. There are no specific sections addressing the details of safety in the Technical Specifications. There is no reduction in the margin of safety as defined in the basis for any Technical Specifications. (SORC 93-029)

C. Safety Evaluations

1EC-3217 Pkg 1

"Replacement of No. 1 Fire Diesel Fire Pump" Rev. 1 - The purpose of this revision is to address the new fire pump controller being added by this DCP. The new controller has been chosen so that its normal operating functions will be the same as the functions of the existing controller. The new controller configuration will be compatible with the existing No. 2 Fire Pump as well as Control Room alarms. In addition, the new controller provides several features not included in the original controller. These include an "Engine Test" push button which can be used to create a loss of pressure condition at the pressure transducer to cause an auto engine start sequence; a "Minimum Run time" option which allows the engine to shutdown either automatically after 5 or 30 minutes if system pressure has been restored, or manually; and safe engine shutdown circuits which cause engine shutdown to occur if the engine is running due to loss of AC start signal or test push button and either an engine low oil pressure or high temperature signal is received. The Fire Protection Program was reviewed and it was determined that no concerns pertaining to system integrity exist. There is no reduction in the Margin of safety as defined in the basis for any Technical Specification. (SORC 93-029)

SALEM GENERATING STATION  
MONTHLY OPERATING SUMMARY - UNIT 1  
APRIL 1993

SALEM UNIT NO. 1

The Unit began the period operating at 100% power. Power reductions were performed throughout the period due to waterbox fouling, travelling screen problems, and loss of circulating water pumps resulting from an excessive influx of swamp grass.



REFUELING INFORMATION  
MONTH: - APRIL 1993

DOCKET NO: 50-272  
UNIT NAME: SALEM 1  
DATE: MAY 10, 1993  
COMPLETED BY: J. FEST  
TELEPHONE: (609) 339-2904

MONTH APRIL 1993

1. Refueling information has changed from last month:  
YES \_\_\_\_\_ NO X
2. Scheduled date for next refueling: OCTOBER 2, 1993
3. Scheduled date for restart following refueling: DECEMBER 13, 1993
4. a) Will Technical Specification changes or other license amendments be required?:  
YES \_\_\_\_\_ NO \_\_\_\_\_  
NOT DETERMINED TO DATE X
- b) Has the reload fuel design been reviewed by the Station Operating Review Committee?:  
YES \_\_\_\_\_ NO X  
If no, when is it scheduled?: \_\_\_\_\_
5. Scheduled date(s) for submitting proposed licensing action:  
N/A
6. Important licensing considerations associated with refueling:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
7. Number of Fuel Assemblies:
  - a. Incore 193
  - b. In Spent Fuel Storage 656
8. Present licensed spent fuel storage capacity: 1170  
Future spent fuel storage capacity: 1170
9. Date of last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity: September 2001