



**PSE&G**

Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

MAY 20 1993

NLR-N93064

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

NRC BULLETIN 88-11  
PRESSURIZER SURGE LINE THERMAL STRATIFICATION  
SALEM GENERATING STATION  
UNIT NO. 2  
DOCKET NO. 50-311

By letter dated December 10, 1992 (ref: NLR-N92164), Public Service Electric & Gas Company (PSE&G) revised its response to Bulletin 88-11. WCAP-12913, Revision 1, was submitted as an enclosure to the letter. Based on the revised WCAP, PSE&G withdrew its commitment to perform spring hanger modifications and committed to perform walkdown measurements of the Pressurizer Surge Line spring hanger travel and pipe whip restraints during the seventh refueling outage.

PSE&G hereby confirms the completion of the required walkdown measurements. These walkdowns were performed during the on-going seventh refueling outage. The results of these walkdowns indicate that the spring hanger displacements and whip restraints do not show any adverse results and are satisfactory. No further actions have been identified at this time. However, PSE&G will perform walkdowns during the eighth refueling outage, currently scheduled for Fall, 1994 to provide data for trend analysis.

Should there be any questions with regard to this submittal, please do not hesitate to contact us.

Sincerely,

S. LaBruna  
Vice President -  
Nuclear Engineering

240106

9306020199 930520  
PDR ADOCK 05000311  
Q PDR

The power is in your hands.

JE30 1/0

MAY 20 1993

C Mr. J. C. Stone  
Licensing Project Manager

Mr. T. Johnson  
Senior Resident Inspector

Mr. T. Martin, Administrator  
Region I

Mr. Kent Tosch, Chief  
New Jersey Department of Environmental Protection  
Division of Environmental Quality  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625