

June 28, 1993

MEMORANDUM FOR: Robert C. Jones, Chief  
 Reactor Systems Branch  
 Division of Systems Safety and Analysis

THRU: Timothy E. Collins, Section Chief  
 BWR Reactor Systems Section  
 Reactor Systems Branch  
 Division of Systems Safety and Analysis

FROM: Margaret S. Chatterton, Reactor Engineer  
 BWR Reactor Systems Section  
 Reactor Systems Branch  
 Division of Systems Safety and Analysis

SUBJECT: MEETING WITH WOG ON ROD CONTROL SYSTEM

See Reports

A meeting was held in the NRC Headquarters Phillips Building in Bethesda, Maryland on June 14, 1993 with the Westinghouse Owners Group and NRC staff to discuss the safety implications of the Salem Rod Control and Indication System malfunction. The staff had activated the Westinghouse Regulatory Response Group on June 8, 1993 and posed questions concerning (1) generic aspects of the issue (2) the consequences of uncontrolled rod withdrawals, (3) interim actions and operating restrictions recommended by Westinghouse, and (4) long term actions.

The Owners Group presented background information, including an overview of the rod control system, description of the Salem event, and failure analysis. The Owners Group presented discussions on the regulatory bases, classification and analysis of postulated events, equipment performance history and the safety assessment. The Owners Group confirmed that this failure mechanism applies to all Westinghouse plants except Haddam Neck. The Owners Group analysis show that asymmetric RCCA withdrawal at power and from a subcritical condition are the limiting cases. For both of these cases conservative bounding evaluations indicate that a small percentage (less than 5%) of the rods experience a calculated DNBR below the limit value. Little or no actual fuel failure is predicted. The Owners Group argued that on the basis of the small probability of these events, they should be considered Condition III events (infrequent fault that could result in a small fraction of failed fuel) and that plants should continue operation and/or startup without restrictions. This may be less conservative than the current licensing basis for some plants in terms of classification of frequency and consequences. The Owners Group committed to evaluate the root cause of the event, and to investigate Rod Control System performance history. Furthermore, the Owners Group asserted that a more detailed 3-D analysis would most likely show no rods in DNB and that the analysis bounds base loaded and load follow plants.

300022

NRC FILE CENTER COPY

9307010112 930628  
 PDR ADOCK 05000272  
 P PDR

DF03  
111

At the conclusion of the Owners Group presentation, the staff stated its position that this did not appear to be a significant safety issue in view of the following:

- all automatic safety functions will perform as designed
- for the worst cases only a small number of fuel rods will be in DNB and perhaps none
- not all events will lead to rods in DNB

Furthermore these events do not provide a challenge to the reactor coolant system or the containment boundary. However, the staff stated that compliance with GDC 25 had not been demonstrated, and that data used for probabilistic estimated was incomplete. The staff indicated that based on the low safety significance, it is appropriate to take no immediate actions to restrict plant operation. However, the compliance concern may warrant acquiring certain information from licensees as to their basis for concluding that they are in compliance with GDC 25.

A transcript of the meeting including the Owners Group Handout is in the Public Document Room. The list of meeting attendees is attached.

*Margaret S Chatterton*

Margaret S. Chatterton, Reactor Engineer  
BWR Reactor Systems Section  
Reactor Systems Branch  
Division of Systems Safety and Analysis

Attachment:  
As stated

SRXB:DSSA  
MCHATTERTON: jh  
6/28/93

SRXB:DSSA *tes*  
TCOLLINS  
6/29/93

SRXB:DSSA  
RJONES  
6/29/93

DOCUMENT NAME: G:\MTGSUM.MC

MEETING SUMMARY DISTRIBUTION

Central File ———  
SRXB R/F  
NRC PDR ———  
OTSB (11E-21)  
JMTaylor (17G-13)  
TMurley/FMiraglia (12G-18)  
WRussell (12G-18)  
BSheron (NL-007)  
JPartlow (12G-18)  
DCrutchfield (12G-18)  
SVarga (14E-4)  
JWiggins (7D-26)  
ATHadani (8E-2)  
EAdensam (13E-4)  
AChaffee (11A-1)  
JRoe (13A-2)  
GLainas (14H-3)  
JZwolinski (13H-24)  
OGC-WFI (15B-18)  
EJordan (MNBB-3701)  
NRR Mail Room (12G-18)  
YOverton (12E-4)  
ACRS (10)  
GPA/PA (2G-5)  
JWermiel (8-H3)  
JStone (14-E21)  
TMartin (RGN-I/ORA)  
WHodges (RGN-I/ORS)  
WRuland (RGN-1/EB)  
RJones  
TCollins  
MChatterton

WOG MEETING ON ROD CONTROL SYSTEM  
MEETING OF THE 6/17/93  
FULL COMMITTEE MEETING

ATTENDEES - PLEASE SIGN BELOW

PLEASE PRINT

NAME	AFFILIATION
<del>HARRY WALSH</del>	<del>NARSC (WOG)</del>
Jim Hardy	FPL - Turkey Point Plant
Tom Carrier	PSE + G
HAROLD MAGUIRE	WESTINGHOUSE, NATD
NICK LIPARULO	WESTINGHOUSE, NATD
E.J. WEINKAM	FPL/Turkey Point, WOG RRG
Allen Hansen	NRC/NRR
David Smith	FPL
Jeff Bass	Westinghouse NATD Licensing
FRANK THOMSON	PSE + G
STAN LA BRUNA	PSE + G
STEVE MILTENBERGER	PSE + G
Jose Ibarra	NRC / AEDL
Bill Beckley	NRR / DRPW
Roger Newton	WEPL / WOG
James Stone	NRC / NRR / PD I-2
DUKE WHEELER	NRC / OEDO
L. Robert Cooper	NRC / OEDO / REP
Glenn Heberle	Westinghouse NATD
Steve Fowler	Westinghouse NATD
Chris Vertes	Westinghouse NATD
Ashok Thadani	NRC / NRR / OESA

PLEASE PRINT

WOG MEETING ON ROD CONTROL SYSTEM  
 MEETING OF THE 6/14/93  
 FULL COMMITTEE MEETING

ATTENDEES - PLEASE SIGN BELOW

PLEASE PRINT

NAME	AFFILIATION
Nancy Glasky	Westinghouse NATD
BAARD JOHANSEN	Westinghouse NMD
Glenn Lang	Westinghouse
KEN BUDSON BOHX	DELMARVA Power
CARL CASO	Westinghouse
HANK SEPP	Westinghouse
JAMES BRILEY	PSEG
ARUN P. SAHASRABUDHI	WESTINGHOUSE
JOHN MCINERNEY	WESTINGHOUSE
TOM BAKER	WESTINGHOUSE
Robert Jones	NRC/SRXB
Timothy Collins	NRC/SRXB
M. J. VIKELW	NRC/DSSA
E. C. Marinop	NRC/NRP/DRCH
MARIL Proviano	Westinghouse
John M. Inerney	Westinghouse
Larry Harster	NAESCO
AL DEAGAZIO	NRR/DRPE
H. C. GARG	NRR/HICE
W. R. Buland	NRC/RT
AC [unclear]	[unclear]

PLEASE PRINT



50-272

PSE&G

SALEM 1

MEETING WITH WOG ON ROD CONTROL SYSTEM

*Rec'd W/MEMO DTD 6/28/93 #9307010112*

**-NOTICE-**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE RECORDS & REPORTS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS & ARCHIVES SERVICES SECTION P1-122 WHITE FLINT. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

**-NOTICE-**

ORIGINAL  
OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission

Title: Generic Assessment of the Salem Event

Docket No.

LOCATION: Bethesda, Maryland

DATE: Monday, June 14, 1993

PAGES: 1 - 147

**ANN RILEY & ASSOCIATES, LTD.**

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

\*\*\*

NRC PRESENTATION

\*\*\*

GENERIC ASSESSMENT OF  
THE SALEM EVENT

\*\*\*

Nuclear Regulatory Commission  
Conference Room P-110  
7920 Norfolk Avenue  
Bethesda, Maryland

Monday, June 14, 1993

ANN RILEY & ASSOCIATES, LTD.  
Court Reporters  
1612 K Street, N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950

## 1 PARTICIPANTS:

2

3

A. Thadani, NRC/NRR

4

T. Collins, NRC/NRR

5

R. Jones, NRC/NRR

6

M. Virgilio, NRC/NRR

7

W. Ruland, NRC Region I, AIT Team Leader

8

A. Chaffie, NRC/NRR

9

J. Wermiel, NRC/NRR

10

J. Calvo, NRC/NRR

11

R. Newton, WOG

12

L. Walsh, WOG

13

N. Liparulo, Westinghouse

14

J. McInerney, Westinghouse

15

S. LaBruna, PSE&amp;G

16

F. Thomson, PSE&amp;G

17

T. Carrier, PSE&amp;G

18

S. Fowler, Westinghouse

19

G. Lang, Westinghouse

20

C. Vertes, Westinghouse

21

B. Johansen, Westinghouse

22

N. Closky, Westinghouse

23

24

25

ANN RILEY & ASSOCIATES, LTD.  
Court Reporters  
1612 K Street, N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950

## P R O C E E D I N G S

[1:10 p.m.]

1  
2  
3 MR. COLLINS: Let's begin this meeting between NRC  
4 and the Westinghouse Owner's Group. The purpose of the  
5 meeting is to discuss generic safety implications of  
6 malfunctions in the rod control system which have been  
7 experienced at the Salem plant.

8 This is an open meeting, meaning that it's open  
9 for observation by members of the public. We have received  
10 no requests from the public to speak at this meeting.  
11 However, if members of the public wish to question the NRC  
12 staff at the end of the meeting, the staff will be available  
13 for a short time after the meeting.

14 This meeting is being transcribed and, therefore,  
15 persons who are not at the table here, if they speak, please  
16 go to a microphone and give your name and your affiliation  
17 at the beginning of whatever you're going to say.

18 Everyone present should sign in on sheets at the  
19 back of the room. We need those to keep track of who was  
20 here.

21 I believe I can turn this over to Ashok Thadani at  
22 this point.

23 MR. THADANI: Thank you, Tim. As Tim said, we're  
24 here to discuss with the Westinghouse Owner's Group the  
25 regulatory response of the safety implications of

ANN RILEY & ASSOCIATES, LTD.  
Court Reporters  
1612 K Street, N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950

1 malfunctions that were experienced in the control rod system  
2 at Salem.

3           We activated the regulatory response group last  
4 Tuesday, although the staff investigations into an event  
5 that occurred at Salem are still ongoing. At Salem, while  
6 starting up, a control rod withdrew in response to an insert  
7 signal. A similar rod control system is used at nearly all  
8 Westinghouse-designed pressurized water reactors.

9           Initial assessments by the staff concluded that a  
10 single failure in the rod control system could result in un-  
11 demanded rod withdrawal movement and multiple control rods.  
12 While the staff recognizes that the reactor protection  
13 system is independent of the rod control system logic and,  
14 therefore, the scram function is not compromised, there  
15 remains an important concern in that a previously  
16 unanticipated single failure mechanism may exist in the  
17 control system which can initiate or aggravate reactivity  
18 excursions and result in fuel failure.

19           This is of particular importance since the  
20 frequency of demand on the rod control system, particularly  
21 for power adjustments, is very high; in some cases, on a  
22 daily basis.

23           The staff expects that single failure mechanisms  
24 in the rod control system should be eliminated or the  
25 consequences minimized in accordance with General Design

1 Criterion 25 and reactor protection system requirements for  
2 reactivity control malfunctions.

3 For the meeting today, we have requested that the  
4 Westinghouse Owner's Group presentation include the  
5 following topics; a brief description of the rod control  
6 system, its operation, and the event at Salem Unit 2; a  
7 discussion of what rod motions are possible as a result of a  
8 single failure at any power level; a discussion of  
9 applicable regulatory requirements, particularly General  
10 Design Criterion 25; analyses that have been performed,  
11 including all power levels from subcritical to full power;  
12 definition of initial conditions and the bases for selection  
13 fo those initial conditions; the impact of load following  
14 demand signals; transients that would result in demand for  
15 rod insertion; impact of initial conditions outside the  
16 actual flux demand, the band; and then impact of manual  
17 versus automatic mode of operation.

18 The next topic we'd like to hear about is the  
19 operability considerations and the requirements of the  
20 technical specifications. We are also, as I indicated to  
21 you last Friday, interested in getting a really good  
22 understanding of the failure rates; that is, what kind of  
23 data is available, how many failures have been experienced,  
24 quality of data, source of the data, failure rates, and,  
25 again, as I indicated to you, we are interested in

1 understanding if there are any age-related facts on these  
2 components.

3 Finally, and this is an extremely important part  
4 of the discussion also, is the basis for continued operation  
5 of the Westinghouse-designed plants. We'd like to hear your  
6 views on compliance with GDC-25, what short-term  
7 compensatory actions are needed, mechanism and schedule for  
8 short-term action implementation. This is important, so we  
9 can then decide if we need to go out and take action  
10 ourselves.

11 So it's very important that we hear from you what  
12 the individual owners might be doing as a result of  
13 recommendations that might flow out of the Owner's Group.  
14 Finally, what the long-term actions will be and what the  
15 schedule will be for those corrective actions.

16 This is basically what we discussed last Friday.  
17 Roger, you're going to start out.

18 MR. COLLINS: Excuse me, Roger, before you do  
19 that. There may be some members of the public here who are  
20 not familiar with the players. So let's go around the head  
21 table and just announce who we are. We'll start with you,  
22 Roger.

23 MR. NEWTON: I'm Roger Newton of Westinghouse  
24 Owner's Group. I'm Chairman of the Regulatory Response  
25 Group.

1 MR. WALSH: I'm Larry Walsh. I'm the Chairman of  
2 the Westinghouse Owner's Group.

3 MR. LIPARULO: I'm Nick Liparulo. I'm Manager of  
4 Nuclear Safety and Regulatory Activities.

5 MR. McINERNEY: John McInerney, Westinghouse,  
6 Manager of Nuclear Safety Licensing.

7 MR. LaBRUNA: Stan LaBruna, Vice President-Nuclear  
8 Engineering for PSE&G for Salem and Hope Creek Stations.

9 MR. THOMSON: Frank Thomson, Manager of Licensing  
10 and Regulation for PSE&G.

11 MR. CHAFFIE: I'm Al Chaffie. I'm with the  
12 Nuclear Regulatory Commission. I'm the Chief of the Events  
13 Assessments Branch.

14 MR. WERMIEL: I'm Jared Wermiel. I'm Chief of the  
15 Instrumentation and Controls Branch, NRC.

16 MR. RULAND: I'm Bill Ruland. I'm the AIT, the  
17 Salem AIT Team Leader and I'm Section Chief of the  
18 Electrical Section in Region I.

19 MR. VIRGILIO: Marty Virgilio, Deputy Director,  
20 DSSA.

21 MR. THADANI: Ashok Thadani, Director of Division  
22 of Systems Safety and Analysis.

23 MR. COLLINS: Tim Collins, Section Chief in  
24 Reactor Systems Branch.

25 MR. JONES: Bob Jones, Chief of the Reactor

1 Systems Branch.

2 [Slide.]

3 MR. NEWTON: I will try to use no microphone so I  
4 can move around and I will endeavor to do that. If you  
5 can't hear in the back of the room, let me know and I will  
6 try to speak louder.

7 The meeting is to discuss the generic aspects of  
8 the Salem event. As was mentioned here, it's the  
9 Westinghouse Owner's Group. The purpose of the meeting is  
10 to discuss the generic aspects of the Salem event; in  
11 particular, as it impacts the Westinghouse Owner's Group.

12 [Slide.]

13 MR. NEWTON: As previously mentioned, the purpose  
14 is to meet with the NRC. They did activate the RRG, the  
15 Regulatory Response Group. After Three Mile Island, the  
16 Owner's Group set up a Regulatory Response Group to be able  
17 to respond to issues that are generic to a particular  
18 vendor's activities. It can be activated by the Owner's  
19 Group itself, a utility, or the NRC, or even NUMARC if an  
20 issue comes up to activate it.

21 I'm not going to go into details of the operation  
22 of the RRG, but it allows the generic aspects of an issue to  
23 be focused on from a broader perspective and a broader  
24 outlook of utilities. We have a Chairman, a Vice Chairman  
25 and four or five utilities that stand on this committee all

1 the time. Should the need arise, we're there to convene and  
2 discuss the issue.

3 The other objective of the meeting is to provide  
4 an open forum in which to discuss this issue that surrounds  
5 the control rod system event. To date, the NRC -- we've  
6 been keeping the NRC informed as to the status. We've had  
7 several phone calls. Also, they've been working through  
8 Salem.

9 We hope to be able to address the questions with  
10 respect to plant safety and operability today. We have a  
11 sequence of events to go through. We anticipate that, with  
12 minimal questions, it will take about an hour-and-a-half to  
13 get through our material.

14 We may not have covered every -- we may not be  
15 able to address -- your list is pretty long of items that  
16 you've had there and hopefully we can knock most of them off  
17 and then look at which ones we still have to address.

18 I think, from an overall standpoint, we approached  
19 it from the larger envelope of defining the issues and then  
20 we may be able to focus on some of the smaller ones as an  
21 action item from this meeting. So I don't guarantee that  
22 list will be covered line-by-line, but hopefully we can  
23 address most of them.

24 At the end, we expect there will be items to  
25 address. We have planned some future actions ourselves.

1 Issues that come up during this meeting, we'll try to keep  
2 track of them and make sure we understand what are the  
3 issues that we still need to define and answer more  
4 thoroughly.

5 We have three groups that are coordinated here.  
6 We have the Westinghouse Owner's Group that represents the  
7 generic aspects. We have Westinghouse, that is the vendor.  
8 We have the utility, Salem Public Service Electric and Gas,  
9 that's specific to the event.

10 Most of the issues are aimed at the generic  
11 aspects. So the WOG and Westinghouse will be doing most of  
12 the presentation, but Salem will be called upon should a  
13 specific issue head in that direction. I will probably  
14 point to Westinghouse or Salem and they'll have to direct  
15 the right person to respond to the question or the issue.

16 From our perspective, we've got four or five  
17 presenters that will be coming up here to present a portion  
18 of the program, and I'm going to go through that agenda and  
19 show you how that's going to flow.

20 [Slide.]

21 MR. NEWTON: I've got just some opening remarks,  
22 reviewing the agenda, which I'm doing now, and just some  
23 status items of where we are. We'd like to get into the  
24 Westinghouse presentation and the description of the event  
25 will be done by a Salem person. Then we start to get into

1 more of the aspects of the failure analysis.

2 [Slide.]

3 MR. NEWTON: Regulatory basis classifications,  
4 analysis of the events that we envision could possibly  
5 occur. We are looking at some of the performance of the  
6 equipment and the history of that to give us some insights  
7 as to what is happening here and how to interpret that.

8 We have an overall safety assessment that we're  
9 drawing conclusions from, the previous work. Then we'll get  
10 into where we think the operability and where we're going on  
11 this issue. Hopefully, we will have addressed most of the  
12 items you talked about.

13 [Slide.]

14 MR. NEWTON: The status from the WOG/RRG  
15 perspective. The Salem plant-specific evaluation is  
16 underway. We are following that, but we are not  
17 participating in that as an active member. That's really a  
18 utility-specific item, working with Westinghouse and the NRC  
19 on that, as you have already been doing that.

20 We obviously are very interested in what's  
21 happening there. We are getting the benefit of the work  
22 they're doing and factoring it into what you see here today.

23 Westinghouse and the Westinghouse Owner's Group  
24 are continuing to evaluate the generic aspects. From our  
25 perspective, this is less than a week old. The RRG charter

1 requests or identifies that within five working days, we're  
2 to look at an issue and try to define a plan, and that's  
3 kind of what this meeting is here. It culminates the  
4 initial work that we've done, defines the issue and sets the  
5 course for where we're going.

6 Westinghouse has prepared a reasonable assurance  
7 of safe operation. We feel that adequately addresses the  
8 concerns regarding plant operability and the health and  
9 safety of the public. That was mailed out last Friday as  
10 part of an information notice to the utilities.

11 The overall conclusion from that, and we'll  
12 hopefully be able to demonstrate that as we go through the  
13 afternoon, is that all plants should be able to continue to  
14 operate and should be able to start up. We don't envision  
15 that what happened at Salem is indicative of a frequent  
16 event that causes a problem that's non-detectable and  
17 results in an undue risk to the public health and safety.  
18 We hope that we'll be able to demonstrate that this  
19 afternoon.

20 [Slide.]

21 MR. NEWTON: Just a short summary of what has  
22 taken place already, and this is only from the Owner's Group  
23 RRG perspective. We really just became aware of this late  
24 on Monday a week ago. So we're relatively new to the issue.  
25 So we've done a lot of catch-up on that.

1           As mentioned, Ashok called the Westinghouse  
2 Owner's Group Chairman on Tuesday morning, and it was early.  
3 Larry is in the east coast time zone, so he's more  
4 available. We were faxed five questions that were of  
5 immediate concern to the NRC.

6           At the conclusion of the meeting, we're going to  
7 put those five questions up and see what the answers are to  
8 those questions as of today and see where we stand. It will  
9 be based on everything that is presented before that. So  
10 this will pop up again at the very end.

11           On Wednesday, there should be an "and" in here,  
12 the WOG Chairman and the Vice Chairman were at Westinghouse  
13 to meet with them, to become familiar with the event. There  
14 was a telephone call, not listed on here, in the afternoon.  
15 There was also a telephone call with the NRC.

16           I had some eye surgery on Wednesday. So I was a  
17 little bit out of commission, but I did listen to the phone  
18 call on Wednesday. It was just kind of an initial phone  
19 call. We were more interested in your concerns. We didn't  
20 provide you a whole lot of answers on Wednesday, anyway.

21           On Thursday, from an RRG perspective, we had our  
22 first official -- what we called an activation, where the  
23 members were brought together in a phone call and we became  
24 familiar with what was happening and what to do about it.  
25 So this was our first official one. We needed to gather

1 information ourselves before we felt knowledgeable enough to  
2 talk about what was happening.

3 There was an afternoon conference call with the  
4 NRC, the WOG, Westinghouse and Salem reps, and at this phone  
5 call, I think we provided more information to the NRC, at  
6 least. Preliminary as it was, it was much better than the  
7 Wednesday afternoon call. It identified what we had looked  
8 at and where things were going at that time.

9 [Slide.]

10 MR. NEWTON: Also, at that Thursday phone call, we  
11 committed to send to the NRC a draft version of what we were  
12 going to send to the Westinghouse utility customers. That  
13 was in draft form. So in the morning of Friday, we had a  
14 second conference call where we evaluated, reviewed with  
15 Westinghouse that customer safety -- give me the right words  
16 -- advisory letter. For the most part, it was the same, but  
17 there were some minor modifications made to it.

18 That went out Friday afternoon and all of the  
19 utility customers -- I don't want to say received it Friday  
20 afternoon, but I'm sure by now they've received it. A lot  
21 of them -- Nick, I don't know if you can swear that we all  
22 received it by Friday afternoon, but it was on its way.

23 In the afternoon, Friday afternoon, there was  
24 another conference call between the NRC, Westinghouse, WOG  
25 and Salem, and it was primarily to make you aware of the

1 advisory letter, you had gotten a copy of it, and to go over  
2 the agenda for this meeting to cover the items you had  
3 addressed.

4 MR. THADANI: Roger, was the advisory letter  
5 modified from the draft that we had received?

6 MR. LIPARULO: There were some modifications, but  
7 the types of modifications didn't change the conclusions or  
8 the technology it was based on. We have faxed down a copy  
9 of the final memo to you, Ashok.

10 MR. THADANI: Thank you.

11 MR. NEWTON: This concludes my part of the  
12 introduction, which just lays kind of the foundation of what  
13 the involvement of the Westinghouse Owner's Group and RRG  
14 is. I'd like to have Nick introduce his people for the rest  
15 of the presentation that deals with what happened and all of  
16 the other questions that you've asked us concerning the  
17 design and safety and so on. Nick?

18 MR. LIPARULO: Our next speaker will be Steve  
19 Fowler, who will take us through an overview of the rod  
20 control system. The idea of the way we've laid out the  
21 presentation is to go through the system, how it works, then  
22 to talk about the Salem event, and then take you to the  
23 point where the failure analysis indicates the types of  
24 motion that we can see.

25 I think that was the specific item that you

1 requested at the beginning that you wanted to hear. So  
2 Steve Fowler is the next speaker.

3 [Slide.]

4 MR. FOWLER: The purpose of my presentation is to  
5 provide enough of the background information on the rod  
6 control system and its operation to aid in the discussion of  
7 the failures, transients and analysis that are going to  
8 follow my presentation.

9 A very basic description of the rod control  
10 system. Its purpose is to position the rods, specifically  
11 the rod control cluster assemblies or RCCAs, as you'll hear  
12 them referred to, in response to demand signals from either  
13 the reactor operator or the reactor control system.

14 The system is a non-Class 1E system. That means  
15 it's a non-safety system. A basic description will follow.  
16 I'm going to first look at a control rod drive mechanism in  
17 terms of the way it normally functions, the normal  
18 withdrawal sequence to move RCCAs out, and insert sequence,  
19 and the response to the reactor trip signal from the reactor  
20 protection system.

21 Then there will be a look at the control rod  
22 arrangement in the core, so we understand some of the  
23 concepts of which rods can and can't move; rod groups, how  
24 rods move and some bank overlap, and then a very brief look  
25 at the rod control system cabinets that are involved in this

1 event; specifically, the slave cyclor circuit where the  
2 failures were located at the Salem event.

3 [Slide.]

4 MR. FOWLER: I'd like you to please look at Figure  
5 No. 1. The control rod drive mechanism used in our  
6 Westinghouse plants is an electro-mechanical jack mechanism.  
7 What's shown here is a drive rod which is connected to the  
8 rod control cluster assembly. So that when the drive rod  
9 moves, so does the rod control cluster assembly.

10 To hold the drive rod in position, a stationary  
11 coil is energized. In energizing that coil, there's a  
12 solenoid effect that pulls up on stationary grippers and  
13 makes them grip the rod. That holds the rod in place.

14 If we want to position the rod and move it out one  
15 step, there's a sequence of events as follows. We transfer  
16 the holding of the drive rod from the stationary gripper to  
17 a moving gripper; that is, we grab it with the moving  
18 gripper and let go with the stationary gripper.

19 Then the left coil is energized and the way the  
20 mechanism is designed, when the lift coil is energized, it  
21 actually lifts up on the moving gripper five-eighths of an  
22 inch. Then the stationary gripper is reenergized. We  
23 transfer the load back from the moving gripper to the  
24 stationary gripper. The moving gripper is then -- or coil  
25 is deenergized, the moving gripper can swing away.

1           At that point, the rod is now five-eighths of an  
2 inch higher up. We can then deenergize the lift coil to be  
3 ready to respond to another request for movement. To get  
4 the rod from the bottom to the top takes 228 of these step  
5 motions for a 12-foot core.

6           There's a very different sequence for moving the  
7 rod down. In trying to make the rod insert -- again,  
8 starting from the stationary gripper holding the rod -- with  
9 the moving grippers deenergized, we energize the lift coil.  
10 This pulls up the deenergized moving grippers or the  
11 unattached moving grippers and then at that point we grab it  
12 with the moving grippers. It's being held by both.

13           We let go with the stationary grippers. It's  
14 being held by the moving gripper. At that point, we  
15 deenergize the lift coil and the rod drops down five-eighths  
16 of an inch. We transfer the drive rod back to the  
17 stationary gripper and let go with the moving gripper. At  
18 that point, we're back to a hold condition with the rod in  
19 five-eighths of an inch.

20           It is important to recognize what happens with  
21 this reactor sequence when the reactor trips. No matter  
22 which coil is energized, which grippers are holding this  
23 rod, in a reactor trip, all of the coils are deenergized,  
24 lose power. With the help of springs, any grippers that  
25 were holding the rod are pushed open and the rod drops.

1 [Slide.]

2 MR. FOWLER: Please turn to Figure No. 2 for a  
3 typical arrangement of the control rods, the RCCAs, within a  
4 core. This is a four-loop core, but it would be very  
5 typical for two or three loops to have some of these same  
6 features. One is that the rods are arranged in a symmetric  
7 pattern and the rods are broken into banks.

8 We have shutdown banks and control banks. In a  
9 short while, I'll show what the difference between them in  
10 terms of controlling the reactor is. But a key feature is  
11 that the rods are arranged symmetrically within a bank.

12 If you look at the shutdown bank A rods, they are  
13 the black colored squares around the periphery of the core  
14 in a symmetric pattern. The banks are typically divided in  
15 half to form two groups of rods, a group one and group two  
16 for each bank.

17 When we do move the rods -- I discussed the single  
18 rod movement. When we move rods, we send signals for bank  
19 movement. When a bank is requested to move, the whole bank  
20 has to move. In fact, what we do, though, is move group  
21 one, half the bank, and then group two. We're going out;  
22 group one, group two. In other words, the groups move  
23 alternately and sequentially to reposition the bank of rods.

24 There's one other feature about movement of rods  
25 that's worth discussing in terms of the analysis that's

1 going to follow, and that is the bank overlap feature.

2 [Slide.]

3 MR. FOWLER: For the control banks only, and this  
4 is on Figure 3, we use a mode of operation called bank  
5 overlap. The rod control cluster assemblies, due to the  
6 nuclear physics of the matter, have low reactivity worth  
7 when they're near either the bottom of the core or the top  
8 of the core. They're most effective in the center of the  
9 core.

10 The system has been arranged such that when a bank  
11 is nearing the edge -- the top or the bottom of the core, a  
12 second bank begins to move with it for the control banks,  
13 and that's what's basically being shown here. As control  
14 bank A nears the top of the core, the next sequential bank,  
15 control bank B, in this case, begins to move with it, until  
16 control bank A reaches the top of the core. Control bank B  
17 continues on its own and then there's a similar overlap with  
18 control bank C and D.

19 The order for withdrawal would be control bank A,  
20 B, C, D. For insertion, it's the reverse of that. Control  
21 bank D inserts first, followed by C, B, and A. What this  
22 does is make for a smoother rate of reactivity change.

23 [Slide.]

24 MR. FOWLER: Please look at Figure 4 and it will  
25 be a brief description of the components of the rod control

1 system. The rod control system consists of a logic cabinet,  
2 which is the cabinet that responds to demands for motion and  
3 direction from the reactor operator or the reactor control  
4 unit.

5 Power cabinets, as many as five in our plants.  
6 The number depends on the number of primary coolant loops in  
7 the plant; actually, the number of RCCAs in the core. Power  
8 cabinets, which have the job of supplying current to the  
9 coils we've discussed for the control rod drive mechanism.

10 Of minor importance to this discussion is a DC  
11 hold cabinet that has the ability to hold one group of rods  
12 out of the core in a stationary manner. Of very much  
13 importance to this discussion is where the reactor  
14 protection system enters the case here.

15 The reactor trip breakers are between the source  
16 of AC power that the power cabinets use to distribute to the  
17 control rod drive mechanisms. By opening either of the  
18 reactor trip breakers that are located in this spot in  
19 series, you disconnect power to the power cabinets, as well  
20 as the DC hold cabinet, to ensure that all the coils  
21 deenergize and the RCCAs drop into the core.

22 I do want to just mention a few words about the  
23 slave cyclers. Inside the logic cabinet, there are slave  
24 cyclers whose purpose is to supply current commands to the  
25 stationary lift and moving coils via the power cabinets.

1 For each power cabinet, there's a slave cyclor circuit  
2 located in the logic cabinet that produces the current  
3 commands.

4 Those commands from a slave cyclor are sent to  
5 effect all the rods in a group. They are not separate  
6 signals for each control rod drive mechanism. There is a  
7 single set of commands sent to a power cabinet to effect all  
8 the rods in a group.

9 The commands for in and out motion, the current  
10 commands, are very different in their shape. As I tried to  
11 describe in the motion of the control rod, up or down, it  
12 takes a different set of current commands to make the rod go  
13 up and to go down.

14 [Slide.]

15 MR. FOWLER: Would you please return to my outline  
16 slide or -- excuse me -- the next in your package should be  
17 an outline slide. I'll briefly discuss modes of operation  
18 and features of the rod control system.

19 I'd like to take it from startup condition of the  
20 reactor through full power with some brief points of  
21 interest. Before the reactor is started up, there's a  
22 series of startup tests that can be performed where we prove  
23 operability of the rod control cluster assemblies.  
24 Specifically, we pull each bank of rods out of the core and  
25 then drop the control rods back into the core, the RCCAs

1 back into the core to ensure that they drop within the  
2 specified time limits; basically, to ensure that we can trip  
3 the reactor.

4 Startup begins with the withdrawal of the shutdown  
5 banks. The shutdown banks are withdrawn individually, the  
6 whole bank. Shutdown bank A is withdrawn, then shutdown  
7 bank B and so on. They're withdrawn sequentially, one at a  
8 time.

9 The operator is in control of that evolution in  
10 that he or she moves an in-hold-out switch to withdraw the  
11 rods. By holding a switch in the out position, the rods are  
12 withdrawn. The operator also selects which banks should  
13 move.

14 The control banks are withdrawn in the bank  
15 overlap mode I described. The operator selects a manual  
16 mode of operation from the control board bank selector  
17 switch and then uses the in-hold-out switch to withdraw the  
18 rods. Again, the rods are withdrawn with the bank overlap  
19 mode, control bank A first, overlapped with B, then C and D.

20 The operator stops periodically during this  
21 evolution to assess rod movement and the reactivity  
22 addition. The manual mode is used until, in most plants, a  
23 little above 15 percent power, through criticality and up to  
24 about 15 percent power. In the automatic mode of operation,  
25 the motion and direction demand signals are provided by a

1 reactor control unit, which is part of the process control  
2 in the plant.

3           The reactor control unit provides its signals in  
4 response to changes in the average temperature of the  
5 primary system or changes in the demanded power on the  
6 reactor, the turbine demand. Basically, the idea is that if  
7 the temperature in the reactor is lower than it should be  
8 for the given power level, if it's lower than it should be,  
9 we push rods in in order to -- excuse me -- we pull rods out  
10 in order to raise the temperature back to where it should  
11 be.

12           If the turbine power is increasing, we can  
13 withdraw rods to match that new power level and keep  
14 temperatures from changing. During these automatic  
15 operations, the operator does have indication of automatic  
16 operations through several features, including the rod speed  
17 demand is indicated. Demand direction lamps let the  
18 operator know which direction is being demanded and the  
19 changing in the rod position indication, which I'll describe  
20 briefly shortly.

21           It's also important to know that the operator can  
22 override any automatic operation by either selecting manual  
23 operation or, if necessary, by tripping the reactor.

24           Rod motion surveillance tests. Periodically,  
25 surveillance tests are performed according to the technical

1 specifications of the plant. These tests involve taking  
2 each bank individually and moving the bank to ensure that  
3 it's operable, that the rods move in the proper direction.

4 I guess in final review from an operations  
5 standpoint of reactor trip, if the reactor protection system  
6 or the operator initiates a reactor trip signal, either of  
7 two reactor trip breakers can open and drop all of the rod  
8 control cluster assemblies into the core. We've removed  
9 power from the power cabinet, rods drop into the core.

10 So it's important to realize that a reactor trip  
11 signal will override all rod control system signals.

12 MR. THADANI: May I ask you a question at this  
13 point?

14 MR. FOWLER: Yes, sir.

15 MR. THADANI: Have you done enough looking and  
16 checking at this failure mode to be confident of that  
17 statement?

18 MR. FOWLER: Yes, sir.

19 MR. THADANI: Thank you.

20 [Slide.]

21 MR. FOWLER: I'd like to put one final slide up,  
22 which is to look at the indication alarms associated with  
23 the rod control system or the rod control cluster  
24 assemblies. For rod position and movement indications, we  
25 have the individual rod position indication. This is a

1 system for each rod individually. The position of the rod  
2 is indicated to the control room operator.

3 There are also group step counters that display  
4 the demanded position of each group of rods. There are  
5 in/out demand lights located also on the control board that  
6 display what demand is being placed on the system, whether  
7 it's in motion or out motion.

8 There's a rod insertion limit recorder that shows  
9 the bank demand for the control banks, what the bank demand  
10 height is versus the technical specification insertion limit  
11 for the rods.

12 MR. THADANI: Can you --

13 MR. FOWLER: Yes, sir.

14 MR. THADANI: You've gone through a number of  
15 indications and other information that's available to the  
16 operators. Can you kind of briefly describe specifically,  
17 since rod movements take place almost every day at many of  
18 the plants, what do the operators really look for, how  
19 closely do they look at that information?

20 MR. WALSH: Ashok, I think maybe I'd like to try  
21 to answer that since I am at the station and Steve is not.  
22 I think predominantly an operator's responsibility at a  
23 station for any manual rod control would to, at power level,  
24 he's looking at basically a temperature versus turbine power  
25 from matching. Basically, what he's trying to do is

1 accomplish the matching scheme.

2 His activities would be to manually control the  
3 reactor with rod control to make sure that the turbine power  
4 and reactor power are balanced. So his primary concerns are  
5 that the rods are moving in a manner which offers him this  
6 balance.

7 We have been trained on several occasions that  
8 when you are in front of the reactor control system, there  
9 are no other things that should be deferring your attention  
10 away from that system. So I think through training,  
11 requalification and examinations, that's one of the areas  
12 where you understand that the operator pays attention to his  
13 indication.

14 MR. NEWTON: I think the other point to make is  
15 that when the reactor is in automatic and a demand signal -  
16 - the temperature deviation is such that rods need to go in  
17 or out, rod movement occurs automatically, but the operator  
18 is usually made aware of that either through the noise of  
19 the rod position system motion, the lights that come on and  
20 indicate in or out, or, in some cases, some plants have even  
21 had an alarm to make sure they alert the operator to motion.

22 His responsibility, through his training, is to  
23 make sure that the motion and what's happening is correct  
24 for what's going on in the plant. Routinely, as part of  
25 their training, that's their job to do. So they are aware

1 of motion in automatic. They have to verify that it's  
2 responding correctly to what's going on.

3 MR. THADANI: Is this even when you have such  
4 motion taking place fairly frequently? Certainly, for some  
5 plants, I imagine it's quite frequent.

6 MR. NEWTON: All I can speak for is our plant.  
7 The operator -- when a control room is in base load, the  
8 operator watches rod motion. It's something that's  
9 happening. It's something that he has to pay attention to  
10 and it also gives him a lot of subtlety indications of  
11 what's happening in the plant.

12 So he's used to looking at that to, indeed, see  
13 why did the rods move, did I change boron, did something  
14 else happen, is there a frequency change on the grid that is  
15 asking for up or down demand on the turbine. It's the first  
16 indication he has of what's happening around the reactor and  
17 he's used to paying attention to that because that's the  
18 first alert he gets to something happening.

19 MR. FOWLER: I would put in one other comment on  
20 that from a senior reactor operator's standpoint with the  
21 Navy, as well as training. The operator has been trained to  
22 listen to the rods stop moving, as well as start. Once we  
23 have motion, it's key that the operator knows that the rods  
24 should stop and you're listening and looking to see if  
25 that's happening.

1 MR. THADANI: How about the load following?

2 MR. FOWLER: Regardless of when the rods move, I  
3 think what Roger and Larry have said is a true statement,  
4 whether it's during load follow or not. The fact that the  
5 rods are moving is very important to the operators.

6 MR. THADANI: I guess my question -- I'm looking  
7 for a more specific response. If I have fairly frequent rod  
8 motion taking place, I'm trying to understand specifically  
9 what does an operator do. What are the steps that the  
10 operator goes through?

11 MR. WALSH: Well, the steps are one of monitoring  
12 --

13 MR. THADANI: By the way, I understood the control  
14 part, the average versus turbine conditions. I understand  
15 that part. I'm trying to be a little bit more prescriptive,  
16 so to speak. The operator is used to seeing this motion  
17 going at some frequency, I imagine.

18 Is there anything written down that says here is  
19 what an operator is supposed to do when control rods move up  
20 or down?

21 MR. NEWTON: I think that's covered by training.  
22 There's not a set procedure that he goes to or a normal  
23 procedure or alarm procedure. That is covered by training.

24 MR. WALSH: Within the training documentation,  
25 there may be such as training instructor's observation of

1 operators on the main control board. And one of the things  
2 they will observe is not only is the operator paying  
3 attention to the activity in front of him, but is there an  
4 interrelationship between all operators on the board.

5           What I mean by that is -- your question was how  
6 about load follow. Well, no plants that I know of are  
7 allowed to be on automatic load follow with the reactor  
8 plant. It has to be a manual mode change. The turbine  
9 operator is always told to inform the reactor operator when  
10 he is going to make a turbine load change, so that the  
11 operator can verify that the change was accurately done and  
12 that the reactor is following that change in temperature  
13 control.

14           MR. NEWTON: And the reactor operator, he just  
15 doesn't let rods move wherever they want. In most  
16 Westinghouse plants, you've got to make sure you're  
17 controlling your axial power distribution properly. So  
18 during load follow operation, you're adjusting boron  
19 concentration to get your rods where you want them to be.

20           So there's a lot of interaction and attention on  
21 the operator to rod position, because it controls the power  
22 shape of the reactor and he has to maintain that within set  
23 limits.

24           MR. THADANI: Can you, at some point later on, tie  
25 in this issue of the operator attention to what is going on

1 motion for that bank. As it was going in, they noticed one  
2 rod, 1SA3 was now moving out. So they stopped.

3 The next data point we have is where the step  
4 counter is at six. This one rod is indicating eight steps.  
5 All the other rods in that bank, all of the other rods in  
6 the core still indicating zero on the IRPIs.

7 Next, the operators continued to demand in motion  
8 for shutdown bank A and took it from six down to zero. At  
9 that point in time, the one rod that they had noted, 1SA3,  
10 was now indicating 15 steps. All of the other rods are  
11 still indicating zero. Brought in a controls technician,  
12 went into the IRPI racks, verified voltages in the racks.  
13 That confirmed or agreed with the one rod was at 15 steps  
14 and the others are all at zero.

15 The next step was to open the stationary gripper  
16 fuse for 1SA3. The intent was to drop the rod. The  
17 expected response was to see the rod drop from 15 steps to  
18 zero on the IRPI. So that was observed. We also went into  
19 the racks, measured the voltage again. It also was in  
20 agreement with what we had observed.

21 The next thing we did was lift -- the lift coil  
22 disconnects were opened to prevent any further rod motion.  
23 The next troubleshooting evolution was to make some  
24 recordings of the shutdown bank A current orders. When we  
25 did that -- I'll move this up so you can see it. When we

1 reviewed those, we observed distorted wave forms.

2 Subsequent troubleshooting identified two  
3 different failures on two circuit boards. This event is  
4 still being investigated back at the plant.

5 MR. LIPARULO: Our next speaker is Steve Fowler,  
6 who will discuss the failure analysis and range of rod  
7 motions.

8 [Slide.]

9 MR. FOWLER: These are conclusions of the failure  
10 analysis of the failures that occurred within the logic  
11 cabinet at Salem. As Tom mentioned, there were two circuit  
12 card failures, both of them located in logic cabinet slave  
13 cyclers.

14 The effect of those failures on the slave cycler  
15 current orders, taken both singly and in combination, would  
16 have the following effects on system operation. As this  
17 table is showing here, I've broken this out between the  
18 effect of having only one failure that causes an in  
19 direction signal to be present when it's not supposed to be  
20 and this middle column is when only the out direction signal  
21 is present, and then, finally, as it happened at Salem, if  
22 both failures are present.

23 For an in failure only, when a demand is placed on  
24 the rod control system, the following things occur. If the  
25 demand is for in motion with an in direction failure, the

1 system works normally. The rods insert.

2 If the demand is placed on this failure for out  
3 motion, the rods in the group that is selected and receiving  
4 these current orders will either not move or they all move  
5 out.

6 There's a flipflop of this situation for an out  
7 failure. If the failure in the slave circuitry is an out  
8 direction signal, when out motion is requested, the demanded  
9 signals that are sent out by the slave cyclers present  
10 normal out motion. If in motion is requested, then the  
11 slave cycler current orders are demanding either no motion  
12 or out motion, again.

13 At Salem, when both signals were present at the  
14 same time, two separate failures, two slave cycler failures,  
15 whether you requested in motion or out motion, the current  
16 orders that were produced, the distorted wave forms will  
17 produce either no motion or out motion.

18 The conclusion with that is that the slave cycler  
19 current orders, these are some points to note on this, they  
20 are sent to all the CRDMs in the rod group. Again, they are  
21 not sent individually to different CRDMs.

22 The CRDMs may respond with outward motion. They  
23 cannot respond with inward motion. The rods cannot move in  
24 both directions simultaneously. They can only move out.

25 MR. THADANI: Can you clarify that for me a little

1 bit? You said that there's overlap amongst the banks  
2 earlier. So let's take banks C and D. Is it possible that  
3 failures such as the one that occurred at Salem could lead  
4 to one of the banks continuing to insert and the other one  
5 leading to potentially rods going outward?

6 MR. FOWLER: No.

7 MR. THADANI: Okay. Can you tell me why you say  
8 that's the case?

9 MR. FOWLER: Yes, sir. The signals at Salem, the  
10 failures -- when I say it's on the in and the out signals,  
11 those signals or direction signals are applied to all of the  
12 slave cyclers, the in and the out. So if you were in bank  
13 overlap and requesting inward motion from control banks B  
14 and C at the same time, the slave cyclers within B and C  
15 would produce the same corrupted signals. They're being  
16 effected in the same way.

17 So now you'd get to the point where, for control  
18 banks B and C, the rods are either not going to move or the  
19 signals being sent would cause outward motion of all the  
20 rods in the banks. I think that's maybe -- just on the  
21 bullet here is that -- I don't want to miss the third from  
22 the bottom bullet.

23 There is not a demand signal created by these  
24 failures. There's a signal that changes the direction, but  
25 it does not create the signal to say move rods. That is a

1 separate signal. It does not effect that circuitry. It has  
2 no effect on bank overlap. Again, if B and C are supposed  
3 to move, they will. You can't have A and C move, for  
4 example.

5 MR. CHAFFIE: You said that either all the rods  
6 move out in the bank or none of them move at all.

7 MR. FOWLER: Yes, sir.

8 MR. CHAFFIE: Whereas in Salem, one rod moved out.

9 MR. FOWLER: Right. But what I'm stating here is  
10 as far as the failures in the logic cabinet, the signals  
11 that are created should either -- since they're sent the  
12 same to all the CRDMs, should either produce no motion or  
13 out motion, never inward motion.

14 The fact that one rod moved, we'll discuss that  
15 later in this discussion, is not as a result of the signals  
16 coming out of the slave cyclers. Those are identical  
17 signals to all of the CRDMs that are selected at that point.

18 The final point, just to refer back to what I  
19 think was stated in Mr. Thadani's opening remarks, the  
20 failure cannot prevent a reactor trip. Whether the  
21 corrupted or distorted signals are not being sent out, the  
22 reactor trip can override.

23 MR. JONES: May I ask a couple of questions?

24 MR. FOWLER: Yes, sir.

25 MR. JONES: The analysis here is only for the

1 failures of the Salem event, correct?

2 MR. FOWLER: Yes, sir.

3 MR. JONES: This kind of motion was not picked up  
4 by the original FMEA on the system.

5 MR. FOWLER: Actually, there is a statement as far  
6 as the original FMEA for this type of failure. It describes  
7 the effect of the -- as far as the signals that are being  
8 produced and it states that the response will be -- at  
9 power, anyway, will be a reactor trip.

10 I think we can get you that exact statement from  
11 the FMEA. Roger, the next speaker.

12 MR. LIPARULO: The next portion of the discussion  
13 is going to provide our technical evaluation of the  
14 situation of the event. Glen Lang, our first speaker, will  
15 cover the regulatory basis.

16 [Slide.]

17 MR. LANG: We have been asked to provide an  
18 overview of the assumptions we make on the operating modes  
19 of the control systems when we perform our accident analysis  
20 and also the regulatory basis. So I will be covering the  
21 first part. Then we'll talk about the different  
22 classifications of the various rod withdrawal accidents and,  
23 finally, we'll talk about the event-specific analysis that  
24 has been performed.

25 [Slide.]

1 MR. LANG: The discussion you are about to hear  
2 will provide the basis for reaching these conclusions. The  
3 first conclusion we reach is that random failures in control  
4 systems are not assumed nor are they required to be assumed  
5 concurrent with an AOO or a DBA.

6 The second conclusion we will reach is that the  
7 consequences of postulated failures in the rod control  
8 system do not exceed radiological release acceptance  
9 criteria established for a Condition III event. And,  
10 finally, that all plants should continue to operate and if  
11 they are not operating right now, there should be no  
12 restrictions on them returning to power.

13 MR. THADANI: Are you going to address at any time  
14 if credit is taken for control systems or if control systems  
15 can aggravate an abnormal operational occurrence?

16 MR. LANG: Yes, sir.

17 MR. THADANI: You're going to talk about it.

18 [Slide.]

19 MR. LANG: The three regulatory standards to  
20 industry and one regulatory industry standard that we'd like  
21 to briefly concentrate on today would be -- probably the  
22 first one is the most well-known, the IEEE-279 concerning  
23 single failure, IEEE-379 which was written to expound upon  
24 the single failure criteria in IEEE-279, and, finally, the  
25 standard review plan concerning operation of control systems.

1 during the accidents.

2 [Slide.]

3 MR. LANG: Section 4.2 of 279 deals with single  
4 failure. I think everyone is probably familiar with it.  
5 Any single failure within the protection system shall not  
6 prevent proper protective action at the system level when  
7 required.

8 [Slide.]

9 MR. LANG: IEEE-379 was then published to provide  
10 clarification to the industry concerning what Section 4.2 of  
11 IEEE-279 stated. Basically, this is a quote of the  
12 paragraph in 379 that talks about the general single failure  
13 criterion. The point that is most applicable here is "The  
14 protection system shall be capable of performing protective  
15 actions required to accomplish a protective function in the  
16 presence of a single detectable failure within the system,  
17 concurrent with all identifiable, but non-detectable  
18 failures, all failures occurring as a result of the single  
19 failure and all failures which would be caused by a design  
20 basis event."

21 It goes on further in the standard to talk about  
22 non-detectable failures. I just excerpt the part that was  
23 most important. It says "A failure which cannot be detected  
24 by a specific system test," as Mr. Fowler talked about  
25 earlier, "is considered to be non-detectable."

1           And, finally, it goes on and states that "In the  
2 analysis of the effect of each single failure, all  
3 identified non-detectable failures shall be assumed to occur  
4 as part of the original single failure."

5           Now, remember that this standard was written  
6 specifically for Class 1E systems, not necessarily control  
7 systems, and I'll touch upon that in a little while.

8           MR. JONES: Does IEEE-279 apply to a non-1E  
9 system?

10          MR. LANG: No, it doesn't. IEEE-279 was  
11 specifically written for automatically actuated protection  
12 systems.

13           [Slide.]

14          MR. LANG: I believe there were some statements  
15 out of the standard review plan that were very applicable in  
16 the analysis of the Salem event. I specifically picked one  
17 out of Section 15.2.7, which is the loss of normal  
18 feedwater, but it really doesn't make any difference what  
19 incident it's chosen from.

20          But the sequence of events from initiation until a  
21 stabilized -- these are the statements that the reviewer is  
22 giving guidance on what they should look at when reviewing a  
23 specific accident.

24          The extent to which normally operating plant  
25 instrumentation and controls are assumed to function; the

1 extent to which plant and reactor protection systems are  
2 required to function; and, the credit taken for the  
3 functioning of normally operating plant systems.

4 So number one and number three are really the ones  
5 that are in question here, and, finally, also, for ESF,  
6 which isn't applicable in this particular transient.

7 [Slide.]

8 MR. LANG: So based upon those standards which  
9 apply specifically for Class 1E, we then generated our  
10 assumptions that Westinghouse makes in the analysis of their  
11 transient analysis or accident analysis in the FSAR.

12 As required by the standards I just went over, we  
13 must assume a random single failure in the reactor  
14 protection system, concurrent with an initiating event.  
15 Random failure in the control system can be assumed as an  
16 initiating event. Most Condition II events, AMS Condition  
17 II events are initiated due to a random failure in a control  
18 system.

19 The control system operating assumptions during  
20 the --

21 MR. THADANI: Can I hold you on that one for a  
22 moment?

23 MR. LANG: Certainly.

24 MR. THADANI: I have an event. Let me assume it's  
25 loss of load or partial loss of load or something that

1 demands rod insertion.

2 MR. LANG: Yes.

3 MR. THADANI: The intent of the Chapter 15  
4 analyses has always been that we have found a bounding event  
5 in that class of initiators that can take place.

6 MR. LANG: Yes.

7 MR. THADANI: Because you don't want to analyze  
8 hundreds and hundreds of events. Now, you have an event  
9 that calls for rod insertion. You take no credit for rod  
10 insertion, because then you say you might -- you'll get the  
11 next signal. If things get worse, you'll scram the reactor  
12 and the consequences will be okay, whatever class of events  
13 we're talking about, II, III, IV, whatever it is. Right?

14 MR. LANG: Yes.

15 MR. THADANI: Now, what is your view that -- what  
16 if, during this process, you knew that the control system  
17 can aggravate the situation? How would you treat that?

18 MR. LANG: Third bullet. What do we assume for  
19 the control system operating assumptions? Number one, it's  
20 either assumed to be in a manual mode or it's assumed to be  
21 operating in automatic mode. The criteria we use for  
22 determining which of those should be applied when we do the  
23 accident analysis is dependent upon which assumption results  
24 in the most severe consequences of the initiating event.

25 MR. THADANI: But this says assumed to operate

1 normally.

2 MR. LANG: Normally meaning as designed, assuming  
3 no failures exist in the system.

4 MR. THADANI: That's what is confusing me.

5 MR. LANG: We do not assume that there are  
6 failures existing in the control system as -- that's the  
7 last bullet. No random failures assumed, other than the  
8 initiating event, in the control systems, concurrent with  
9 the AOO or the DBA.

10 MR. THADANI: But if you go back to the philosophy  
11 of how these classes were developed and how they were  
12 analyzed.

13 MR. LANG: Yes.

14 MR. THADANI: And a lesson that I thought people  
15 learned after the Three Mile Island accident, the effects of  
16 PORV opening and so on. Is it your view that the  
17 requirement called for not taking credit for control systems  
18 or if you took -- or if the control system were operational,  
19 its failure might degrade the consequences?

20 MR. LANG: We assume that if the operation of the  
21 control system exacerbates the consequences, we will assume  
22 it works normally. The next slide will go into why we will  
23 not take a random failure in a control system concurrent  
24 with the event.

25 MR. NEWTON: Ashok, one of the issues here, too,

1 is detectability, and we'll be talking a little bit more  
2 about that, as to whether this is detectable or not and  
3 whether you need to make the assumption. So it ties  
4 together. But we need to talk about detectability.

5 [Slide.]

6 MR. LANG: So the justification for the position I  
7 just stated that we will take a failure in a control system  
8 as an initiating event, but we won't take it as a random  
9 failure concurrent with the event, is number one. As Mr.  
10 Fowler stated, there are several surveillance tests that we  
11 perform on the control systems during operation.

12 Number two, Mr. Fowler pointed out several things  
13 the operator looked at to determine whether the rod control  
14 system is, indeed, operating as demanded. So there are  
15 multiple, numerous indications in the control room for the  
16 operator to know whether his control rods are going where  
17 they're being demanded.

18 MR. THADANI: I will come back and I think this  
19 has been stated before. You have to put it in the  
20 perspective of what is that information available to the  
21 operator, what is the expected response of the operator, and  
22 the timing of that response and how that relates to your  
23 analyses.

24 MR. NEWTON: I think one of the key issues, too,  
25 is what is normally happening in the control room and if

1 this failure is detected or not. One of the key items is  
2 that for the transient you postulated where you have a power  
3 reduction and the control system should respond to that, the  
4 control system is responding every shift -- I don't want to  
5 say every hour, every minute, but it is in operation every  
6 shift, every hour, and there's usually rod stepping going  
7 on.

8           If the failure would occur and the rods -- the  
9 next time they're demanded to move and they move in the  
10 wrong direction, that would create an unstable situation  
11 that would become detected immediately during the normal  
12 stepping of rods, because it would go out instead of in and  
13 the operator -- that would make the condition worse because  
14 temperatures would be off, there would be more demand for  
15 it, and it would be detected almost on the spot during the  
16 normal fluctuation of rod movement.

17           So one of the keys you'll see and we'll keep  
18 bringing up is whether this fault is detectable or not. I  
19 think our position is very strongly that it is detectable.  
20 That makes the difference as to what assumptions you have to  
21 make in analysis space.

22           MR. THADANI: Roger, I think I understand what you  
23 just said and I'll wait and I'm anxious to make sure we walk  
24 away with a clear understanding that it is detectable. But  
25 also important is the element of timing. When is it

1 detected, what actions are taken, what would be the  
2 consequences given that process that you've gone through.  
3 That's important.

4 MR. WALSH: I agree it's important, but I think  
5 it's important with the idea is does the -- is the operator  
6 the only mechanism that protects -- offers protection. And  
7 if it is, then it's very important that he observes it  
8 closely and rapidly. But we have precedent that operators  
9 have seen failures in feedwater systems that would have  
10 caused reactor trips due to low steam generator levels and  
11 they've tripped out the reactor early enough, but it's  
12 dependent on the mode failure; do they have enough time to  
13 see it and what is their response.

14 And like Roger said, if there was an incident,  
15 we'll say, with load rejection and he realized that the  
16 temperature was not being regulated by the reactor control  
17 system, his choice would be to trip the reactor because of  
18 safety purposes. We can't assume that we can understand  
19 every one of the actions. All we can assume is he's  
20 properly trained and he's well aware of what's going on in a  
21 reactor plant.

22 MR. NEWTON: Also, that failure would have had to  
23 occur simultaneous with that event, and we don't have to  
24 assume those failures. That's a failure in the control  
25 system.

1 MR. THADANI: I want to make sure you don't walk  
2 away with a misunderstanding of what I'm saying. I think we  
3 are pretty well convinced that the protection system will do  
4 what it's supposed to do when the conditions to those set  
5 points.

6 But what I'm trying to focus attention on instead  
7 is what credit is given to operator actions and how that  
8 might influence Condition II or Condition III events and  
9 what are the acceptance criteria that are applied to these  
10 events. I agree with you on the point you made on the  
11 protection system aspects.

12 MR. WALSH: I think maybe we want to hold those  
13 questions until maybe at the end of our presentation when we  
14 evaluate what we think the analysis shows.

15 MR. LANG: To summarize what Roger said concerning  
16 the periodic surveillance and the detectability from  
17 indications available to the operator in the control room,  
18 the conclusion is that the result in low probability in  
19 random control system failures does not have to be taken  
20 with an AOO or a DBA. One point I want to also make --

21 MR. THADANI: Look. I hope somebody is going to  
22 be able to provide supporting information to these  
23 statements you're making.

24 MR. LANG: There will be probabilities presented.  
25 If, indeed, we identify a situation where there's a

1 postulated failure that is not detectable through  
2 surveillance or control room indication, we would assume  
3 that detectable failure or non-detectable failure concurrent  
4 with the AOO or DBA. That is an extrapolation of the  
5 condition that I went over in IEEE-379 which applied to  
6 protection systems, but we would extrapolate that to the  
7 control systems

8 MR. JONES: If I could just follow up and I think  
9 it relates a little bit to my understanding of the failure  
10 mechanisms in the Salem event and the failure of the slave  
11 controllers.

12 As I understand it, you actually could have a  
13 failure which will not -- some sort of voltage fluctuation,  
14 as I understand it, the root cause or the postulated root  
15 cause of the Salem event and it's the continued exercising  
16 of the chip that will degrade the chip and ultimately it  
17 will fail.

18 So that is not a sudden chip failure, but, rather,  
19 something that slowly degrades and then appears. How does  
20 that fit within your definition of detectable failure when  
21 the detectable failure is really voltage fluctuations as  
22 opposed to the chip failure?

23 MR. LANG: We would argue that regardless of the  
24 mechanism of how that failure occurred, if we were operating  
25 at full power during normal rod motion to maintain your

1 reactor temperature, that that failure would have been  
2 detectable, because if a demand would have been generated  
3 for rod out motion or rod in motion and it went the wrong  
4 way, it would have been detectable through process variables  
5 or eventually through alarms available to the operator.

6 MR. LIPARULO: Plus the surveillance testing.

7 MR. JONES: Well, the surveillance testing --  
8 again, as I understand the root cause, the surveillance  
9 testing will not pick up the voltage spikes that were  
10 causing -- or degrading the chip. Again, this is how I  
11 understand it. Am I correct on the failure mode as we  
12 understand it today?

13 MR. RULAND: Today, yes.

14 MR. JONES: Thank you.

15 MR. NEWTON: But we're playing a little semantics  
16 here on what is the failure and what is detected. We're  
17 saying that the result of the failure, which can be any  
18 number of things that can cause the rod control system not  
19 to operate properly. Whatever all those are, those are  
20 detected by the operator when the system does not work  
21 properly.

22 That can be very obvious things, such as alarms  
23 telling him the system is not working to simply silent on  
24 the alarms, but the rods don't move or they move the wrong  
25 direction. We're treating all of those as ways of detecting

1 that the system is not working. We don't detect what caused  
2 it not to work, but we detect that it's not working. We  
3 consider that detectable.

4 MR. WALSH: Let me restate something, too. I  
5 think your description and what I've heard are different.  
6 What you described to me sounded like the distorted signal  
7 caused the chip failure.

8 MR. JONES: No. Not the signal that came out of  
9 the relay card. I'm way over my head in the I&C matters.  
10 So as I say, it's my understanding. But it was something to  
11 do with the counters that were put in giving some sort of a  
12 signal that a high voltage fluctuation is input to the chip,  
13 which could continually degrade the chip with time.

14 MR. WALSH: We don't have that as information, so  
15 I guess I'll pass.

16 MR. RULAND: At some point, you're going to  
17 discuss the probability of failures of the semiconductor  
18 devices. Is that going to be discussed to classify this as  
19 either a Condition II or Condition III event?

20 MR. LIPARULO: Yes. We have a discussion on  
21 equipment failures and probability.

22 MR. RULAND: And how long is -- how many steps are  
23 you talking about before the operator or the system actually  
24 detects the failure?

25 MR. NEWTON: We've had detection at our plant of

1 MR. CHAFFIE: Okay.

2 [Slide.]

3 MR. LANG: My final slide is something I want to  
4 go over on what we assumed. Our control systems, if we have  
5 a Condition I event, the one we arbitrarily chose was a load  
6 rejection. The three control systems that are most  
7 predominant in a load rejection event would be the steam  
8 dump to dump a load, pressurize PORVs, the main thing,  
9 pressure control on the primary, and, finally, the rod  
10 control system to go in to decrease the reactor load.

11 MR. JONES: If I could go back to just that  
12 Condition I, is it not assumed for the load rejection that  
13 that bounds normal plant load maneuvering from a -- that  
14 that -- that, as a design basis event, is expected to bound  
15 scenarios caused by partial load follow events.

16 MR. LANG: You will not find a design transient  
17 load rejection in the SAR analysis. This is what  
18 Westinghouse calls design transients, where they demonstrate  
19 that with control systems operating normally, the reactor is  
20 able to ride through that transient without generating a  
21 reactor trip.

22 But depending upon what load rejection capability  
23 a plant would have, it may be 50 percent, it may be 100  
24 percent. But this would be what we call a design transient  
25 to demonstrate that the control systems can ride through it.

1           What we would do in the accident analysis would be  
2 to analyze an event we call loss of load or turbine trip,  
3 inadvertant turbine trip, to demonstrate that the protection  
4 system set points are adequate to protect the core.

5           MR. JONES: Okay. Let me go back to that event,  
6 then. Is it not fair to say that you would anticipate that  
7 a normal plant maneuver with a single failure in the control  
8 system would be bounded by your design basis load rejection  
9 for, say, a partial load event?

10          MR. LANG: Exactly, and that's what I have down  
11 here. If the control systems operate properly, the steam  
12 dump system would open and when the load was sufficiently  
13 reduced, it would close. If we assume it fails open, we  
14 would say this transient was bounded by our steam line break  
15 analysis, either Condition II or Condition III.

16          If the pressurizer PORV opened, normally it would  
17 close when the pressure in the primary is below the set  
18 point. If it fails open, we would claim that that transient  
19 is bounded by RCSD pressurization, which is the DNB part of  
20 it, and the small LOCA, which is the stuck-open PORV.

21          Similarly, for rod control, if we had a  
22 malfunction of the rod control system during the design  
23 transient, we would say it's bounded by the rod withdrawal  
24 incidents.

25          MR. JONES: And the rod withdrawal incidents are

1 considered to be a Condition II or a Condition III event?

2 MR. LANG: We will get into that in the next  
3 presentation, but they are various. We'll get into the  
4 probabilities in the next presentation.

5 MR. CHAFFIE: And do these rod withdrawal events  
6 include just a bank of rods moving out or individual rods?

7 MR. LANG: We'll talk about the whole spectrum.

8 MR. JONES: Let me go back to my question and let  
9 me ask it slightly differently. If I have a partial load  
10 rejection or just a normal maneuvering transient with a  
11 single failure in the control system, should that event, in  
12 your opinion, be a Condition II or a Condition III event?  
13 Or let's put it this way. Should such an event be within  
14 the design basis as to not cause fuel failure?

15 MR. LANG: We would state that if a failure in a  
16 control system occurred during a design transient, that it  
17 is bounded by a Condition II or III event.

18 MR. JONES: I'm not asking for a load rejection.  
19 I want to be very clear about that. I am talking normal  
20 plant operation, the load follow maneuver. Should such load  
21 following and maneuvering given a single failure in your rod  
22 control system, should such an event -- should the  
23 protection system given that event act in a timely manner  
24 such that no fuel rod failures would be postulated to occur  
25 from a failure of, like, the DNB limit?

1 MR. NEWTON: Let me see if I can answer the  
2 question. I think what we're saying is that for a rod  
3 control system failure, we would expect that a bank or group  
4 of rods would move together and that's been analyzed as a  
5 Condition II event, for what we'll be talking about later.

6 We'll talk about Condition III as part of the  
7 discussion that will deal with that probability. But to  
8 answer your question, I think it's a Condition II event that  
9 we would expect the failure mechanism to result in bank  
10 movement.

11 MR. JONES: Fine.

12 MR. NEWTON: Bob, the reason I say that is that  
13 it's a detectable situation in that the failure would occur  
14 at that time from rod motion, the lack of it. If it had  
15 been operating perfectly up to that point in time, rods  
16 moving together as a bank in and out, and then you have a  
17 failure, a single failure per our analysis that results in  
18 signals going to banks or groups of rods.

19 MR. JONES: I guess what I'm trying to be careful  
20 of and separate is -- I know you're putting a lot of stock  
21 on this detectable, but going along with the detectable  
22 argument, I think there's some sort of an assumption as to  
23 the challenge rate. So that there are periods of time when  
24 you could be detecting or have to assume other additional  
25 single failures.

1           When you talk about events like load rejection,  
2 turbine trips, these are not daily things. If a plant is in  
3 a load following mode, that plant can be maneuvering  
4 multiple times during that day, making multiple demands, and  
5 a 30-day surveillance may not be adequate as a detectable -  
6 - as detection. It may just pop up.

7           So what I'm looking to make sure is the design  
8 basis event, in our minds, at least certainly in my mind,  
9 has been chosen to bound a lot of what I would call normal  
10 everyday operations with single failures in these various  
11 control systems.

12           Whether the situation is detectable or not, if  
13 these kind of normal everyday maneuvers with the failure  
14 within the control system should be bounded by some other  
15 design basis transient.

16           MR. NEWTON: I think one of the keys we're going  
17 to show you, and that's why we keep going to detectability,  
18 is that it's the basis for our failure rate argument later  
19 on and what occurred in the different categories.

20           MR. WALSH: Going back to your discussion of load  
21 follow where plants could be moving their load daily, that's  
22 a daily exercise of the rods. So their 30-day surveillance  
23 test is happening daily. So the operator observes every day  
24 that the rods are functioning properly.

25           MR. JONES: But the difference, though, Larry, is

1 I'm not taking you to the next step, which is give me a  
2 turbine trip with the control system moving with the single  
3 failure. I'm just taking what happens for normal plant  
4 maneuvers with this single failure, where do you end up.

5 Do you consider that bounded or within your  
6 analysis envelope as a Condition II event? I believe it is.

7 MR. THADANI: I think maybe if we can go on, I  
8 suppose we talk about detectable or detectable and  
9 undetected failures, the concept of standby is important.  
10 But for plants where you have rods moving continuously, I'm  
11 not sure how significant an issue that is, except when you  
12 get into the issue of frequency and what defense you're  
13 going to be looking at. I'm very anxious to hear the next  
14 part.

15 MR. NEWTON: I think the point we're trying to  
16 make is that with the plants with rods moving all the time,  
17 if this failure would then suddenly occur, it would become  
18 detectable right away because they're moving right away and  
19 they would detect it before the transient that you're  
20 talking about occurred.

21 MR. JONES: Let me ask it simply. Will the  
22 presentation -- this is a yes or no question. Will the  
23 presentation show me or give me the results of analysis of a  
24 partial load -- well, a load following maneuver with this  
25 single failure assumed in it?

1 MS. VERTES: It will tell you that the analysis  
2 that we've performed bounds that situation.

3 MR. JONES: As a Condition II event.

4 MS. VERTES: We will conclude that it's  
5 appropriate to consider it a Condition III, given what  
6 occurred at Salem.

7 MR. JONES: But you do not have the specific  
8 analysis I asked about.

9 MR. NEWTON: We have it treated as a Condition III  
10 event, that failure.

11 MR. JONES: Okay.

12 MR. COLLINS: It looks like from the slides we're  
13 going to get into a key portion of this meeting. Would this  
14 be a good point to take maybe a ten-minute break?

15 MR. NEWTON: We're at a natural break point here.

16 MR. COLLINS: Why don't we take a ten-minute  
17 break, come back at quarter to three.

18 [Recess.]

19 MR. COLLINS: Let's get started again. Ms.  
20 Vertes.

21 [Slide.]

22 MS. VERTES: This is what we were going to  
23 describe before we took the break, and that is that the  
24 basic design philosophy behind safety analysis  
25 classification is that the Condition II, Condition III,

1 Condition IV event classification is based upon probability  
2 of occurrence.

3 We have analyzed a number of rod withdrawal  
4 scenarios, all of which could have been postulated to occur  
5 as a result of the Salem event, some of which are already  
6 analyzed within the FSAR to be postulated to occur as a  
7 result of other initiating scenarios.

8 Of those rod withdrawal events, all of them are  
9 bounded by the conditions at which we -- well, below --  
10 initiation from a load follow scenario is bounded by the  
11 analysis that we have done, either from full power or part  
12 power.

13 In general, we've seen that initiation from a  
14 steady-state condition at full power bounds initiation at  
15 some part-power condition at which you would be during a  
16 load follow event. The basis for that is a methodology we  
17 use in analyzing rod withdrawal at power events, and that  
18 has to do with the fact that we assume that these events  
19 trip on over-temperature delta-T and that we conservatively  
20 assume that conditions in the core will be at the most  
21 limiting spot, if you will, on the core limit line, such  
22 that we've actually taken a very conservative bounding  
23 approach.

24 If you want to get into the details of why that  
25 approach would support any initiation condition from part

1 power to full power, we can get into that later. But I  
2 think the basic premise is that the analyses that we've done  
3 would bound initiation from a load follow.

4           Whether it should be classified as a Condition II  
5 or a Condition II event is dependent upon what initiates  
6 that event following a load follow.

7           With respect to the basic design philosophy, I'd  
8 like to discuss this with respect to how we classify the  
9 Salem events. I'd like to just first start off by saying  
10 that the basic philosophy is that those that are most likely  
11 to occur should have the least risk to the public health and  
12 safety.

13           Those that have the potential for the greatest  
14 risk should be the least likely to occur. That basic  
15 premise is used in determining the Condition II, Condition  
16 III and Condition IV frequency. And because of those  
17 frequencies, the acceptable consequences are gradually  
18 increasing based on those classifications.

19           [Slide.]

20           MS. VERTES: In addition to the ANS classification  
21 events design philosophy that's used in plant FSARs for  
22 categorization of safety analysis events, the general design  
23 criteria is also used to determine the acceptance criteria  
24 for control and components within the reactor coolant  
25 system.

1           The GDCs themselves specify the acceptable  
2 criteria for operation of control and components. GDC-25  
3 relates specifically to reactivity control system  
4 malfunctions. GDC-25, which was alluded to earlier,  
5 specifically states that the protection system shall be  
6 designed to assure that the specified acceptable fuel design  
7 limits are not exceeded for any single malfunction of the  
8 reactivity control system, such as accidental withdrawal of  
9 control rods.

10           MR. JONES: Could you give me your definition of  
11 what the specified acceptable fuel design limits are with  
12 respect to GDC-25?

13           MS. VERTES: The specified acceptable fuel design  
14 limits, as referred to in the standard review plan, refer  
15 you back to the minimum DNBR. We would say that although  
16 specified acceptable fuel design limits, as referred to in  
17 the SRP, are minimum DNBR, but we feel that the intent of  
18 GDC-25 is to show that the probability of an event should be  
19 commensurate with the consequences or the consequences  
20 should be commensurate with the probability.

21           Hence, it's acceptable, if you have a sufficiently  
22 low probability of having a control system malfunction that  
23 would result in some challenge to the reactor protection  
24 system, that the consequences should be based on the  
25 probability of occurrence.

1 MR. THADANI: I guess I understood the first part  
2 of your previous viewgraph. Have you researched this issue  
3 so completely as to conclude what you just did? That the  
4 intent of this GDC was to look at what the probabilities  
5 might be and to assign appropriate safety limits given those  
6 probabilities.

7 I think this GDC has defined consequences. It is  
8 not into your previous chart, because the fuel design  
9 limits. That's the consequence you want to make sure is not  
10 exceeded.

11 But you concluded that that's driven by  
12 probabilities, I think quite correctly. However, this goes  
13 on to say for any single malfunction, there's no explicit  
14 statement on what that probability is. There's implicit  
15 consideration of probability by saying any single  
16 malfunction.

17 If you had said implicit in this is some  
18 probability consideration, I would agree with that. But I  
19 think you took the next step. That's the part that I don't  
20 understand.

21 MR. NEWTON: I think the next step is required in  
22 many of the things we do when we exercise our judgment and  
23 how we interpret the regulation. Some part is very  
24 explicit. Some part is -- we have to establish how to  
25 interpret it.

1 MR. THADANI: I understand that, but have you done  
2 that -- now, what I'm saying is do you agree, first, that  
3 the consequence is clearly defined here? Is there any  
4 question about the consequence part?

5 MR. NEWTON: Let me put it this way. We're giving  
6 you our logic for making the call under Part 25. If you  
7 disagree with that, we're asking you to explain why that is.  
8 We think the logic ties together and meets the understanding  
9 of the regulation. So we have a sub-logic here and it is  
10 tied to probability of occurrences.

11 MR. THADANI: Let me make sure. Let's take this  
12 slowly because this is an important issue. Did you read in  
13 the GDC the very explicit definition of what the acceptance  
14 criteria are?

15 MR. NEWTON: It identifies specified acceptable  
16 fuel design limits.

17 MR. THADANI: Have you gone through years and  
18 years of analyses as to what this actually means?

19 MR. NEWTON: We're here to meet to determine what  
20 that is. We feel that ---

21 MR. THADANI: What is specified acceptable fuel  
22 design limits?

23 MR. NEWTON: Right. We feel that there is a  
24 definition for Condition II and Condition III that are used.

25 MR. THADANI: I think let's start -- I want to be

1 very -- let's be very explicit. Do you know what those  
2 terms mean?

3 MR. NEWTON: We are giving your our  
4 interpretation.

5 MR. THADANI: Have you seen safety analyses  
6 reports, your safety analyses reports which define what  
7 these terms mean?

8 MR. WALSH: Chris, could you help us on our  
9 interpretation?

10 MS. VERTEES: There are some specific plant FSARs  
11 which do talk about probability of occurrence and meeting  
12 specified acceptable fuel design limits within the Condition  
13 III classification of events, which would lead one to  
14 believe that you could interpret specified acceptable fuel  
15 design limit to be the criteria for the classification of  
16 events.

17 MR. THADANI: We may have to come back to this  
18 issue. Now, in terms of the single failure, can you define  
19 better what you think the intent was by way of people who  
20 crafted this GDC? What do you think they were looking for?

21 MS. VERTEES: I think the intent, and I'm not sure  
22 whether my thoughts on this have any real meaning with  
23 respect to the outcome of this, was very similar to the  
24 classification of events in terms of probability, that it  
25 was thought that a single malfunction had a fairly high

1 probability of occurrence and that, therefore, one should  
2 limit the consequences to that of the specified acceptable  
3 fuel design limit, which I believe at the time the intent  
4 would have been minimum DNBR.

5 MR. THADANI: Yes. Now, I did not ask you on your  
6 previous viewgraph for a very specific reason. Now, let me  
7 ask you what is the role of confidence limits in these  
8 discussions? When you assign probabilities, do you think  
9 there is some confidence level at least considered?

10 MS. VERTES: I think that's appropriate.

11 MR. THADANI: Are these estimates at 95 percent  
12 confidence?

13 MS. VERTES: At this time, I would --

14 MR. LIPARULO: Ashok, I think we have a  
15 probability assessment that we'll discuss later that puts  
16 us, based upon the data we have, within the range of a  
17 Condition III event. We have not had the time given the  
18 schedule we've been under to assign confidence levels at  
19 this point.

20 MR. THADANI: Nick, I understand that. What I'm  
21 trying to make sure is I understand the thought process and  
22 what -- as a minimum, I'd like to understand what are those  
23 boundary conditions that we're trying to make sure that we  
24 are working to. There are two very important pieces in  
25 this. One is consequences. In that statement, we all need

1 to understand what those are.

2 We also need to understand the first part, which  
3 is the issue of probabilities. While I understand you  
4 haven't had a lot of time, I would like to understand if you  
5 think the -- since we're talking about the intent and the  
6 thought process, if you think people were looking for some  
7 high level of confidence when they considered these values.

8 MR. WALSH: Ashok, I think we're going to show  
9 analysis later and then we're going to show the probability  
10 effects, and then come back on a slide that summarizes, and  
11 that might be a better point to discuss the same issue.

12 MR. THADANI: Okay.

13 MR. JONES: Can I ask just one simple question?

14 MS. VERTES: Certainly.

15 MR. JONES: To the best of your knowledge, in  
16 demonstrating compliance to GDC-25 prior to the Salem event,  
17 did you interpret the SAFDLs in a probability sense or was  
18 it the minimum DNBR that you used in demonstrating  
19 compliance?

20 MS. VERTES: I believe that prior to the Salem  
21 event, there was no single malfunction that fell outside of  
22 Condition II criteria and the Westinghouse method  
23 demonstrates acceptable consequences by meeting the minimum  
24 DNBR limits. So there was no intent not to consider  
25 confidence. It was logical to just look at minimum DNBR.

1 MR. LIPARULO: I think, Bob, when our next speaker  
2 comes up, Baard Johansen, he can at least discuss in his  
3 analysis that I believe we did have a probability and a  
4 confidence associated with that, his transient analysis.

5 MR. WALSH: We're at a little bit of a  
6 disadvantage in that answer because I think most of the  
7 FSARs that look at some of these events, like single rod  
8 withdrawal and bank rod withdrawal, just have a common  
9 statement. There are Condition II and Condition III events  
10 here and I don't know if we narrowed it down to which is  
11 which. So we've got a little bit of both.

12 [Slide.]

13 MS. VERTES: With respect to the appropriate  
14 classification of this event, I think there's four very  
15 important points to make with respect to detectability. We  
16 believe that the occurrence at Salem is detectable based on  
17 two things; one, the every day frequency of rod motion and  
18 the monthly surveillance.

19 We also believe that this is a low probability  
20 event based on the operating history of the Westinghouse  
21 PWRs. From the reported data that we have looked at or we  
22 have been able to obtain, there are only two events which  
23 were reported which indicated that a card failure resulted  
24 in an RCCA misalignment. In both of those cases, the  
25 misalignment was a group or a bank of rods.

1           Both of those are symmetric rod withdrawal events  
2 which are bounded by current FSAR analyses classified as  
3 Condition II events. So at this point, there is no event  
4 that's been reported which results in a single rod  
5 withdrawal at a power or subcritical condition.

6           The initial assessment of the probability of this  
7 event based on the reported data that we looked at would be  
8 commensurate with the Condition III probability.

9           In addition, that probability was based upon  
10 looking at the card failures which resulted in misalignment,  
11 not necessarily extrapolating that to the limiting condition  
12 which would be a multiple asymmetric withdrawal and it would  
13 be a very specific scenario defined in a very -- given, say,  
14 nine D bank rods, you would have to look at the two rods  
15 from the two groups within D bank that are adjacent to each  
16 other.

17           There's only, I think, one four-loop rod control  
18 system configuration with the nine rod D bank. So it's a  
19 very limited scenario which results in the most significant  
20 consequences. And the probability of that occurring is  
21 much, much lower than the probability of the card failure  
22 resulting in misalignment that we've assessed based on the  
23 data that's available.

24           MR. THADANI: Yes. I think that's an important  
25 point you make. I assume in the analysis you have concluded

1 that is the only case where you're going into --

2 MS. VERTES: That's correct.

3 MR. THADANI: Okay. The second part -- and I  
4 agree with you. That clearly has to be of lower likelihood  
5 than any failure. But the second part is have you ruled out  
6 aging effects? If you're estimating probability, then you  
7 have to look at some random phenomenon.

8 MR. LIPARULO: We have a specific discussion of  
9 aging coming up in the PRA discussion. In summary, we do  
10 not see a correlation with respect to age.

11 MR. RULAND: One question about detectability.

12 MS. VERTES: Yes.

13 MR. RULAND: In this case, the operator moved --  
14 at Salem -- moved the rods 20 steps and albeit shut down.  
15 Is that within your bounds at power or detectability that  
16 they're given 20 steps to detect it or more? I mean, at  
17 what point does it have to become --

18 MS. VERTES: With the analyses that we've done at  
19 part power and full power conditions, we've taken no credit  
20 for operator action. So we've assumed that the rods would  
21 just move -- a single rod or a multiple rod, whichever would  
22 be the limiting scenario, would move out of the core and you  
23 would get a trip on an over-temperature delta-T, and we've  
24 analyzed the consequences as a result of that.

25 For the rod withdrawal for subcritical analyses

1 that we have looked at, if we were to assume that the  
2 operator were to act within 48 steps, I believe, and Beard  
3 will get into this, that we would show that the minimum  
4 DNBR, when it would be met -- three individual rods from  
5 subcritical.

6 If we have to -- if we do not credit operator  
7 action and we assume that the rods would continue to  
8 withdraw from the core, then we would expect to see a small  
9 percentage of rods fail, but that's based on using our  
10 current methods. If we were to use more sophisticated  
11 tools, we would expect to be able to demonstrate that there  
12 would not be any significant fuel failure.

13 MR. NEWTON: I don't know if that was the answer.  
14 That's the accident analysis answer. Now, if you're asking  
15 the operator question, how soon does he detect it, if the  
16 operator is getting feedback, meaning he's critical or he's  
17 at power, 20 steps is a lot of rod motion without any  
18 response from a reactor.

19 So he's detecting it probably before that, unless  
20 he's totally got his back to it. Then you go to the  
21 accident analysis to see what the consequence is. The only  
22 time an operator does not get significant feedback to rod  
23 motion is when he is substantially subcritical, which was  
24 the case at Salem, where he was lifting the first shutdown  
25 bank out and he had his position indication then as his only

1 indicator of rods out of position.

2 But the other time, you always expect the in or  
3 out feedback from in or out motion and the reactor behaves -  
4 - within a few steps, you've seen reactivity increase power,  
5 decrease temperature, whatever you're doing. It's there.

6 MR. WALSH: In addition, he's going to have to  
7 ignore alarms because there's a 12-step deviation alarm away  
8 from bank. So there's an actual alert point that he's got  
9 to ignore to continue to --

10 MR. NEWTON: Right. If you set all of that aside,  
11 what Chris is talking about -- what she's going to talk  
12 about on the accident analysis results.

13 MR. THADANI: I guess I would still go back to how  
14 much time are you estimating is available before a certain  
15 number rods go into DNBR or at least DNB condition, perhaps.  
16 Certainly below 1.3, I guess.

17 MS. VERTES: Can you address that? Yes. Beard  
18 will address that during his presentation.

19 MR. THADANI: And I would like to understand that  
20 in the context of what Roger just said. Where are the  
21 operators and how long does it take for certain actions to  
22 be taken and how long does it take for rods to go into DNB?

23 MR. NEWTON: For the at power case.

24 MR. THADANI: For the at power case.

25 MR. RULAND: One more question about the operating

1 history. How confident are you of your database? Meaning  
2 that you've identified all the instances where this  
3 happened. The operator did move 20 steps before he noticed  
4 it and it took some additional rod motion before he finally  
5 figured it out.

6 MS. VERTES: I don't know that I'm the best person  
7 to answer that. I know that we intend to do a survey. We  
8 do realize that not all these card failures would be  
9 reported, but we also feel that it's not appropriate to  
10 consider every card that is replaced during a maintenance as  
11 a failure.

12 Steve or --

13 MR. NEWTON: Let me just see if I can answer that  
14 from a history perspective. We have a limited database that  
15 we have used and it's the best we have now without going and  
16 asking the utilities to more specifically go back into their  
17 records and look at what's there and bring it forward.

18 So we ourselves feel that we think it's indicative  
19 of what's happening. We're also basing this on our own  
20 experience from operating the reactors for 20-25 years and  
21 not having these things happen. This is an unusual event  
22 that if it happened, operators would be remembering it. We  
23 don't have many of these there.

24 So we know we've operated reactors for hundreds of  
25 years without having this happen. We need to go back in the

1 database and look more closely at that, because every once  
2 in a while when you look real closely, you get surprised,  
3 and we want to do that.

4 That's one of the things that we'll be talking  
5 about later. That's one of the commitments the Owner's  
6 Group is making to further quantify the probability.

7 MR. WALSH: We already stated that we didn't think  
8 we had a real high confidence because of the time scale  
9 we've been working in and trying to get back to you at this  
10 meeting to let you know the general overall picture of what  
11 we have determined.

12 Our intention is to not let go of this and  
13 continue to investigate to get some confidence levels.

14 [Slide.]

15 MS. VERTES: I'd like to address this with respect  
16 to the Salem event, which I think sheds some additional  
17 light on the significance of the situation. Given the  
18 failure in the logic cabinet that we saw at Salem, all the  
19 rods in shutdown bank A should have either moved out or  
20 remained stationary.

21 We believe that there must have been some other  
22 condition which resulted in a single rod being withdrawn  
23 from the bank. We have a technical investigation that's  
24 still ongoing and it's important to understand that if  
25 another mechanism had not been present, the resulting event

1 would have been a bank or a group withdrawal, which is  
2 currently bounded by the safety analyses presented in the  
3 FSAR.

4 So it's only in addition to this condition that we  
5 need to continue to further investigate that you would have  
6 a situation where you could have this limiting condition  
7 with an asymmetric rod withdrawal occurring.

8 Again, the initial probability assessment that we  
9 feel is appropriate is to assess this as a Condition III  
10 event, and, therefore, that it would be appropriate to  
11 demonstrate compliance with the Condition III event  
12 criteria, which would allow for a small fraction of the fuel  
13 to be predicted to fail.

14 Westinghouse conservatively assumes that it -- we  
15 predict that the rods are below the design DNBR limit, that  
16 they are assumed to go into DNB and that there's a small  
17 amount of fuel failure that would result.

18 But in reality, what we have seen based on the  
19 results is that the small prediction of the fraction of  
20 failed fuel that we would get based on using this assumption  
21 would easily allow you to conclude that there would be  
22 absolutely no gross fuel damage at all.

23 MR. THADANI: This is, again, with the assumption  
24 that you take experience and make a point estimate.

25 MS. VERTES: Sure, certainly. We have to be able

1 to do that.

2 MR. THADANI: And you're equating the point  
3 estimate to your earlier ranges.

4 MS. VERTES: Yes. Based on this, we feel that the  
5 intent of GDC-25 has been met with these analyses.

6 MR. CHAFFIE: So what you're saying, then, is that  
7 there should be no single failure that should cause a single  
8 rod withdrawal to occur and there must have been something  
9 else at Salem in addition to this one shift failure that's  
10 causing a single rod to move.

11 MS. VERTES: I don't know that we know that at  
12 this time, but there certainly appears to be something else  
13 besides a single failure which would result in the incorrect  
14 current signal. The incorrect current signal would be sent  
15 to all the rods in the bank and you would expect that all  
16 those rods in the bank would either move out or stay  
17 stationary.

18 And to postulate that the single rod randomly  
19 moved out is something that we're not ready to conclude yet.

20 MR. RULAND: Let me ask you to postulate  
21 something. Let's suppose the single rod moved out because  
22 of a design tolerance or corrosion of the mechanism or  
23 something along those lines. Would this change the  
24 conclusion you've drawn here?

25 MS. VERTES: I would say not. Based on the

1 probability of occurrence of the event, we still would feel  
2 that it's appropriate to consider the consequences  
3 commensurate with Condition III.

4 MR. CALVO: Jose Calvo, NRR. Will you duplicate  
5 this particular thing at Salem? Have you tried to do it  
6 again to see what happens and you only tried one rod or all  
7 the rods in the bank happen to be moving in the wrong  
8 direction?

9 MS. VERTES: I believe they did a test and when  
10 they did the test, all the rods that received a signal moved  
11 out. The incorrect signal moved out. So we were not able  
12 to reproduce one out of a bank or group receiving the same  
13 demand.

14 MR. WALSH: I think we ought to let Salem answer  
15 that since they're closer to the issue.

16 MR. LaBRUNA: We did not duplicate the in situ  
17 performance that duplicated or didn't duplicate. We just  
18 did not run a test, an active test of actually movement of  
19 rods. We did do some testing at our training center where  
20 we have a mockup, but it's obviously not the exact  
21 environment for loads on the drive mechanism.

22 MR. CHAFFIE: But in spite of the fact that you  
23 don't think any single failure could cause a single rod  
24 withdrawal or, the worst case, I guess, two rods adjacent to  
25 each other, you still took into account an analysis that

1 showed the impact of a single rod or two rods.

2 MS. VERTES: Yes.

3 MR. CHAFFIE: As it pertains to a Class III event  
4 against the Class III criteria.

5 MS. VERTES: Yes.

6 [Slide.]

7 MS. VERTES: These are the events that one could  
8 postulate as a result of the Salem event. The single RCCA  
9 withdrawal at power, which is what you just referred to, is  
10 currently analyzed in many plant FSARs as a Condition III  
11 event. The classification was based on -- was thought to  
12 take multiple failures or multiple operator errors to result  
13 in a single rod withdrawing from a bank or group.

14 The other events --

15 MR. COLLINS: Excuse me. Does that event result  
16 in exceeding the DNBR?

17 MS. VERTES: Yes.

18 MR. COLLINS: The FSAR.

19 MS. VERTES: Yes.

20 MR. COLLINS: It does.

21 MS. VERTES: Yes. The criteria used is a small  
22 fraction of the fuel could fail. The Westinghouse criteria  
23 has typically been five percent. Most of our analyses  
24 demonstrate that you're well below that. In addition to the  
25 single rod withdrawal at power, you could postulate a single

1 rod withdrawal from subcritical. Also, you can postulate  
2 bank withdrawals from power or subcritical, and, finally,  
3 asymmetric rod withdrawals at power or asymmetric rod  
4 withdrawals from subcritical.

5 Of these six postulated events, it's the single  
6 rod withdrawal from subcritical and the asymmetric rod  
7 withdrawals from either at power or subcritical conditions  
8 that have not yet been analyzed and presented in plant  
9 FSARs.

10 Westinghouse has done analyses and evaluations to  
11 look at these scenarios, has determined that the asymmetric  
12 rod withdrawals are the most limiting conditions. We have  
13 looked at that from both at power and subcritical  
14 conditions, and Beard will present the analyses for that.

15 The one point I wanted to make earlier and I just  
16 want to reiterate on -- Bob, you had asked the question with  
17 respect to load follow. Of all these events that you can  
18 postulate, for the at power events, if we were to analyze  
19 them from some part power condition given a load follow when  
20 you had a demand on the rods and you were to postulate that  
21 this failure would result in a single or an asymmetric rod  
22 withdrawal, the consequences initiated from a load follow  
23 versus full power steady-state conditions would be no  
24 different based on the way we do the analyses.

25 They would be bounded by what we have done.

1 MR. CHAFFIE: I have a question. Of the different  
2 examples that are on here, I take it all of these would meet  
3 the criteria for Class III type event.

4 MS. VERTES: Yes.

5 MR. CHAFFIE: Not exceed that. How many of these  
6 would not meet Class II criteria?

7 MS. VERTES: Right now, from what we have done,  
8 which is a bounding case to try to make an initial  
9 assessment, given the timeframe, the asymmetric rod  
10 withdrawals and the single rod withdrawal subcritical would  
11 not meet Condition II criteria given our current methods and  
12 the bounding assessment we have done.

13 The bank rod withdrawals are analyzed in the FSAR  
14 to meet Condition II criteria. The single rod withdrawal at  
15 power is currently presented in most plant FSARs as a  
16 Condition III event and is not required to meet Condition II  
17 criteria.

18 [Slide.]

19 MS. VERTES: Based on the analyses and evaluations  
20 that we have done, we've assessed the following. The events  
21 that can be postulated -- the limiting event that could be  
22 postulated has a low probability of occurrence which is  
23 commensurate with Condition III and infrequent fault.  
24 Therefore, we feel that the allowance of a small amount of  
25 fuel damage is consistent with the design philosophy used in

1 the classification of events and determining acceptable  
2 consequences.

3 The conservative analysis that Westinghouse has  
4 done to assess the significance of this issue at this time  
5 would allow us to demonstrate that the rods would experience  
6 a calculated DNBR below the limit value, but that it would  
7 only be a small percentage of the rods and that little or no  
8 actual fuel failure would be predicted to occur.

9 Based on that, we feel that this presents no undue  
10 risk to the public health and safety.

11 MR. THADANI: Let me ask you your opinion.  
12 Condition II events are ones, I guess, you analyze or --  
13 quite a large number of them. For those Condition II  
14 events, the way they are analyzed, you have to meet design  
15 limits, and that includes fuel design limits.

16 MS. VERTEES: Correct.

17 MR. THADANI: The initiating events that you  
18 considered there have frequencies less than ten-to-the-  
19 minus-two per reactor year implicitly and we will not yet  
20 define at what confidence level.

21 MS. VERTEES: Right.

22 MR. THADANI: Would you agree with me that I have  
23 now identified a class of events that the way these are  
24 analyzed is conservative fashion; that is, you assume  
25 conservative initial conditions?

1 MS. VERTES: Yes.

2 MR. THADANI: You have, in general, a conservative  
3 evaluation model.

4 MS. VERTES: Yes.

5 MR. THADANI: You don't take credit for certain  
6 situations.

7 MS. VERTES: That is correct.

8 MR. THADANI: Give me your own view of what you  
9 think the possibilities might be when you take all those  
10 conservative factors together and still meet fuel design  
11 limits. What do you think the probability might be?

12 MS. VERTES: The probability of occurrence or the  
13 -- I'm not sure --

14 MR. THADANI: Of the event for which the whole  
15 scenario, the event itself, plus the way you analyze with a  
16 lot of conservative assumptions, for which you say you must  
17 still meet fuel design limits.

18 MS. VERTES: I'd say it can't occur.

19 MR. THADANI: That's probably true. I'm trying to  
20 get you to take the next step. That is, there is a concept  
21 of confidence. When you have this approach of frequency  
22 safety limits -- and I think you're exactly right. The more  
23 likely the event, the tighter the limits.

24 But it's not a point.

25 MS. VERTES: Okay. I agree.

1 MR. THADANI: It's a band. And I'm trying to get  
2 you to think about this not in the point estimate world, but  
3 more in the confidence world, so to speak. Ninety-five  
4 percent is traditionally what a lot of people do. It  
5 doesn't have to be that.

6 From your own studies and looking at these, what  
7 do you think people are looking for? Do you think they are  
8 looking for some level of confidence?

9 MS. VERTES: Yes. I think they are looking for  
10 some level of confidence. It's something that we feel,  
11 given the way the events are categorized or classified and  
12 not recognizing all the conservatisms that one puts into an  
13 evaluation model.

14 You clearly have a hundred percent confidence that  
15 you've met acceptable criteria. I can put it in the reverse  
16 maybe and say that if I were to use -- if I were to  
17 eliminate the gross conservatisms and some of the incredible  
18 assumptions that I assume coincident in my methodology and I  
19 were to use a three-dimensional spacial kinetics model and  
20 look at this event, rod withdrawal from subcritical, rod  
21 withdrawal from power, asymmetrically or otherwise, that I  
22 would be able to demonstrate that I would not violate my  
23 minimum design DNBR limit.

24 MR. THADANI: Good. Now, that's where I'm headed  
25 also. Have you done such analyses?

1 MS. VERTES: We've done one representative case.  
2 We've spoken to a licensee, NNC in Britain, who's currently  
3 licensed to model or is in the process of licensing a three-  
4 dimensional model for Sizewell B in the United Kingdom.

5 Based on those results, we would expect to be able  
6 to demonstrate the same. However, Westinghouse currently is  
7 undergoing V&V on that particular analysis methodology and  
8 it's not yet approved by the staff. So we've done some work  
9 with SP Nova-K, which is the code that we would be using,  
10 and demonstrated significant DNBR margins exist, but we  
11 haven't been able to do that in licensing space.

12 MR. THADANI: Okay.

13 MS. VERTES: With that, I'd like to introduce  
14 Baard Johansen, who performed the safety analyses to assess  
15 the significance of these events.

16 MR. LIPARULO: Baard, could you characterize the  
17 probabilities and confidence levels of your analyses? It  
18 was mentioned that you were going to do that.

19 MR. JOHANSEN: Yes. I think that's something we  
20 can go through as I talk about the analysis, talk about what  
21 sort of conservatisms were actually included in terms of the  
22 DNBR criteria that we're comparing to, what sort of  
23 confidence is applied to that.

24 My name is Baard Johansen. I'm Acting Manager of  
25 the Core Design Section in the Nuclear Manufacturing

1 Division at Westinghouse.

2 My responsibility was to evaluate the core  
3 response and the accident analysis impact of the asymmetric  
4 rod withdrawal events, both at power and occurring from  
5 subcritical condition.

6 [Slide.]

7 MR. JOHANSEN: Let me just quickly give you an  
8 event description of the asymmetric rod withdrawal at power.  
9 The assumption based on the postulated failure mechanism,  
10 how this event could occur. RCCA banks would be operating  
11 within the rod insertion limits in normal overlap. So  
12 you're going to be at some power level with the rods  
13 anywhere from their lower rod insertion level to the top of  
14 the core.

15 At some point, operator demand or automatic rod  
16 control demand for an RCCA insertion coupled with the  
17 postulated failure or control system malfunction results in  
18 a single or multiple RCCA withdrawal.

19 Obviously, if you have an entire bank withdrawing,  
20 you're covered by or analyzed as part of our RCCA bank  
21 withdrawal at power accident. Also, for most current plants  
22 FSARs, we consider the event of single RCCA withdrawal at  
23 power and demonstrate that only a small fraction of the fuel  
24 would be below the DNBR limit. Typically, that limit would  
25 be five percent.

1           Our concern with this event is that you would have  
2 multiple rods, not a full bank, but not a single rod, but  
3 some combination of multiple rods withdrawing from the core,  
4 which potentially could create higher F delta Hs for peaking  
5 factors and also lead to more rods being below the DNBR  
6 limit.

7           [Slide.]

8           MR. JOHANSEN: We performed the dimensional full  
9 core calculation using our approved code system, Phoenix And  
10 and C, and devaluated different combinations of single,  
11 double, triple and quadruple rod withdrawal, either  
12 partially or fully, from the core at different power levels  
13 and from banks at the insertion limit and partial  
14 insertions.

15           We determined and we looked at two-loop, three-  
16 loop, and four-loop cores as part of our evaluation. We  
17 also considered the effect of different control rods. As  
18 part of our evaluation, we also considered the effect of  
19 different control rod patterns. What we determined was that  
20 the limiting results in terms of the greatest number of rods  
21 going into DNBR compared to the results of a single rod  
22 withdrawal event would occur from those control rod patterns  
23 of the nine-rod D bank where you would have the asymmetry,  
24 where you have D bank rods in relatively close proximity.

25           For plants where you would have a five-rod D bank,

1 the D bank rods are not close enough that if you withdrew  
2 two, you actually get some power flattening compared to the  
3 single rod withdrawal case.

4 So just to summarize, the limiting cases relative  
5 to single rod withdrawal at power event occurred with two or  
6 three adjacent D bank rods withdrawing from the core. We  
7 only found this to be more limiting for the three and the  
8 four-loop core that have the nine-rod D bank.

9 What we determined for the limiting case,  
10 comparing to the limiting single RCCA withdrawal, that we  
11 would have fewer than one percent additional rods below the  
12 DNBR limit value. The DNBR limit value is based on a 95-95  
13 criteria, the 1.3 or whatever DNBR correlation that plant is  
14 using.

15 So we took no credit for the conservatisms  
16 inherent in the DNBR correlation. In addition, we apply an  
17 eight percent uncertainty on top of our calculated peaking  
18 factors, consistent with our approved methodology.

19 Now, to put that increase, that one percent  
20 increase into perspective, we surveyed all our current core  
21 designs that we have the design responsibility for. The  
22 maximum percent of rods calculated to be below the DNBR  
23 limit value for the single rod withdrawal event was 1.5  
24 percent.

25 So I think with a high degree of confidence, we

1 could extrapolate and say that for the bounding type of  
2 value percent of rods below the DNBR limit for our current  
3 reload designs would be about 2.5 percent; again,  
4 significantly below our criteria of typically five percent.  
5 The conclusion is that little or no fuel damage would result  
6 because of the asymmetric rod withdrawal.

7 MR. THADANI: Are you going to talk about those  
8 cases and the time when you calculate the --

9 MR. JOHANSEN: Yes, I can talk about it. What we  
10 did was look at the core power distributions for the  
11 different cores analyzed and we selected the most limiting  
12 time in life in terms of the time when the power  
13 distribution for all rods or rod conditions was closest to  
14 the peaking factor limit.

15 Then we went through and selected the combinations  
16 of rods that would be in close proximity to give you the  
17 worst power distribution tilting. So we were -- let me show  
18 a figure.

19 [Slide.]

20 MR. JOHANSEN: This is a typical four-loop control  
21 rod pattern. In this case, we have nine D bank rods located  
22 here, here, here, center. Obviously, to get the worst  
23 peaking factors, we would want to withdraw rods that are in  
24 this vicinity of the D bank rods, and that's exactly what we  
25 did. We pulled combinations of D bank rods in combination

1 with C bank rods at the lower power levels. At full power,  
2 obviously it's just a D bank rod.

3 So we pulled combinations of this D bank rod with  
4 this one in combination with the center rod, in combination  
5 with this one, so on. What we found was that after you --  
6 once you begin pulling four or more rods, you got actually  
7 reduced peaking factors because you were flattening the core  
8 power distribution.

9 For this particular four-loop core, the limiting  
10 single rod withdrawal occurred when we pulled this one out,  
11 keeping the remaining D bank rods at their insertion limit.  
12 The worst multiple case occurred when we pulled these two  
13 adjacent D bank rods.

14 When we looked at another four-loop core that had  
15 the same control rod pattern, again, this was the most  
16 limiting single rod. The most limiting multiple occurred  
17 pulling this bank and this D bank.

18 [Slide.]

19 MR. JOHANSEN: Also, for a three-loop core -- I'm  
20 sorry. Here's a typical three-loop control rod pattern.  
21 Again, we pulled different combinations of rods, trying to  
22 come up with a configuration that gave the worst peaking  
23 factors and the largest percent of rods in DNB. The single  
24 RCCA withdrawal was this D bank pulling.

25 We found that three D bank rods pulling gave the

1 worst multiple asymmetry F delta H, and that consisted of  
2 these banks here.

3 [Slide.]

4 MR. JOHANSEN: Again, for the two-loop core,  
5 because of the way -- basically, because of the spacial  
6 separation of the D bank rods, you can see we don't have any  
7 D bank rods that are in close proximity. Once we pulled a  
8 second D bank rod, the core F delta H actually decreased and  
9 the percent of rods below the DNBR value was improved.

10 MR. THADANI: Can you tell me the timing issue?

11 MR. JOHANSEN: Yes. We looked at -- for the two  
12 and the three-loop cores, we picked the time in the cycle  
13 depletion where we had the minimum margin to the safety  
14 analysis peaking factor limit and picked that depletion step  
15 and began the multiple rod withdrawals.

16 For the four-loop cores, we looked at several  
17 times in life, both beginning of live and depending on the  
18 type of burnable absorber in the core, perhaps 4,000  
19 megawatt day might be the most limiting, because our  
20 burnable absorber, if it depends to deplete out at that  
21 point, and you get some power peaking.

22 We also looked at end of cycle. So end of cycle,  
23 you may have a flatter power distribution. It's not quite  
24 as peaked, but because you have a flatter power  
25 distribution, you may actually generate more rods in DNB,

1 even though your maximum power peak is a little bit lower.

2 So that effect was evaluated.

3 MR. THADANI: And for these cases, how long before  
4 you were calculating a certain number of rods going into  
5 DNB? Twenty seconds?

6 MR. JOHANSEN: The core response -- these  
7 represent static calculations. What we assume is that  
8 eventually we will get a trip on OT delta T. And the  
9 assumption is any rod above the safety analysis limit will  
10 go into DNBR, will be in DNBR. So depending on what the  
11 peaking factor of the F delta H limit is for the plant, 155  
12 or 165, any rod above that would be assumed to be in DNBR,  
13 conservatively assumed to be in DNBR.

14 MR. THADANI: What do you think in those cases the  
15 operator could do to prevent a rod from getting into DNBR?

16 MR. JOHANSEN: Well, I think the first indication  
17 would be that if he noticed the rods were moving at some  
18 point. At some point, he'd see that the rods were  
19 misaligned from the rest of the bank. So he will have that  
20 alarm.

21 MR. THADANI: Can I ask you again? How much --  
22 can you quantify --

23 MR. JOHANSEN: In terms of core response time to  
24 the point of DNBR.

25 MR. THADANI: Yes.

1 MR. JOHANSEN: That number I don't have, but  
2 that's a number that we could provide to you for these  
3 cores.

4 MR. THADANI: Yes. I would be interested.

5 MR. CHAFFIE: Do you know how far the rods have to  
6 be out of position before you have a problem?

7 MR. JOHANSEN: We assume very deep insertion  
8 limits. There are 170 steps. We actually did sensitivity  
9 on one plant; does this correlation between the percent of  
10 rods below the DNBR limit, how does that vary if you were to  
11 have a deeper insertion limit. What we found was the delta  
12 in percent of rods in DNBR for multiple versus single RCCA  
13 withdrawal, that held up as we went to deeper and deeper  
14 insertion limits.

15 So we looked at a 188-step insertion limit at full  
16 power and a 170-step insertion limit at full power. What I  
17 don't know is if you were parked at 170 steps, how much of a  
18 misalignment could you tolerate before you were in DNBR.  
19 But I think the other point is for the plants we surveyed,  
20 the maximum of all those plants in terms of percent of rods  
21 in DNBR for single rod withdrawal was only 1.5 percent.

22 For a large fraction of the core, the cores that  
23 we looked at, we predict no rods to be in DNBR and that's  
24 really a function of the fact that we have different thermal  
25 hydraulic analysis being performed for different plants.

1           Some plants are licensed and have used improved  
2 thermal hydraulic methods to predict -- to translate DNBR  
3 margins into higher peaking factors. If the plants aren't  
4 actually designed to those peaking factors, that's margin  
5 that you would have. So you could tolerate a higher  
6 withdrawal or misalignment before you would actually have  
7 rods in DNBR.

8           So that's very plant-specific. Some plants, we  
9 can go in and use a DNBR margin to demonstrate that no rods  
10 would be in DNBR. It really depends on what power level the  
11 plant's at and what type of peaking factors they're designed  
12 to.

13           MR. NEWTON: Ashok, what I think we're saying is  
14 that we didn't do a transient analysis of stepping the rod  
15 out and then seeing which catches you first. The over-  
16 temperature delta T trips you out before you get a power  
17 distribution, that puts rods in --

18           MR. RULAND: So that means that any effect on the  
19 set point you didn't factor in. Is that true? The OT delta  
20 T set point was not -- any effect that the rod misalignment  
21 would have on the OT delta T set point was factored in or  
22 not factored in?

23           MR. NEWTON: It's two different static cases, one  
24 with the rod in, all rods in at insertion limit, and then  
25 you take one or two rods out. You're simply looking at

1 power distribution for rods in DNB. You're not looking at  
2 the set point because you're not looking at that  
3 calculation.

4 MR. HEBERLE: Glenn Heberle, Westinghouse  
5 Transient Analysis. I think the question related to the  
6 effect on the over-temperature delta T set point of the rod  
7 misalignment.

8 The over-temperature delta T set point is taken  
9 from the process parameters of temperature and pressure, so  
10 forth, and there is one term in there that is affected by  
11 the power shape in the core. That's the F delta I penalty  
12 function. That would only act to reduce the set point and,  
13 therefore, make you reach it sooner.

14 So if anything, the rod misalignment would cause  
15 you to reach the set point faster than without the  
16 misalignment.

17 MR. RULAND: And that's regardless of the position  
18 of the rods.

19 MR. HEBERLE: Yes.

20 MR. JOHANSEN: Let me add to that. From the  
21 neutronics standpoint, the assumption is the plant is  
22 operating either through a load follow or at steady-state.  
23 But in normal operating mode, the plant would establish a  
24 target axial offset which they would maintain during the  
25 base load operation or during the load follow operation.

1           We conservatively assumed that they're operating  
2 outside that axial offset target band. So we conservatively  
3 skew the power distribution towards the top of the core,  
4 pushing the axial offset of power distribution outside the  
5 allowable axial offset band; therefore, actually  
6 contributing to the impact of the RCCA misalignment. So  
7 that's just a further conservatism that's supplied in the  
8 analysis.

9           MR. JONES: Just a clarification. When you said  
10 you went into DNB was when you exceeded the F delta H limit.

11          MR. JOHANSEN: The assumption -- the core --

12          MR. JONES: Or your minimum DNBR limit.

13          MR. JOHANSEN: The assumption on the set points is  
14 that any rod that is at the safety analysis F delta H limit  
15 will be at the point of DNBR or will have a DNBR of 1.3. So  
16 we say that any rod that has an F delta H greater than the  
17 safety analysis limit would be below the DNBR limit.

18          MR. JONES: That appears to be conservative.

19          MR. JOHANSEN: Right.

20          MR. JONES: On the other hand, you're obviously  
21 then not starting these analyses at conditions that your  
22 tech specs allow you to be at, correct?

23          MR. JOHANSEN: Correct.

24          MR. JONES: F delta H and other things.

25          MR. JOHANSEN: We start the assumption, the

1 initiating condition is that -- well, these really represent  
2 just a static calculation. This is where you're going to  
3 wind up after you have the misalignment. This is the  
4 peaking factor that you will find up with.

5 MR. NEWTON: But does the worst power distribution  
6 have the core limit peaking factor. It might be somewhere  
7 else in the core. Or are you looking at peaking factors  
8 that aggravates this portion of the core as your starting  
9 point? I think that's what you're saying.

10 You could be at your limit, but it might be  
11 somewhere else in the core and it would actually help you  
12 for this rod withdrawal.

13 MR. JOHANSEN: That's right. We're taking the  
14 worst set point combined with the worst power distribution,  
15 which could -- and the worst power level, which actually  
16 could come from different times.

17 MR. JONES: I thank you.

18 [Slide.]

19 MR. JOHANSEN: We have also examined asymmetric  
20 RCCA withdrawal from subcritical. The conclusion is that  
21 it's a multiple withdrawal, so it would bound the single  
22 RCCA withdrawal both from the standpoint of peaking factor  
23 based on the conclusions we determined from the full power  
24 event that two rods or three rods would lead to higher  
25 peaking factors than a single rod.

1           Also, the reactivity insertion associated with two  
2 or more rods going out would be greater than the single rod  
3 withdrawing.

4           For this event, the reactor is conservatively  
5 assumed to be at hot zero power with a core value of 1.0.  
6 So you're just critical with the shutdown bank's withdrawal  
7 from the core. The banks are assumed to be operating at  
8 normal overlap and can be in any position from fully  
9 inserted to up to their rod insertion limit.

10          Again, the failure mechanism is that you're in  
11 manual rod control. The operator gives a demand for a rod  
12 RCCA insertion, coupled with the postulated control system  
13 malfunction, RCCAs actually withdraw. Two or more RCCAs  
14 withdraw from any inserted bank.

15          And that could be -- if you're fully inserted, all  
16 banks fully inserted, that could be any rods coming from A  
17 bank. It could be from A plus B if A is partially inserted  
18 into the core, so forth, B plus C, C plus D.

19          Again, the concern with this event relative to  
20 what we currently analyze for most plant FSARs, the rod  
21 withdrawal from -- rod bank withdrawal from subcritical is  
22 that you may have higher peaking factors associated with an  
23 asymmetric withdrawal.

24          That, of course, would be offset by the fact that  
25 when you're only withdrawing two or three or four rods, the

1 reactivity insertion that you're adding to the core is going  
2 to be significantly less than what you obtained from bank  
3 withdrawal.

4 [Slide.]

5 MR. JOHANSEN: Let me first talk about some of the  
6 conservatisms that are in our current bank withdrawal  
7 analysis. The way we currently analyze it, we assume that  
8 the banks are withdrawing with one hundred percent overlap.  
9 That means A plus B bank are both pulling out the core at  
10 the same height.

11 What we're trying to do here is maximize a  
12 reactivity insertion rate, do a very conservative bounding  
13 type of analysis. We also assume that the rods are moving  
14 at a high rate of speed, typically 72 steps per second. We  
15 also in our evaluation of DNBR assume a very conservative  
16 bottom skewed power shape, a type of power shape that you  
17 would only see perhaps in a no xenon core for a first cycle.

18 You would not see that type of power shape in a  
19 reload core. So the implication of that is that it's a  
20 significant DNBR penalty when we actually go to do the DNB  
21 calculation.

22 We also use conservative radial power  
23 distributions. The concern here is that for the postulated  
24 asymmetric withdrawal, the  $F \Delta H$  could be higher than  
25 our typical generic radial  $F \Delta H$  assumed for the bank

1 withdrawal. So somehow we need to address that.

2 The first thing I think we can assume is that for  
3 the manual operation, the typical rod speed would be about  
4 48 steps per minute. If, for a worst case scenario, we  
5 postulate the operator, despite the training that he's  
6 received, despite the fact that he's getting a rod deviation  
7 alarm, allows the RCCA withdrawal to continue for a full  
8 minute with no action.

9 At that time, you would have the maximum  
10 misalignment of the 48 steps. This would provide -- would  
11 limit the amount of the F delta H perturbation compared to  
12 the symmetric bank withdrawal case. Also, because we're  
13 looking at a relatively low number of rods withdrawing and  
14 the fact that they withdraw and overlap, the reactivity  
15 insertion rate of this transient is very low.

16 We have calculated for a number of cores not to  
17 have greater than 15 pcm per second reactivity insertion  
18 rate. That compares to the 75 pcm per second we obtain for  
19 a generic RCCA bank withdrawal analysis.

20 And just to describe the core response for the  
21 bank withdrawal event, when you insert a high reactivity,  
22 core power increases very quickly. We eventually trip, but  
23 the trip doesn't occur fast enough that you get an overshoot  
24 in power level. And it's that maximum power level which  
25 could be significantly above the trip set point that we

1 analyze for DNBR.

2 Core response is calculated for the type of  
3 reactivity insertions that we're postulating for this event  
4 are showing much lower power levels. Basically, when you  
5 hit the trip set point, you will trip and you won't get the  
6 power overshoot.

7 Right off the bat, that provides a significant  
8 DNBR margin. Other areas of conservatism in our bank  
9 withdrawal analysis, we assume that in mode two, when you're  
10 critical, you will have only two of four pumps running for a  
11 four-loop core or one of two pumps running for a two-loop  
12 core, two or three pumps running for a three-loop core..

13 Point of fact. When you're in mode two, I think  
14 all tech specs require that you have all pumps running.  
15 Again, when you make that assumption and more better  
16 estimate type calculation, take credit for the fact that  
17 pumps actually will be running in mode two, you get a  
18 tremendous DNBR benefit.

19 Calculations for four-loop core indicate that that  
20 DNBR benefit is worth on the order of about 40 percent, not  
21 taking credit for the fact of using more realistic power  
22 shapes.

23 So I think we have several areas of conservatism  
24 in the analysis, the assumptions on the number of pumps  
25 running, the conservative bottom skewed power distribution,

1 the lower reactivity insertion rates associated with this  
2 event, that all lead us to the conclusion that the results  
3 of this analysis should be bounded. When we are able to go  
4 through a detailed analysis for two, three, and four-loop  
5 core, we'll be bounded by the results for the bank  
6 withdrawal.

7 At this point, we are comfortable in drawing the  
8 conclusion that we would have little or no fuel rods below  
9 the DNBR limit value. When our analysis is completed, we  
10 feel that we can demonstrate that there would be no rods in  
11 DNBR.

12 I think something else that needs to be mentioned,  
13 we've talked about it, is we are still working with methods  
14 that are 15 years old or 20 years old. We have new methods  
15 that are being developed, the 3-D space kinetics programs.

16 In fact, we did a benchmark calculation last year  
17 of the rod withdrawal from subcritical event -- this was  
18 bank withdrawal from subcritical event -- where we compared  
19 the core response for using -- for this event, using the  
20 current methods and their conservative assumptions compared  
21 to what you would obtain from a 3-D solution.

22 Using the current methods, we predicted about an  
23 eight percent DNBR margin for this four-loop core. When we  
24 went to the 3-D kinetics methods, the percent of DNBR margin  
25 increased from eight percent to 77 percent, which you could

1 translate directly into increased F delta H, which you could  
2 use to accommodate asymmetric RCCA withdrawal.

3 So I think looking down the road, with new  
4 analysis tools, you could probably say even if I permitted  
5 full withdrawal from the RCCA from subcritical, any  
6 subsequent peaking factor associated with that would be --  
7 we would be able to accommodate that using these types of  
8 methods.

9 Again, I think the bottom line conclusion is based  
10 on either current methods and revisiting the assumptions in  
11 those methods or going to more detailed methods, we can  
12 safely conclude that there is little or no fuel damage as a  
13 result of this event.

14 MR. THADANI: Are you planning to do that  
15 analysis?

16 MR. JOHANSEN: That is not really in our plans.  
17 What is in our plans in a short time period is to conclude  
18 our analyses using the current methods, improving our  
19 assumptions, and looking at the two, three and four loop  
20 cards.

21 MR. THADANI: I will come back to it when we talk  
22 about what the individual licensees are going to do. I  
23 think this would be an issue we would want to discuss.

24 MR. JOHANSEN: I think at this point Nancy Closky  
25 will give a discussion about the probabilistic assessment

1 that was performed.

2 [Slide.]

3 MS. CLOSKY: My name is Nancy Closky. I work in  
4 one of the probabilistic risk assessment groups at  
5 Westinghouse.

6 In the short period of time since the  
7 identification of this event, we have conducted initial  
8 review of the component failure located in the logic  
9 cabinets of the rod control system, using the available data  
10 sources that were available at the time, within the past few  
11 days, the nuclear plant reliability data system, the  
12 licensee event reports and nuclear power experience.

13 [Slide.]

14 MS. CLOSKY: Based on that initial review, we  
15 identified 34 logic cabinet component failures. When we  
16 broke those component failures down, we broke them down into  
17 what they -- what impact they had on the rod control system.  
18 Twenty-four of those events resulted in no rod movement, or  
19 no rod movement with an urgent alarm. Two of the events  
20 were step counter driver failures. One failure was a card  
21 failure that was identified subsequent to reactor trip, and  
22 was not identified and related to that with an MSSV trip.

23 MR. THADANI: Could I ask you a question? It's a  
24 general question. How much confidence do you have in this  
25 database, particularly, if you believe this represents the

1 total population of Westinghouse-designed plants?

2 MS. CLOSKY: Our initial review of these indicates  
3 that this is not a consistently reported type of failure.  
4 And that's why we have agreed to do the Westinghouse owners  
5 group survey to collect additional data.

6 MR. CALVO: Jose Calvo, NRR. If this event would  
7 have occurred at power, would the licensee of the utility  
8 have reported that to Westinghouse or to the NPRDS data? Is  
9 this event you have in the NPRDS -- this is an event that  
10 happened during maintenance or happened during power  
11 operations?

12 MS. CLOSKY: Most of the ones we have identified  
13 have been during power operation.

14 MR. CALVO: Power operation?

15 MS. CLOSKY: Yes. Some are due -- the LER ones  
16 are actually due to the failures during the tests, the  
17 monthly surveillance tests. Those are the ones that are  
18 reportable by the LER events.

19 MR. CHAFFEE: But, are these failures required to  
20 be reported in the NPRDS system?

21 MS. CLOSKY: No.

22 MR. JONES: Of the 24 no rod movement events, were  
23 you able to find anything dealing with the root cause to  
24 those failures? Were there chip failures that showed up on  
25 those, similar to what was seen in the Salem event, or were

1 they just 24 failures and you don't know the condition of  
2 the card?

3 MS. CLOSKY: We have identified just to the  
4 component level whether it was a slave cyclers or a buffer  
5 memory or supervisory memory card. That's as far as we have  
6 been able to determine. A lot of the data that's available  
7 currently does not go into the level of detail to say  
8 whether it's chip failures or not.

9 MR. JONES: Of the 24, how many would be slave  
10 cyclers?

11 MS. CLOSKY: I don't have that readily available;  
12 but, I have those identified.

13 MR. CHAFFEE: If some of the NPRDS data did  
14 identify chips, were you able to figure out if those were  
15 the chips that we were interested in?

16 MS. CLOSKY: In the time frame that we have been  
17 able to conduct this experiment, we have not been able to go  
18 into that level of detail. The nuclear power experience  
19 does give the best descriptions of most of the events which  
20 what exactly failed. Some of them are just faulty cards.  
21 That's why we are pursuing the additional data.

22 MR. JONES: I guess my reaction is it seems a  
23 little bit low, although I don't have a magic database.  
24 But, it seems to me that lately, in the last two to three  
25 years, there has been a large number of events that have

1 come to my attention dealing with problems with the rod  
2 control systems at various plants, generally PWRs, and a lot  
3 of the issues related to changing the technical  
4 specifications and the definition of operability, or  
5 interpretation of operability is related to only the trip  
6 function and not the movement within the normal rod control  
7 system -- that is, checking whether you can move the rod  
8 plus or minus a few steps was not necessarily considered to  
9 have an effect on the operability of the control rods so  
10 that you could still trip and, therefore, fulfill its safety  
11 function and ending up giving either additional time to  
12 repair or modifying the steps to give more time for repair  
13 of the cards so you could replace the cards in those  
14 circumstances. So, it appears to me there has been -- there  
15 has been some interaction on this over the last two or three  
16 years that seems to be high. I don't know how that may  
17 correlate. I will just point it out to you that you may  
18 want to look into that kind of experience. I don't have any  
19 numbers or even who. It has died down lately, but it may be  
20 because we changed several tech specs, and plants just  
21 stopped asking for them, since we have taken care of a bunch  
22 of them which were having problems, I don't know.

23 MR. RULAND: How do the numbers that you've found  
24 compared to the numbers and data found in the Brookhaven  
25 study that was performed?

1 MS. CLOSKY: Most of the data that we have  
2 included in the 34 covers those events. We have done a  
3 correlation between those. There are a few that, in their  
4 assessment, would fall into the power cabinet versus the  
5 logic cabinet. We are saying the logic cabinet is the one  
6 that could cause the rods to move.

7 We identified five failures that caused rod drop  
8 events and we identified two rod group misalignment events  
9 that had occurred previously to the Salem event. Let me  
10 reiterate that this was groups or banks that moved in those  
11 two events. Okay? It was not a single rod moving.

12 [Slide.]

13 MS. CLOSKY: Based on our initial review, we have  
14 not found a reported failure that has resulted in a single  
15 rod becoming misaligned, as with the Salem event. And,  
16 based on our preliminary calculations of the frequency of  
17 occurrence of this misalignment with the two events, plus  
18 the Salem event, we feel that it is a condition -- it falls  
19 into the Condition III frequency.

20 MR. THADANI: Let me ask you your opinion. Given  
21 that you said that you yourself have some questions whether  
22 you have good quality database, that you are still looking,  
23 would you question the words that says confirms that the  
24 event is a Condition III?

25 MS. CLOSKY: Well, based on the distribution that

1 we saw of the rod movements, okay, the number of rod jobs -  
2 - the number that actually caused no rod movement, okay, we  
3 are getting to a smaller subset each time. Okay? Based on  
4 our knowledge from the operating history side from the  
5 plants, we don't think that that's going to increase  
6 significantly.

7 MR. THADANI: I can understand that statement.  
8 But, you don't think it's going to go up significantly?  
9 But, to me, that's not the same thing as confirming that  
10 it's low.

11 MR. NEWTON: I think we will give you the numbers  
12 we have and we can make a judgment on that a little bit  
13 better. That's one of the items that we feel we do need to  
14 look at more carefully.

15 [Slide.]

16 MS. CLOSKY: Just to share the various types of  
17 events -- this didn't come out too well on the slide. We  
18 tried to correlate it with what we know at this point. So,  
19 we took the failures and distributed them over the time  
20 frames, the five-year time frames. The first block on each  
21 shows the number of failures within the given time periods.  
22 The other one is just to show how many plants --  
23 Westinghouse plants we had in commercial operation at those  
24 times. So, by the time you get up to 50 or 48 we have had a  
25 relatively minor amount of component logic failures from the

1 data that we have seen this far.

2 MR. CALVO: Excuse me. Have any of those failures  
3 that you have noted -- have those resulted in the reactor  
4 scram? Were those just failures that occurred at power, and  
5 fail -- it didn't -- these did not participate a reactor  
6 scram?

7 MS. CLOSKY: Most of the rod jobs would  
8 precipitate a reactor --

9 MR. CALVO: It precipitated it?

10 MS. CLOSKY: Most of them would. We don't have  
11 the data parceled out to say which would cause a trip.

12 MR. CALVO: I was wondering if you had a problem  
13 at power that it precipitated a reactor scram. Then when  
14 the trouble-shooting was done in the shutdown conditions,  
15 were there any failure that it would find out that the cause  
16 was a particular reactor scram? What I am saying is suppose  
17 you have got a control rod withdrawal that you don't want to  
18 see it at power, then the reactor -- the protection system -  
19 - the over delta T will catch it, will trip the reactor.  
20 Then you go down to zero to shutdown condition, you trouble-  
21 shoot the reactor control system. Would you then report  
22 that event -- that malfunction?

23 MR. NEWTON: Every reactor trip is reported. And  
24 certainly if a trip down and over -- you know, temperature  
25 delta T, that would significantly be reported. I think --

1 I'm not sure I heard what you said, but, for those cases  
2 where rods drop, they usually result in a reactor scram.  
3 For cases where the system just locks up, no, it does not  
4 usually result in a reactor trip.

5 MR. CALVO: Okay.

6 MR. NEWTON: Most of these cases are -- I am  
7 making a judgment on system lock-up versus dropped rods.

8 MR. CALVO: Okay.

9 MR. NEWTON: So, I think most of these cases did  
10 not result in reactor trip.

11 MR. WALSH: In Westinghouse plants there's such a  
12 thing as a negative insertion trip, and most plants that  
13 tripped on dropped rods got that negative insertion trip.

14 MR. CALVO: I guess I was just wondering -- those  
15 control rods that fail at power, any one of them show what  
16 kind of the problem was in the control rod system indicative  
17 of some of the problems that we are looking at on Salem?  
18 That was what I was getting at.

19 MR. NEWTON: Those are the things that we are  
20 going to have to look at more carefully to characterize it  
21 correctly. Was it a logic card -- and then look at their  
22 resultant repair on that to determine, indeed was it chips  
23 or was it something else that caused it to lock-up.

24 MR. CALVO: I am sorry to tell you, this data, it  
25 doesn't give me the kind of warm feeling that I can see that

1 you support your conclusions. That is all right.

2 [Slide.]

3 MS. CLOSKY: We also looked at the card failures -  
4 - the reported card failures by time of commercial  
5 operation. As you can see, most of those failures occurred  
6 within the first three years of commercial operation of  
7 plants and has remained relatively constant in the years  
8 after that.

9 [Slide.]

10 MS. CLOSKY: So, based on our initial reviews, we  
11 don't -- we do not feel that there is a correlation to the  
12 aging effect. But, we are giving consideration to  
13 collecting the additional data and revisiting this at that  
14 time.

15 MR. COLLINS: Your last bullet here says  
16 consideration is being given to the collection of additional  
17 data. I thought I had heard that that was something that  
18 you had decided to do already.

19 MS. CLOSKY: Yes, we have, but we haven't exactly  
20 figured out what type of data and what kind of form we want  
21 that data in.

22 MR. COLLINS: Okay.

23 MS. CLOSKY: Okay.

24 [Slide.]

25 MS. VERTES: I see a lot of smiling faces. Oh, we

1 reversed the order. I wanted to go through the safety  
2 assessment, based on the evaluations and analyses that you  
3 have heard about so far. I want to stress some of the  
4 things that Mr. Thadani had pointed out -- that the approach  
5 that we have taken has been conservative and consistent with  
6 the approved methods that we are currently using for design  
7 basis analyses. Given the time frame and the need to make a  
8 very quick assessment on the safety significance, that we  
9 felt was the most prudent approach to take, given that it  
10 would be the most easily defensible, and most easily  
11 understood or recognized, based on what the staff has  
12 already seen, in terms of Westinghouse methods for  
13 performing safety analyses.

14           Given those analyses, and our initial assessment  
15 on the probability of occurrence of this event, which is  
16 based on not only the probability data, but the  
17 detectability of the failure itself, and the operating  
18 history which indicates that this has never occurred, we  
19 feel that this is, when we are all said and done, going to  
20 be in the realm of probability of a Condition III event --  
21 that, if we were to use the conservative methods that we are  
22 currently using, that we would predict minimal or no actual  
23 fuel damage as a result. If we went to best estimate or 3-  
24 D spacial kinetics models, we would be within the Condition  
25 II acceptance criteria, and that, in addition, no challenge

1 to the integrity of the reactor coolant system or  
2 containment has been demonstrated as a result of the  
3 conservative methods that we have already used. And, as a  
4 result, there is no undue risk to the public health and  
5 safety. And, based on those conclusions, we feel that it's  
6 appropriate to have plants continue to operate or resume  
7 operation as currently scheduled.

8 MR. JONES: Let me ask a couple of questions,  
9 since this is kind of your wrap-up slide. I don't know  
10 where to ask these questions as they build up.

11 MS. VERTES: Okay.

12 MR. JONES: I am not sure you are the right person  
13 to ask them to, but I will ask them to you, and I am sure  
14 you will get your cohorts --

15 MS. VERTES: I will defer them.

16 MR. JONES: -- to pitch in.

17 MS. VERTES: Yes.

18 MR. JONES: Where I am coming from is one, is GDC-  
19 25 and the control systems in general, the rod control  
20 system. Now, it's my understanding the FMEA was done on the  
21 control system, is that correct?

22 MS. VERTES: Yes.

23 MR. JONES: What were you trying to accomplish, or  
24 what was the purpose of that FMEA, if not to show compliance  
25 with GDC-25?

1 MS. VERTES: I am not the appropriate person to  
2 answer that. I don't know whether that's Steve or Horum.

3 MR. JONES: Someone could answer me about it  
4 earlier.

5 MS. VERTES: Yes. Okay.

6 MR. FOWLER: I have a copy of it here. I will  
7 just read you the abstract as far as what it says the  
8 purpose was.

9 "By the use of a failure modes and effects  
10 analysis, it is shown that the full length rod control  
11 system will perform its reactivity control functions  
12 considering the loss of single active components."

13 MR. JONES: Okay. Very much like what is in the  
14 GDC. Does the Salem event raise any questions in your mind  
15 about the completeness of the FMEA done in the control  
16 system?

17 MS. VERTES: Steve?

18 MR. THADANI: Go ahead, Nick.

19 MR. LIPARULO: I think that's a very difficult  
20 question for us to answer at this time, Bob. I think, as we  
21 perform the evaluation of the event, as it continues, we  
22 will be able to give you a better answer to that question.

23 MR. JONES: Okay. Let me just continue it then.  
24 I know you can't answer it, but let me go through the rest  
25 of my line of thinking. It's my understand of the FMEA that

1 when you look at the FMEA, it was done in the very high  
2 level of the block level, and never considered the type of  
3 failures I think we are seeing in -- from the Salem event.  
4 At least, that is the preliminary understanding I have from  
5 the team and their feedback to us. I think that, in turn,  
6 raises some questions about the completeness of the FMEA  
7 done on this system and how that demonstrates or doesn't  
8 demonstrate compliance to GDC-25.

9 I think it also may raise some questions about  
10 some of your assumptions related to your safety assessment.  
11 If part of your assumptions are, while you are focused, and  
12 rightly so, I think on the specific failures that showed up  
13 from this event, if FMEA is incomplete, there may be other  
14 events and failure modes where things such as not having  
15 bank overlap may occur. I don't know whether that's true.  
16 I am not an I&C person, as I stated earlier. But, it  
17 appears to me the issue of completeness of the FMEA and  
18 those kinds of things come into play, whether all of your  
19 assumptions in these analyses are correct or not.

20 I will also wish to state, for the record, my  
21 opinion that when we developed GDC-25, way back in the late  
22 '60s, early '70s, that it was the staff's to not have any  
23 single failures in a rod control system for maneuvering  
24 allow fuel failures. And while you may be looking at  
25 changing that definition here, I would say that that is a

1 change in the licensing criteria and the GDC. That's my  
2 opinion.

3 MR. THADANI: Let's go ahead.

4 MS. VERTES: I would like to introduce -- well,  
5 bring back Roger Newton.

6 [Slide.]

7 MR. NEWTON: Chris had the task of summarizing the  
8 safety aspects of it, and then we have to kind of  
9 extrapolate that to system operability. And since system  
10 operability is utility call, they felt it was more  
11 appropriate that the owners group do that call versus  
12 Westinghouse. And, since we are used to doing that, I felt  
13 an obligation that we need to look at the system operability  
14 from what we have seen.

15 So, we are looking at the operability of the rod  
16 control system. We are saying that, through the tech specs  
17 requirements that we do, and we have the requirement for  
18 periodic testing to determine that the rods, you know, do  
19 move, which is a demonstration of operability of that, and  
20 that normal plant operation that we talked about, you know,  
21 being able to detect, you know, the failure faster than  
22 every 31 days or 30 days, that the system is detectable and  
23 maintained -- that those requirements result in the  
24 assessment or conclusion that their control system is  
25 operable. There's nothing there that we feel violates a

1 significant design aspect of the control system.

2           The protection system. We have talked about  
3 maintaining that. We all agree that that is not interfered  
4 with. So, it's just a question of now what do we say the  
5 control system state is? This is based upon the ability to  
6 detect and also the infrequent nature of what happened at  
7 Salem. It was the first of its kind after a lot of years of  
8 operation. We are going to go back and look at that more  
9 carefully determine -- sometimes things happen and we don't  
10 see all of what's happening there. So I think, if we go  
11 back and look at it more carefully, we will characterize  
12 whether this was the first of if there are a few more.

13           And it wouldn't surprise me if we found that there  
14 might have been a couple more. From the numbers we ran with  
15 the operability numbers, you know, Salem was one, to stay  
16 within the Condition III-type event, I think the numbers  
17 came out to be that you could have up to eight of a similar  
18 event where you felt that one rod was moving in the multiple  
19 direction, one or multiple rods was. So, from that  
20 standpoint we felt quite comfortable with the conclusion  
21 that we are making here.

22           MR. CHAFFEE: Is your review, in terms of looking  
23 for other examples, is that going to include Westinghouse  
24 plants outside of the U.S?

25           MR. NEWTON: It will not, no. Okay? On one of

1 these slides we put domestic up there to -- okay?

2 MR. THADANI: Let me make sure I understand what  
3 you just said. Each licensee is expected to make an  
4 operability determination. I assume they have done that.  
5 Guidance is given in Generic Letter 91-18. Certain  
6 statements are made in the FSAR, as well as in the  
7 safety evaluation reports. Can you tell me those licensees  
8 who have -- let me make an assumption. It's fairly clear in  
9 the record that a single failure in the control system  
10 should not lead to exceeding fuel design limits. How would  
11 you expect that licensee to make an operability  
12 determination?

13 MR. NEWTON: There are two aspects of that. We  
14 are summarizing what we have talked about here before. The  
15 failure at Salem, we are characterizing as a failure of the  
16 logic cards, which resulted in similar signals going to the  
17 rods that -- when they look at that, that same failure will  
18 result in a bank or sub-group moving. They will make the  
19 judgment that there is another mechanism or something there  
20 that did cause the Salem event to occur. Also, from the  
21 operating experience of the utility, from a frequency  
22 standpoint, with the data that we have tried to provide to  
23 add more information to them, we are taking it -- even if  
24 this does occur, how do you treat that? We tried to give  
25 them the bigger, broader picture in what information we

1 provided to them. So, I think, if they go back and look at  
2 the design of their system, they will be back to where we  
3 were -- that the bank or group of rods will move together,  
4 and they have been analyzed for that. At the Salem event  
5 something else happened, and it is very infrequent. And,  
6 when we look at that combination with infrequency, you know,  
7 it's beyond the operability call, or you look at how you  
8 analyze that from a risk standpoint.

9 MR. THADANI: I didn't completely follow that. I  
10 guess can you address the following? You don't have a  
11 quality database. You don't have a detailed failure modes  
12 and effects analysis. There may be other faults that could  
13 be of concern, not that there are. Until you have some high  
14 level of confidence that your database is fairly solid, and  
15 that you really do understand specific single faults or  
16 failures that might lead to these conditions, I don't know  
17 how you or I, with the conclusion you just did --

18 MR. NEWTON: I guess because, you know, as an  
19 operating utility, we have to make these calls all of the  
20 time with soft information. And, as of this time, there's  
21 not enough specific, firm information to say the system is  
22 not operable. Therefore, the call is not based on not  
23 having specific information that says the system will not  
24 perform as it is supposed to.

25 So, we are left with the operability call of the

1 information of the owner's group that we have been able to  
2 work with the industry. We have not found anything  
3 accounted to accept as conclusion at this time is what we  
4 are saying. So, asking us to make the call today -- we are  
5 still saying the systems are operable. But, it is a call  
6 the utilities have to make all the time.

7 MR. CALVO: I wonder if you were confronted with  
8 the event at Salem getting at the root of that particular  
9 event, in order to duplicate what happened with the event?  
10 It is an event that happened, but it seems like you were  
11 having difficulty trying to duplicate that event.

12 MR. NEWTON: That is correct.

13 MR. CALVO: You also indicated today that you had  
14 technical specifications that required some surveillance to  
15 be done at power. And that's one way that you would be  
16 confident that the rod moved as required, based on the  
17 surveillance theory. But, maybe those technical  
18 specifications -- the surveillance was prepared as a  
19 function of a failure mode and an externality that showed  
20 the weakness or what is important to the technical system.  
21 It can be may be in a more sophisticated technical  
22 specifications that will look for consideration of how fast  
23 you plan to insert, how fast you are going to withdraw the  
24 rods that may give you an indication there that maybe  
25 something was wrong with the system. Will that -- will the

1 failure mode and effects analysis show that sort -- an  
2 additional surveillance would be required or not or is that  
3 something that you will have to determine?

4 MR. NEWTON: That is obviously one of the things  
5 that, as our evaluation continues, we will look at more  
6 completely. As of right now though, the logics that we went  
7 through on what happens when you have these failures,  
8 confirms that the banks or groups of rods are getting the  
9 motion. What happened at Salem -- something else caused  
10 that set of rods to behave differently. I can postulate all  
11 sorts of things, and other people do too, but those are just  
12 postulations of things that could happen. I think the  
13 better test is the online demonstration that the rods are  
14 moving all of the time. And we test them at least every 30  
15 days. Some do it more frequently than that. It does  
16 demonstrate the system is operating. So, that's the basis  
17 of the operability call.

18 MR. JONES: Let me ask you a different question.  
19 Let me just follow it up a little bit. Your 30-day test on  
20 your surveillance is you move the rod a few steps in and  
21 out, which was to look for binding of the rods. What  
22 happens if you are unable to move a rod -- you go to run a  
23 test and the rod doesn't move? What is your call on  
24 operability at that point?

25 MR. WALSH: the call on operability is you -- if

1 it's not affecting the plant conditions right then and  
2 there, you put the control bank in a manual condition and  
3 call the instrument and control technician to try to  
4 describe what the problem really is.

5 MR. NEWTON: I think our call on operability would  
6 be, if we caught this before we caused the rod to be outside  
7 of the tech spec limit for rods out of position, we would  
8 halt that and probably still say the system is operability.  
9 I am just saying what I think our utility would do. Now,  
10 maybe other utilities can speak up, because I think we have  
11 had this happen before. We correct the problem. We realign  
12 the rods if indeed they were out. And, through this whole  
13 time, the system has been operable. The control system may  
14 not be able to do exactly what it is asking for, but the  
15 protection system and the rods in alignment, from a power  
16 distribution standpoint, have been maintained within their  
17 operability limits.

18 MR. JONES: If you do that, what data will you  
19 collect, assuming it is some sort of card failure? What  
20 follow-up would you do on that card failure to try to  
21 understand the specific failure mode of that card failure,  
22 to relate it as to whether or not that was a Salem-like  
23 condition in that card?

24 MR. NEWTON: This is one of the items that we are  
25 going to have to talk amongst the utility people as to how

1 they record it. In our plant, you know, we have a  
2 maintenance work request. Before they do anything, a  
3 maintenance work request is written. You know, it gets  
4 tagged that it is a rod control system. Then it goes down  
5 and they write exactly what they did in that, and we have a  
6 chance to go back in on the database and dig that out. Does  
7 everybody do it that way? I don't know. But, a piece of  
8 paper should be written for even the maintenance of that  
9 sort of thing. Those are the things that we will be able to  
10 go back in and look for because this would not have been a  
11 reportable event. Okay. So, I think we can significantly  
12 enhance the database by going back into those records. That  
13 is what we are thinking of doing and talking about how we do  
14 that.

15 MR. WALSH: What we want to do is create a survey,  
16 sending it to the industry, that is going to give us some  
17 benefit instead of a whole lot of data coming into us that  
18 doesn't really mean a lot.

19 MR. NEWTON: One thing we have talked amongst  
20 ourselves is that we are not interested in everything that  
21 happens when the unit is shut down during maintenance. For  
22 example, Salem had a lot of things happen that they did  
23 maintenance on and had failures. Well, those we are not  
24 likely to take forward into the operating environment. We  
25 are looking at things that occurred during the operating

1 environment, meaning, not maintenance, the system is going  
2 critical or at-power, or whatever. We will be looking at  
3 those events. Because we just don't want to be overwhelmed  
4 by normal maintenance that is done on the system and have to  
5 plough our way through that. So, we are going to be  
6 somewhat selective. But, we think the selection will be  
7 right. We haven't developed the criteria for that yet.  
8 That is something we will be working on.

9 MR. WALSH: I think that brings up a little bit of  
10 a point too. In the maintenance area, when you say failure,  
11 you have got to watch your terminology because, while  
12 testing and reaching and failure doesn't mean inoperable, it  
13 may mean that the card no longer meets the specifications  
14 for which it was originally designed, but it will still  
15 work, it just works with less tolerances than Westinghouse  
16 designed it for, and they want to refurbish it before it  
17 does go to full failure.

18 MR. NEWTON: Like instrument drift. Okay.

19 MR. VIRGILIO: Have you had an opportunity to go  
20 back and look at the Westinghouse Plants and bound the range  
21 of surveillance requirements that might be out there? I  
22 think we have been throwing around every 31 days, but, can  
23 you say with confidence all plants have that as a tech spec  
24 requirement?

25 MR. NEWTON: I am pretty sure I can say that with

1 confidence. I asked our people. We tested every two weeks.

2 MR. VIRGILIO: And what about operability  
3 requirements?

4 MR. NEWTON: Operability of this system is a  
5 judgment call, like I described to you.

6 MR. VIRGILIO: I realize that making the  
7 operability call involves some judgment. But, once you make  
8 a call and determine it is inoperable, then the first phrase  
9 of the first bullet there -- what are the requirements?  
10 What are the range of requirements that are out there?

11 MR. NEWTON: For the rod control system?

12 MR. VIRGILIO: Yes.

13 MR. WALSH: You have to go to your individual tech  
14 specs for your action statement.

15 MR. VIRGILIO: I realize that. Have you gone back  
16 and looked to see what the range of requirements might be?

17 MR. WALSH: Not in a great deal of detail. This  
18 is just a week old.

19 MR. NEWTON: We look at two parts of operability  
20 on this thing. Is the protection part of it operable or  
21 inoperable, which is a significant difference versus the  
22 control part. We have more flexibility with the control  
23 part being inoperable in time to repair it, versus the  
24 protection part. So, there's a couple of different calls on  
25 this system, because it does combine both control and

1 safety, you know, kind of in the same system. Although they  
2 are somewhat separate, they certainly are interrelated.

3 MR. VIRGILIO: Will your efforts result in a  
4 recommendation to the owners with regard to control system  
5 inoperability, as far as what actions are appropriate? I  
6 recognize this is just a week old. I am trying to see where  
7 you are going with this.

8 MR. NEWTON: I think it's premature to do anything  
9 beyond what they already do.

10 MR. VIRGILIO: Which varies?

11 MR. NEWTON: Which varies, yes.

12 MR. WALSH: I think the idea is we are trying to  
13 bolster our opinion as of today. And, if it is not  
14 bolstered, and it goes in the other direction, we have to  
15 investigate what avenues we need to take then.

16 MR. NEWTON: Right.

17 [Slide.]

18 MR. NEWTON: The other part I said we would get to  
19 eventually was to look at the five questions. And then from  
20 all of the information that is presented, what are the  
21 answers to the five questions -- and that was the  
22 applicability question. On this one, we did put domestic in  
23 -- how many plants could possibly be affected? The answer  
24 is that all domestic Westinghouse plants, except Connecticut  
25 Yankee, have a similar rod control system in principle. And

1 Westinghouse made the comment that the rod control system is  
2 one of the systems that have had the least modifications or  
3 evolutions over the years. So, we are quite similar on  
4 this. Yankee is the only one that has the old mechanical  
5 step-type countering system for signaling when each of the  
6 coils get its power. All of the rest have its solid state  
7 type system.

8 So, this was the easy one. I am assuming we have  
9 no disagreement on this.

10 [Slide.]

11 MR. NEWTON: Two and three we put on the same  
12 sheet just because they are interrelated. Question two asks  
13 are these plants susceptible to the single failure  
14 experienced at Salem, which results in uncontrolled rod  
15 withdrawal? It's kind of -- you know, do you hate your wife  
16 question. You don't know how to answer this with how it is  
17 worded. So, we tried to word it in a more positive way in  
18 our answer, okay?

19 MR. THADANI: I wrote that. I wouldn't ask an  
20 unfair question like that.

21 MR. NEWTON: Right. I know. Okay. It sounded  
22 like one of your questions by the way. We tried to answer  
23 that in a way that we think characterizes what you were  
24 looking for there. Since the plants have a similar rod  
25 control system --

1 MR. THADANI: Roger?

2 MR. NEWTON: Yes.

3 MR. THADANI: Which part? The uncontrolled part?  
4 When you say it sounded like Bob's question, what did you  
5 mean?

6 [Laughter.]

7 MR. NEWTON: Both parts, to tell you the truth.  
8 Okay? Since the first question, as I said, were similar,  
9 what happened there? Since we have similar rod control  
10 systems, we have the same susceptibility, relative to the  
11 control system itself.

12 The expected response to a single failure though  
13 is where we -- you know, the second part of it we have a  
14 problem with. We still feel that's the group where the bank  
15 withdrawal is the -- when you do your failure analysis, that  
16 is still what you come back to.

17 MR. CHAFFEE: Why do you believe it would be a  
18 bank that we would withdraw rather than a single rod? I  
19 mean, I know you said earlier that's because they are  
20 getting the same signal from the logic --

21 MR. NEWTON: Right.

22 MR. CHAFFEE: -- but, in Salem's case, one rod  
23 went out?

24 MR. NEWTON: Well, the other thing is that we have  
25 not seen it ever.

1 MR. CHAFFEE: Except at Salem.

2 MR. NEWTON: Right. That's one case in 600 years  
3 of operation. And, with the rods on the bottom at Salem --

4 MR. THADANI: I will keep coming back. When you  
5 say we have not seen it, I don't think you have looked hard  
6 enough.

7 MR. NEWTON: One of the things we are doing is we  
8 are going to look harder too, okay? We recognize that -- so  
9 we can answer your question with more assurity that we have  
10 looked harder.

11 MR. CHAFFEE: Part of the reason I ask is because  
12 I am wondering if you know something that we don't about how  
13 those signals are generated, such that it absolutely is  
14 clear that there has to be another failure mechanism. That  
15 is why I am asking. I am wondering -- because, what I have  
16 read so far, from what the people have said, it's -- there  
17 are a couple of things that people come up with to explain  
18 why the single failure caused the one rod. And I was  
19 curious if you knew something that refuted that.

20 MR. NEWTON: I think the case is demonstrated  
21 somewhat at Salem, when they took it to their training  
22 facility and simulated the card failures -- the rod did  
23 move, which was the normal, expected way. So, whenever we  
24 go to try to explain what happened there or duplicate it, we  
25 get our standard answer back, is what we have been getting

1 so far. So, there was something else that happened there.  
2 Whether it was corrosion or -- because they were on the  
3 bottom -- it takes more force to pull them out of the dash  
4 box, and if rods do stick, they tend to stick when you are  
5 pulling those out. At least that's what happens at our  
6 plant. So, there are other things that could have been  
7 going on, which when the rods are in the normal mode of  
8 operation, you know, it just doesn't exist, and we haven't  
9 seen it.

10 MR. CHAFFEE: I think there is a misunderstanding.  
11 I thought what they did at the training center was they were  
12 able to demonstrate what actually occurred in terms of a  
13 single rod motion after a period of time, in the undesired  
14 direction.

15 MR. CALVO: The feedback I got was that you tried  
16 four dashes before you started moving the rods. This is  
17 what our people tell us. So, actually, after you tried it  
18 and nothing happened, you went four times before you started  
19 moving. Is that right?

20 MR. LaBRUNA: It was an extensive series of tests  
21 before where we moved rods consistently, where they moved  
22 together on-demand. And there was one occasion -- and I  
23 might have to yield to one of our engineers that was present  
24 when some of the testing was going on -- where we did have,  
25 where the rods were fully in -- a couple of instances of a

1 misstep, and then the rods continued to withdraw together.  
2 We have two rods in simulation at our training center. And  
3 we are comparing the performance of one against the other.

4 MR. CALVO: Did you all find out the reason for  
5 that -- why, at this particular time you had that kind of  
6 failure?

7 MR. LaBRUNA: This is Dave Best from our  
8 Engineering Department.

9 MR. BEST: Good afternoon. Yes, we conducted a  
10 test out at the training center where we pulled steps out on  
11 these two mechanisms at the training center. In each and  
12 every case that we have pulled the rods, either we asked the  
13 rods to move out or the rod did step out. And there was  
14 only one case, and that rod was located on the bottom, but  
15 it's just on the floor here, there was no dashpot, where it  
16 missed the first three steps of a five-step request. It  
17 missed the first three, then ultimately it stepped the last  
18 two.

19 MR. CALVO: Was this all of the rods in the bank  
20 or only one out of all of the banks in the bank?

21 MR. BEST: Out at the training center we only had  
22 one rod in a bank.

23 MR. CALVO: I see.

24 MR. LaBRUNA: There are only two rods in  
25 simulation, where we have coil stats.

1 MR. CALVO: I see.

2 MR. LaBRUNA: There for trouble-shooting and  
3 training purposes.

4 MR. CHAFFEE: So, when you gave an insert command,  
5 the rods when in, and when you gave a withdrawal command,  
6 the rods went out?

7 MR. BEST: No. With the failures, when we  
8 requested it -- we first request, now we demand the rods  
9 when out.

10 MR. CHAFFEE: I see.

11 MR. BEST: When we request an inward demand, the  
12 rods went out, in every case except this one particular one.  
13 And we were not able to repeat that.

14 MR. RULAND: So, you would say is corrosion  
15 another failure? Is that what you are implying?

16 MR. NEWTON: We are not implying anything at this  
17 time, okay? We are saying that the expected behavior is as  
18 the group behavior, like we talked about. And something  
19 else happened there. And because we haven't seen this occur  
20 at plants, we are having a hard time explaining it. But, it  
21 isn't very frequent when we come down and look at it.

22 Now, the database needs to be looked at, and we  
23 agree with that -- that we need to do that more thoroughly.

24 MR. CALVO: Yes. But, Roger, plants like -- we  
25 are getting older. As you get older things shows up that

1 normally don't show up when you are young. I was just  
2 wondering, without knowing the reason for it, I think I kind  
3 of feel uncomfortable about it.

4 MR. CHAFFEE: One last comment. When they gave  
5 the insert demand at the simulator, did the rod immediately  
6 move out, or did it take some time before it started to move  
7 out?

8 MR. BEST: In every case it moved out.

9 MR. NEWTON: The answer to that question was that  
10 it immediately moved down in every case, except for the one  
11 exception that they ran into.

12 MR. BEST: We probably move the rod 50-60 steps,  
13 in increments. We probably asked for five steps out, and  
14 five steps in, and we probably did that 15-20 times. And,  
15 in every time, the rod moved out, except this one case.

16 MR. CHAFFEE: In the one case that it didn't move  
17 out, was that early in the test, late in the test?

18 MR. BEST: About 80 percent into the test.

19 MR. WALSH: I would just like to make a statement.  
20 I think it can be categorized that we looked at Salem event  
21 for information towards the generic aspect of this issue,  
22 and we did not do any detailed looking at Salem's event.  
23 So, I am not too sure that if you are going to continue down  
24 the road of asking a lot of things in Salem that the owner's  
25 group can give you any answers. That best be answered by

1 the utility.

2 MR. NEWTON: I think the point being is that Salem  
3 -- their investigation should not be contrary to the  
4 conclusions we are bringing. This fell into the envelope of  
5 what we are trying to say anyway.

6 The last sentence here deals with the other part.  
7 We do not believe that the rod withdrawal is uncontrolled,  
8 since the resulting rod motion is detectable. So, it's  
9 detectable in many forms. If it is manual, it is obviously  
10 not uncontrolled, the operator will stop it. If, for some  
11 reason, it was a demand signal on automatic, you would be  
12 getting alarms, or an operator would pay attention to it.  
13 So, we feel it is detectable. So, we think we answered it  
14 in a positive way as best as we could.

15 Question three is somewhat related to it. What  
16 are the consequences of rod withdrawals caused by such  
17 failures? Is there a potential or common cause failures  
18 which can cause multiple rod withdrawals because of this  
19 system?

20 The RCCA bank withdrawal is a Condition II event  
21 and is analyzed in current plant FSARs, with the result  
22 being no predicted occurrence of DNB. That's pretty well-  
23 established. The single, or asymmetric rod withdrawals are  
24 treated as a Condition III event, and only a small fraction  
25 of the rods, less than five percent, like we have talked

1 about, are predicted to experience DNB. This, we feel,  
2 meets the acceptance criteria for a Condition III event. We  
3 are dependent upon the failure frequency. We just haven't  
4 seen that. That is important to our overall assessment of  
5 safety.

6 We then get into the common cause failure thing.  
7 To date, and this is a generalization, but either at Salem  
8 or at other plants, no common cause failures have been  
9 identified. This also is part of things that we are  
10 continuing to look at. But, we felt we needed to make a  
11 call of where we were on these questions right now.

12 [Slide.]

13 MR. NEWTON: In question four, what interim  
14 actions or operating restrictions are necessary to ensure  
15 the plants remain within their design basis, again, this was  
16 a cleverly-worded question here. We feel the plants are  
17 operating within their design basis now, but we did make  
18 recommendations, you know, provided in this Westinghouse  
19 Letter 93-007, that emphasized that attention be given to  
20 specific routine operating practices, to assure that the  
21 practices they have now maintain the reliability and are  
22 also aware of this new possibility that they may not have  
23 thought of before. So, their sensitivity to it is raised.

24 And we asked the question amongst ourselves, you  
25 know, we always talk about an operator, when he goes

1 critical, he is withdrawing rods. But, if he decided to  
2 shut the plant down and drives rods in, is his attention  
3 level as acute as when he was going critical? If he drives  
4 it in, the rod starts coming out. Is he paying the same  
5 level of attention? We felt that he would. His awareness  
6 going in might not be as acute, but, from the standpoint of  
7 his training of confirming motion and so on, we feel  
8 confident that, indeed, the awareness would be there. But,  
9 with the knowledge that this could happen, the operator will  
10 give just that much more attention to withdrawals and  
11 insertions, making sure he always confirms what's going on.  
12 I think that is an important fact that, you know, the  
13 operators become aware of this possibility, as remote as it  
14 is, such that they are not surprised by it, and they are  
15 paying attention to it.

16 So, we feel that the design basis, you know,  
17 currently is being operated within and we just are paying  
18 attention to those items that assure that he doesn't even  
19 approach anything that -- I don't want to say would exceed  
20 the design limit, because I don't think we are approaching  
21 that, but, that he just operates the plant as safe as  
22 possible.

23 MR. CALVO: Roger, let me just ask you a question.  
24 What will happen if I am at a hundred percent power, and I  
25 am in low follow, I have got the control rod drive system in

1 automatic, and all of a sudden the automatic system moves  
2 the rod 20 steps and nothing happens? What happens to the  
3 automatic system? What kinds of information do you provide  
4 to the operator that the rods are not behaving as they are  
5 supposed to behave?

6 MR. NEWTON: If the demand was to move it 20  
7 systems --

8 MR. CALVO: That's right, 20 steps.

9 MR. NEWTON: -- and it didn't happen --

10 MR. CALVO: Right.

11 MR. NEWTON: -- you know -- if it actually did  
12 happen when it wasn't supposed to, something is going to  
13 happen to the plant. There is going to be a mismatch on  
14 actual load. But, say, for some reason, it went 20 steps,  
15 but it actually didn't -- is that what you are proposing?

16 MR. CALVO: Yes. Will the control -- will the --  
17 the automatic system will control -- give it another 20, in  
18 view of the fact that he didn't get what he wanted?

19 MR. NEWTON: I think we are mixing apples. At  
20 full power, if the control system actually moves the rods,  
21 and there is not a change made on the demand side, the  
22 turbine side, he is going to be driving power, mismatched,  
23 the temperature is going to start wandering up or wandering  
24 down on him. He is soon going to be getting a deviation  
25 alarm on temperature that his control system is not

1 controlling it properly.

2 MR. CALVO: Yes. But, I am going through the  
3 mechanics to issue demands to move the rods. The rods are  
4 not moving -- use of the demand signal is there. The rods  
5 are not responding, right? So, things are going to get out  
6 of whack. Then all of a sudden I am going to come down with  
7 the signal. So, I am creating the same situation that  
8 happened on Salem.

9 MR. NEWTON: Right.

10 MR. CALVO: The question is what kind of  
11 information do you have in the automatic system to say don't  
12 do no more, because you are not going to accomplish what you  
13 want, or what information is presented to the operator, in  
14 view of alarm or other things, for him to say, take it out  
15 of the automatic, let's put it manual?

16 MR. NEWTON: Right. For example, in automatic  
17 mode, the demand position light, up or down, comes on in  
18 automatic. So, that, if for the demand, the light says, I  
19 need to go in, and he is looking at rods, and they actually  
20 go out, you know, right away you know he has a problem with  
21 it.

22 MR. CALVO: But, he is looking at it. Is anything  
23 else -- like an alarm or anything else that will come up  
24 under those conditions?

25 MR. NEWTON: Since that is an unstable condition,

1 with respect to the control system, he will soon be driving  
2 the rods in the wrong direction from the control system  
3 demand, and temperature immediately is going to be out of  
4 the controllable band. He will get an alarm that the  
5 control system is not controlling temperature within the  
6 allowable band. That is the first alarm. If there are any  
7 other operators, that is the first one he would probably  
8 hear.

9 MR. CALVO: But, in the mean time, I am still in  
10 discrepancies between the demand signal where the control  
11 rods are, right? There I have a deviation there that I have  
12 not made anybody aware of it.

13 MR. NEWTON: Well, the demand signal is always on  
14 T-average. You don't put a demand on position. So, the  
15 control system runs off of T-average. So, if demand said I  
16 should decrease T-average, that means put rods in. But,  
17 really, if control systems put them in, but they go out,  
18 that's going to cause temperature to go higher, and you are  
19 going to be farther away from your demand signal, and you  
20 are going to get an alarm saying that it's not working  
21 right.

22 MR. WALSH: You have a two-degree difference of T-  
23 average, versus T-reference, which is the temperature you  
24 should be at. That is your first alarm that would get you  
25 in temperature space.

1 MR. NEWTON: Right. Normally, if the control  
2 system is behaving itself, there is a degree and a half  
3 difference there, and that the system operates nicely --  
4 that it controls within a degree and a half. If you wander  
5 out of that, it is two degrees, and it doesn't take long,  
6 you will get this first alarm.

7 MR. CALVO: It never goes to automatic?

8 MR. NEWTON: No. The operator would have to  
9 change it to manual. It's the only way it could happen.

10 [Slide.]

11 MR. NEWTON: The last question dealt with what  
12 long-term actions are contemplated to resolve this issue?  
13 We have the evaluation that we are working on. We have  
14 committed to ourselves to collect data on the operating  
15 events and continue to interact with the NRC during this  
16 evaluation period. The immediate -- I think -- commitment  
17 we have only made is to look at the database and indeed get  
18 a better feel for what has happened out there. That will  
19 then cause us to react differently, if the results come back  
20 different. If it confirms what we think, I think our story  
21 will hang together from what we described here, and we will  
22 stay with that story.

23 Our expectation is that -- and we are basing it on  
24 our own judgment of 25 years of experience of just not  
25 running into this -- that it will indeed confirm what we

1 have already made a claim to.

2 Now, you made a statement that you feel  
3 uncomfortable with the failures that have occurred in the  
4 rod system from the data that was presented here. I think  
5 we are going to come back with a lot more and I am going to  
6 use the word failures, when there are really operating  
7 indications of a failure that we get on a rod control  
8 system. We get quite a few of those. We get quite a few  
9 non-urgent alarms and urgent alarms that, you know, they  
10 have to respond to. That is not an unusual occurrence.  
11 Many times there is not a real failure there, re-set or  
12 whatever it is, takes care of it.

13 Many times we end up replacing cards just because  
14 we find that that is an easier way of trouble-shooting a  
15 problem. And, in some cases, we may not identify the root  
16 cause. Other times, we may be able to do that. But, this  
17 control system is a complex system with, you know, thousand  
18 of dials probably in the system. I don't know the number.  
19 And it is sensitive to -- I don't want to say failure -- but  
20 having system detect things that are not normal and that we  
21 have to respond to.

22 MR. CALVO: Keep in mind on salem, as a result of  
23 all this trouble-shooting, to keep in mind that it led to an  
24 event that we can't explain today. So, as you take it into  
25 account, and you put new cards in, mistakes are made. And,

1 when making the mistakes at power, it can be more damaging  
2 than doing it at a condition where you have less reactivity  
3 in the core. So, I mean, if you say that it is a lot of  
4 challenge, a lot of failures that happen at power, it is a  
5 matter of replacing this card, keep in mind what happened at  
6 Salem was as a result of doing that kind of a thing. And I  
7 just want to be sure that you are all prepared to preclude  
8 what happened at Salem at all of these other plants that are  
9 operating.

10 MR. NEWTON: One of the things too, that the rod  
11 control system, because it's what the operators are having  
12 to live with every minute of every day, when they put the  
13 system back in service, they do pretty good post-maintenance  
14 testing on running the cards and the systems through the  
15 diagnostics. So, that when you are at power and you put  
16 this thing back on line, you have demonstrated at least why  
17 you took it off as fixed, and you are not left with a  
18 residual problem. Okay? You have moved your rods, you have  
19 tested your cards, whatever it is. So, the post maintenance  
20 testing is pretty good when it is put back in service.

21 MR. LIPARULO: One conclusion you reached was that  
22 the maintenance on Salem caused the event. I don't think we  
23 have reached that conclusion. You made a statement that -

24 -

25 MR. CALVO: I know what you are saying. Maybe I

1 am jumping ahead. In view of the fact that we never got to  
2 the root cause yet, we cannot duplicate it, you have got to  
3 blame somebody. If you don't blame the trouble-shooting,  
4 then you blame the aging or degradation. That has more  
5 severe consequences than that.

6 MR. LIPARULO: The only point I am trying to make  
7 is that that hasn't been --

8 MR. CALVO: It's like you say. Until I find out  
9 more about it, I am going to blame it.

10 MR. THADANI: Okay. This is the part we are all  
11 waiting for.

12 [Slide.]

13 MR. NEWTON: We have featured actions. We are now  
14 and we will continue to update the NRC on the status. This  
15 week we are having a full owners group meeting. So, from a  
16 timing standpoint, we plan to take pretty much the material  
17 we had here and update our owners, and all of the rest of  
18 the utilities to fill in the gaps that may surround the  
19 information we sent them.

20 I guess I would like to leave this meeting with a  
21 feeling of where we stand on answering your questions. I  
22 hope we have answered a good fraction of them. I am not  
23 sure we answered all of them to your satisfaction.

24 We are continuing to participate in the evaluation  
25 of the root cause determination of the event. That is an

1 ongoing evaluation. So, we are following that. We are not  
2 doing it. It is between Salem and Westinghouse. But, from  
3 an owners group standpoint, we are hopefully plugged in very  
4 close to that, because that is important to us.

5 The results of this effort. You know, we think  
6 somewhere in the August time frame, as well as -- we will  
7 have data on the performance history to come back and talk  
8 to you about it, but I hope that we have left you with the  
9 warm feeling that -- from the operability standpoint, we  
10 have just the system -- the operability. From a GDC-25  
11 standpoint, we at least have our logic that we feel we are  
12 in compliance with that. So, from all of the aspects that  
13 involve the operating and startup of our plants, we think we  
14 have addressed them. We are continuing to look at it. And  
15 it is our judgment right now that we are hoping to further  
16 confirm these judgments. If that is not the case, we will  
17 tell you what we do find out too because it is important to  
18 all of us.

19 MR. THADANI: We certainly want to thank you. I  
20 know this has been hectic for you. It is clear you have  
21 been working very hard on this thing. You have done a lot  
22 of very good work actually. Obviously there were some  
23 important elements to what you are saying. First and  
24 foremost is that all of the automatic safety systems  
25 performed their functions properly -- that, if this failure

1 were to occur, although a small number of rods would go into  
2 DNB and that, if you were to do a really good realistic  
3 analysis, maybe none would. I think that is what I heard  
4 you say -- and that not all rod withdrawal events would get  
5 you into potential for DNB conditions. I think, in my mind,  
6 those stick out as being important factors which probably  
7 confirm the view that, at least given the information we  
8 have today, it is not an issue that requires huge  
9 precipitous type of action from a public health and safety  
10 point of view.

11 On the other hand, I think we are going to have to  
12 think about what you said. I don't think you have  
13 demonstrated compliance. I also don't think you have made a  
14 strong case that this type of Condition III event -- there  
15 are so many questions that I am not sure that's necessarily  
16 the concern -- so many questions about the database, the  
17 quality of the information available.

18 So, it seems to me -- I think we made the right  
19 decision to wait until we heard this story from you, so to  
20 speak, your analysis and the results of your analyses. We  
21 are going to carefully consider what you have said before we  
22 take our next action. We will continue to work with you.  
23 We may want to go forward and acquire certain information  
24 from licensees, as to their bases for concluding that they  
25 are in compliance with GDC-25, B, that they have met the

1 requirements -- and more specifically -- and finally, when  
2 they come back with their decision. Some of those we can  
3 deal with generically. I suspect many of them you can't,  
4 given what we have heard today.

5 So, our next step is going to be to kind of gather  
6 amongst ourselves and make sure we collect our notes and  
7 thoughts on what we have heard before we take our action. I  
8 will commit to let you know what that action would be as  
9 soon as we make that decision.

10 MR. WALSH: We appreciate the opportunity to be  
11 able to come in and have the time to sit down and explain  
12 the full breadth of this. It is an interesting and  
13 complicated issue that we are dealing with here.

14 We have a lot of work to do, and I hope we have  
15 given you the impression that we are going to try to  
16 continue to do it in a straight-forward and factual manner,  
17 so that we base our ultimate conclusions on as much  
18 information as we can obtain.

19 I would like to react to your comment on asking  
20 individual licensees on when they are going resolve this  
21 issue. It will be very difficult for them, since they  
22 haven't had the problem. So, they have a hard time  
23 resolving something you don't have. I think they are going  
24 to come back to the owners group and try to do it on a  
25 generic basis. So, I hope the owners group can provide that

1 to the Westinghouse members, because it will be difficult  
2 for them to do that individually.

3 MR. THADANI: Yes. We would clearly ask them for  
4 their schedule. But, I guess the part that is -- that needs  
5 to be thought through a little bit more carefully is the  
6 issue of GDC-25 and, as I think one of your presenters read  
7 the statement -- that there are different -- fairly  
8 different statements in different safety analysis reports.  
9 I imagine that can only be done on a plant-specific basis.  
10 That's how I understood the comment that was made earlier.

11 MR. WALSH: When you see the answer that we gave  
12 you was that we feel that everybody but maybe Connecticut  
13 Yankee has the same control systems. We feel this is truly  
14 a generic question. We would like the opportunity to know  
15 the questions you are going to ask the utilities, to maybe  
16 give you an answer that WOG would like to have, versus  
17 getting an opinion of 50 different reactor sites on what the  
18 question really is.

19 MR. THADANI: Our concern is, and the question, by  
20 the way, that you said it was cleverly worded, it was not  
21 cleverly worded, that was real. Our concern was and is do  
22 the plants comply with GDC-25? You said yes. The letter  
23 that went to the individual licensees says potentially they  
24 don't comply. I don't know what your real views are on the  
25 issue. We really need to debate this amongst ourselves to

1 come to some consensus. But you have not made a compelling  
2 case, at least, that I can say.

3 MR. NEWTON: After you have thought about this, we  
4 would like to know what your concerns are, so that we can  
5 address them. Because it will be hard for an individual  
6 licensee to address them. So, we want to be given that  
7 opportunity as a owners group.

8 MR. THADANI: My concern is why we think that the  
9 licensees are not in compliance. The licensees need to know  
10 that. The licensees need to be taking some actions, whether  
11 there are some actions that you are recommending or  
12 something else, I don't know. But, they need to determine  
13 what they need to do.

14 MR. NEWTON: That is correct.

15 MR. COLLINS: Before we close, I would like to ask  
16 if there are any members of the public who wanted to make a  
17 statement for the record before we close out the transcript?  
18 Is there anybody there? Would you raise your hand if you  
19 would like to come up and make a statement?

20 [No response.]

21 MR. COLLINS: All right. I see no one wishes to  
22 make a statement from the public then.

23 I believe we can adjourn this meeting.

24 [Whereupon, at 5:01 p.m., the above-entitled  
25 meeting was adjourned.]

**REPORTER'S CERTIFICATE**

**This is to certify that the attached proceedings  
before the United States Nuclear Regulatory  
Commission  
in the matter of:**

**NAME OF PROCEEDING:** Generic Assessment of Salem Event

**DOCKET NUMBER:**

**PLACE OF PROCEEDING:** Bethesda, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

*Maurice Estep*  
\_\_\_\_\_  
Official Reporter  
Ann Riley & Associates, Ltd.

**GENERIC ASSESSMENT OF**

**THE SALEM EVENT**

**NRC PRESENTATION**

**JUNE 14, 1993**

## INTRODUCTION

### PURPOSE

- Meeting at NRC's Request

### OBJECTIVE

- To provide an open forum in which to discuss the issues surrounding the Rod Control System Event.
- To update the NRC on the latest status of the W/WOG evaluations of this issue.
- To address NRC questions with respect to plant safety and operability.
- To outline W/WOG future actions.

AGENDA

- **Overview and Status** (WOG/W)
  - **Objective Meeting** Newton
  - **Agenda Review** Newton
  - **Status** Newton
  - **WDG RRG Activity** Newton
- **Background** Liparulo
  - **Overview of the Rod Control System** Fowler
  - **Description of the Salem Event** Carrier
  - **Failure Analysis** Fowler

**GENERIC ASSESSMENT OF SALEM EVENT**

● **Westinghouse Technical Evaluation**

- **Regulatory Bases** Lang
- **Classification of Postulated Events** Vertes
- **Analysis of Postulated Events** Johansen
- **Equipment Performance History** Closky
- **Safety Assessment** Vertes

● **Operability Assessment** Newton

● **Action Plan** Newton

## STATUS

- The Salem plant-specific evaluation is underway.
- Westinghouse and the WOG are continuing to evaluate the generic aspects of the event.
- The Westinghouse Reasonable Assurance of Safe Operation (RASO) adequately addresses concerns regarding plant operability and the health and safety of the public.
- All plants should continue operation and/or start up.

GENERIC ASSESSMENT OF SALEM EVENT

## WOG RRG ACTUATION

<b>Mon.</b>	PM	<u>W</u> Notify WOG Chairman of Event at Salem Details Limited
<b>Tues.</b>	AM	A. Thadani Request WOG Chairman that RRG be Activated  5 Questions Faxed to WOG Chairman (RRG Chairman Unavailable)
<b>Wed.</b>	AM	WOG Chairman RRG Vice President Hold Event Review Meeting  AM - Telecon with RRG Chairman and Other Members
<b>Thurs.</b>	AM	RRG Officially Activated First Full RRG Briefing and Responses. WOG Chairman and WOG Vice Chairman <sup>1</sup> at <u>W</u> for Review and Evaluation
	PM	Conference Call with NRC, WOG, <u>W</u> and Salem Site Reps Discussion of Rod Control System - Safety Evaluation - Event Probability. Fax NRC <u>W</u> Draft Customer Advisory Letter ~ 1:00 a.m.

---

<sup>1</sup>OG Chairman is a member of RRG also

**GENERIC ASSESSMENT OF SALEM EVENT**

**WOG RRG ACTUATION**

6/11

**AM**

2nd RRG Conference Call Review and Evaluation W Customer Advisory Letter

**PM**

Conference Call with NRC, WOG, W, and Salem Site Reps Discussing Advisory Letter and Monday 6/14 Meeting Agenda

## ROD CONTROL SYSTEM OVERVIEW


The Rod Control System positions rods in response to demands for motion from either the Reactor Operator or the Reactor Control System.

The Rod Control System is a Non-Class 1E system.


### System Description:

- Control Rod Drive Mechanism (CRDM):
  - Normal withdrawal sequence
  - Normal insert sequence
  - Response to reactor trip
- Control rod arrangement:
  - Rod banks, shutdown and control
  - Rod groups
  - Control bank overlap
- Rod Control System cabinets
- Slave cycler description

# FIGURE 1 CONTROL ROD DRIVE MECHANISM




# FIGURE 2 CONTROL ROD ARRANGEMENT




Shutdown		Banks	
S <sub>A</sub>		8 Rods	
S <sub>B</sub>		8	
S <sub>C</sub>		4	
S <sub>D</sub>		4	
S <sub>E</sub>		4	
Control		Banks	
A		4 Rods	
B		8	
C		8	
D		5	

GENERIC ASSESSMENT OF SALEM EVENT

FIGURE 3  
BANK OVERLAP



# FIGURE 4 ROD CONTROL SYSTEM BLOCK DIAGRAM



## ROD CONTROL SYSTEM OVERVIEW

### System Operation from Startup to Full Power:

- Startup tests
- Individual bank operation
- Manual operation with bank overlap
- Automatic operation:
  - Response to changing  $T_{avg}$
  - Response to changing load
- Operator interaction
- Rod Motion Surveillance Tests

### Rod Control System response to a reactor trip:

- AC power removed from Power Cabinets
- Current removed from CRDMs
- CRDMs release rods

A reactor trip signal overrides all Rod Control System signals.

# ROD CONTROL SYSTEM INDICATIONS AND ALARMS

## **Rod Position and Movement Indications:**

- Individual Rod Position Indication (IRPI)
- Group step counters
- IN/OUT demand lights
- Rod Insertion Limit (RIL) recorder
- Rod Bottom lights

## **Alarms:**

- Rod Control Urgent Alarm
- Rod Control Nonurgent Alarm
- Rod Deviation Alarm
- Rod Insertion Limit Alarms
- Rod Bottom Alarm
- Control Bank D Withdrawal Alarm

## DESCRIPTION OF SALEM EVENT

~~The Reactor~~ Operator demanded outward motion of shutdown bank A:

- ~~SBA~~ step counters read 20 steps
- ~~No rod~~ movement observed on IRPI

~~The Reactor~~ Operator demanded in motion of shutdown bank A:

- ~~With~~ step counters at 6, 1SA3 indicated 8 steps
- ~~With~~ step counters at 0, 1SA3 indicated 15 steps
- ~~All ot~~her rods indicated 0 steps

~~Rod Position~~ indication was verified by voltage checks.

~~1SA3 stat~~ionary gripper fuse was pulled to insert rod.

~~Lift coil dis~~connects were opened to prevent rod movement

~~Recordings~~ were made of Shutdown Bank A current orders.

~~Distorted~~ wave forms were identified.

~~Two circuit~~ board failures were identified.

The technical investigation is continuing.

GENERIC ASSESSMENT OF SALEM EVENT

# FAILURE ANALYSIS

Two circuit failures were located in the Logic Cabinet slave cyclers.

The effect on the slave cycler current orders, both singly and in combination, would have the following effects:

FAILURE	IN ONLY		OUT ONLY		BOTH (SALEM)	
	IN	OUT	IN	OUT	IN	OUT
<del>DEMAND</del>						
<del>MOTION DEMAND</del>	IN (NORMAL)	NONE OR OUT	NONE OR OUT	OUT (NORMAL)	NONE OR OUT	NONE OR OUT

## CONCLUSIONS:

- Slave cycler current orders sent to all CRDMs in rod group
- CRDMs may respond with outward motion
- CRDMs cannot respond with inward motion
- Rods cannot move in both directions simultaneously
- The failure cannot create a motion demand
- The failure has no effect on bank overlap
- The failure CANNOT prevent a reactor trip

# ACCIDENT ANALYSIS CONSIDERATIONS

- **REGULATORY BASES**
- **CLASSIFICATION OF POSTULATED  
EVENTS**
- **ANALYSIS OF POSTULATED  
EVENTS**
  - LIMITING SCENARIOS
  - ASSUMPTIONS
  - RESULTS

# CONCLUSIONS

- Random failures in control systems are not assumed nor required to be assumed concurrent with an Anticipated Operational Occurrence (AOO) or Design Basis Accident (DBA)
- Consequences of postulated failure(s) in the rod control system do not exceed radiological release acceptance criteria established for ANS Condition III events (Infrequent Faults)
- All plants should continue operation and/or start up.

GENERIC ASSESSMENT OF SALEM EVENT

CURRENT REGULATORY BASES

- ~~IEEE~~-279
- ~~IEEE~~-379
- NUREG-0800 (SRP)

# IEEE 279-1971

## Section 4.2 Single Failure

"Any single failure within the protection system shall not prevent proper protective action at the system level when required."

# IEEE 379-1977

## Single Failure Criterion for Nuclear Power Generating Station Class 1E Systems

"The protection system shall be capable of performing the protective actions required to accomplish a protective function in the presence of any single detectable failure within the system concurrent with all identifiable but nondetectable failures, all failures occurring as a result of the single failure, and all failures which would be caused by the design basis event requiring the protective function."

### Nondetectable Failures

" ... A failure which cannot be detected by specific system tests is nondetectable."

" ... In the analysis of the effect of each single failure, all identified nondetectable failures shall be assumed to occur."

# NUREG-0800 STANDARD REVIEW PLAN

## ~~EXCERPTS~~ FROM SRP SECTION 15.2.7

~~The~~ sequence of events from initiation until a stabilized ~~condition~~ is reached is reviewed to ascertain:

1. The extent to which normally operating plant instrumentation and controls are assumed to function.
2. The extent to which plant and reactor protection systems are required to function.
3. The credit taken for the functioning of normally operating plant systems.
4. The operation of engineered safety systems that is required.

GENERIC ASSESSMENT OF SALEM EVENT

ACCEPTED ANALYSIS ASSUMPTIONS  
AND  
**CONTROL SYSTEM OPERATING ASSUMPTIONS**

- Random Single Failure in Protection System Assumed Concurrent with Initiating Event
- Random Failure in Control System Assumed as Initiating Event
- Control System Operating Assumptions During Anticipated Operational Occurrence (AOO) or Design Basis Accident (DBA)
  - Assumed to be in Manual Mode

or

  - Assumed to Operate Normally in Automatic Mode

Dependent on Which Assumption Results in Most Severe Consequences

- No Random Failures Assumed (Other than Initiating Event) in Control Systems Concurrent with AOO or DBA

GENERIC ASSESSMENT OF SALEM EVENT

CONTROL SYSTEM FAILURE  
AND OPERATING ASSUMPTIONS

- **Periodic** Surveillance of Control Systems per the **Technical** Specifications
- **Capability** of Operator to Detect Abnormal **Control** System Operation Based on Control **Board** Indications and Control Limit Alarms
- **Any** Postulated Failure that is Not Detectable Via **Surveillance** or Control Board Indication **Assumed** Concurrent with AOO or DBA
- **Resultant** Low Probability of Random Control **System** Failure Concurrent with an AOO or DBA

**GENERIC ASSESSMENT OF SALEM EVENT**

**POSTULATED PLANT EVENT: LOAD REJECTION  
(CONDITION I)**

**CONTROL SYSTEMS ASSUMED TO NORMALLY  
OPERATE**

**STEAM DUMP**

**PRESSURIZER POWER-OPERATED RELIEF VALVES  
(PORV)**

**ROD CONTROL SYSTEM**

**CONSEQUENCES OF POSTULATED CONTROL SYSTEM  
FAILURE(S):**

- **STEAM DUMP FAILS OPEN**

**BOUNDED BY STEAM LINE BREAK ANALYSES**

- **PRESSURIZER PORV FAILS OPEN**

**BOUNDED BY RCS DEPRESSURIZATION/LOCA  
ANALYSES**

- **ROD CONTROL SYSTEM MALFUNCTION**

**BOUNDED BY RCCA WITHDRAWAL ANALYSES**

# SAFETY ANALYSIS CLASSIFICATION

## DESIGN PHILOSOPHY

- Most probable occurrence should yield least radiological risk to the public
- Situations having the potential for the greatest risk to the public should be those least likely to occur

## ANS CONDITION II MODERATE FREQUENCY ( $> 10^{-2}$ /YR)

- Minimum Design DNBR Limit

## ANS CONDITION III INFREQUENT FAULT ( $10^{-4} - 10^{-2}$ /YR)

- Small Fraction of Failed Fuel

## ANS CONDITION IV LIMITING FAULT ( $< 10^{-4}$ /YR)

- 10 CFR 100 Dose Limits
- Maintain Core Coolability

**APPLICABLE  
GENERAL DESIGN CRITERIA**

**10 CFR PART 50 APPENDIX A**

**Necessary design and performance requirements for systems & components to provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.**

**GDC 25  
PROTECTION SYSTEM REQUIREMENTS  
FOR REACTIVITY CONTROL MALFUNCTIONS**

**"The protection system shall be designed to assure that specified acceptable fuel design limits are not exceeded for any single malfunction of the Reactivity Control Systems, such as accidental withdrawal of control rods."**

## ASYMMETRIC RCCA WITHDRAWAL PROBABILITY OF OCCURRENCE

- **DETECTABLE**
  - Rod movement during normal operation
  - Monthly surveillance
  
- **OPERATING HISTORY**
  
- **INITIAL ASSESSMENT INDICATES LOW PROBABILITY OF CONTROL SYSTEM CARD FAILURES RESULTING IN RCCA MOVEMENT (CONSISTENT WITH ANS CONDITION III FREQUENCY)**
  
- **LIMITING ASYMMETRIC RCCA WITHDRAWAL SCENARIO HAS LOWER PROBABILITY OF OCCURRENCE**

## GENERIC ASSESSMENT OF SALEM EVENT

### WITH RESPECT TO THE SALEM EVENT:

- The failures in the Logic Cabinet should have caused all Shutdown Bank A rods to either move out or remain stationary.
- Some other condition may have caused only one CRDM to respond.
- The technical investigation is ongoing.
- The frequency of these combined effects classifies it as a Condition III event.
- It is appropriate to demonstrate compliance with the acceptance criteria for a Condition III event (small fraction of failed fuel).
- This meets the intent of GDC 25 for meeting acceptable fuel design limits.

## GENERIC ASSESSMENT OF SALEM EVENT

### POSTULATED EVENTS

- **Single RCCA Withdrawal at Power**
- **Single RCCA Withdrawal from Subcritical**
- **Uncontrolled RCCA Bank Withdrawal at Power**
- **Uncontrolled RCCA Bank Withdrawal from Subcritical**
- **Asymmetric RCCA Withdrawal at Power**
- **Asymmetric RCCA Withdrawal from Subcritical**

## ASYMMETRIC RCCA WITHDRAWAL

- **Ass**essed to have a low probability of occurrence ~~com~~mensurate with Condition III Infrequent Fault
- **Allo**wance of a small amount of fuel damage is ~~con~~sistent with the design philosophy
- **Con**servative generic bounding evaluation of limiting ~~sc~~enarios indicates that a small percentage of the rods ~~wou~~ld be predicted to experience a calculated DNBR ~~bel~~ow the limit value. Little or no actual fuel failure is ~~pre~~dicted.
- **No** undue risk to the public health and safety

## GENERIC ASSESSMENT OF SALEM EVENT

### ASYMMETRIC RCCA WITHDRAWAL AT POWER

#### Event Description:

- ~~Operator~~ **RCCA** banks operate within rod insertion limits in normal ~~operation~~ **overlap**
- ~~Operator~~ **Operator** or automatic rod control demand for RCCA ~~insertion~~ **insertion** AND postulated failure lead to RCCA withdrawal
- ~~Any~~ **Any** combination of 2 or more RCCAs from inserted ~~control~~ **control** banks (D, D + C, or C + B) withdraw partially or ~~fully~~ **fully** from core

## ASYMMETRIC RCCA WITHDRAWAL AT POWER

Possible increase in FdH due to asymmetric RCCA withdrawal compared to single RCCA withdrawal

### Limiting Scenario

- Full withdrawal of 2 or 3 adjacent D-bank rods (from different groups)
- Remaining D-bank RCCAs at insertion limit
- 100% power

Fewer than 1% additional rods found to be below DNBR limit value compared to limiting single RCCA withdrawal case

Current W reload designs show a maximum of 1.5% of rods below DNBR limit for single RCCA withdrawal at power event

Margin exists to accommodate any additional rods below DNBR limit due to multiple RCCA withdrawal and still satisfy Condition III criteria

Little or no fuel damage will occur due to postulated event

## GENERIC ASSESSMENT OF SALEM EVENT

### ASYMMETRIC RCCA WITHDRAWAL FROM SUBCRITICAL

#### Event Description:

- Reactor in **STARTUP MODE** with  $K\text{-eff} = 1.0$
- Shutdown **banks** are withdrawn from core
- RCCA **banks** operate in normal overlap
- Operator **demand**, in manual control mode, for RCCA insertion **AND** postulated failure lead to RCCA withdrawal
- Any combination of 2 or more RCCAs from inserted control banks (**A, A + B, B + C, C + D**) withdraw partially or fully from core

## GENERIC ASSESSMENT OF SALEM EVENT

### ASYMMETRIC PCCA WITHDRAWAL FROM SUBCRITICAL

Typical rod speed in manual mode is 48 steps per minute

Operator action limits maximum misalignment to 48 steps

- Impact on peaking factors is limited
- Reactivity insertion rate is low

Use of currently approved methods expected to demonstrate the number of fuel rods below DNBR limit will be limited to small fraction of core

Use of 3-D kinetics methods expected to demonstrate no fuel rods below DNBR limit

Little or no fuel damage will occur due to postulated event

# EQUIPMENT PERFORMANCE REVIEW

## INITIAL REVIEW CONDUCTED

- To identify failures of components located in the rod control system logic cabinet
  
- Using three available data bases
  - Nuclear Plant Reliability Data System (NPRDS)
  - Licensee Event Reports (LERS)
  - Nuclear Power Experience

# EQUIPMENT PERFORMANCE REVIEW

## RESULTS


- Total of 34 logic cabinet component failures identified
  - 24 no rod movement or no rod movement with urgent alarm
  - 2 step counter driver failures
  - 1 card failure identified subsequent to a reactor trip and unrelated
  - 5 rod drop events
  - 2 rod group misalignment events

# EQUIPMENT PERFORMANCE REVIEW


## ~~CON~~CLUSIONS

- No reported failure events occurred where a single rod became misaligned (similar to Salem event)
- Estimated frequency of misalignment confirms that event is a Condition III event

# LOGIC CABINET CARD FAILURES BY CALENDAR YEAR



# LOGIC CABINET CARD FAILURES BY TIME FROM COMMERCIAL OPERATION



NUMBER OF EVENTS

## AGING CONSIDERATIONS

### BASED ON INITIAL REVIEW

- ~~The~~ distribution of reported failures by years of plant ~~opera~~tion shows no aging
- ~~The~~ distribution of reported failures by calendar year shows no ~~aging~~
- ~~Consi~~deration is being given to the collection of additional ~~data~~

# SAFETY ASSESSMENT

- **Meet ANS Condition III Acceptance Criteria**
- **Minimal or No Actual Fuel Damage will Occur as a Result of Postulated Failure Scenarios**
- **No Challenge to the Integrity of the Reactor Coolant System or Containment**
- **No Undue Risk to Public Health and Safety**
- **All plants should continue operation and/or startup.**

## SYSTEM OPERABILITY

- **Operability** of the Rod Control System will continue to be **determined** through Tech Spec requirements and normal **plant operations**
- **Current** assessment is that the Rod Control System is **operable**

GENERIC ASSESSMENT OF SALEM EVENT

NRC **QUESTIONS** FOR REGULATORY RESPONSE GROUP

1. How ~~many plants~~ and which plants have a rod control system similar to that at Salem?

Answer

All domestic Westinghouse plants except Connecticut Yankee have a similar Rod Control System

**NRC QUESTIONS FOR REGULATORY RESPONSE GROUP**

2. Are these plants susceptible to the single failure experienced at Salem which results in uncontrolled rod withdrawals?

**ANSWER**

Since the plants have a similar Rod Control System, similar Rod Control System failures could occur. The expected response to the single failure is a RCCA group on bank withdrawal. We do not believe that the rod withdrawal is uncontrolled since the resulting rod motion is detectable.

3. What are the consequences of rod withdrawals caused by such failures? Is there a potential for common cause failures which can cause multiple rod withdrawals because of this system?

**ANSWER**

The RCCA bank withdrawal is a Condition II event and is analyzed in current plants' FSARs with the result being no predicted occurrence of DNB.

Single or asymmetric rod withdrawal are treated as Condition III events and only a small fraction of rods (less than 5%) are predicted to experience DNB. This meets the acceptance criteria for a Condition III event.

To date, either at Salem or at other plants, no common cause failures have been identified.

GENERIC ASSESSMENT OF SALEM EVENT

NRC QUESTIONS FOR REGULATORY RESPONSE GROUP

4. What interim actions or operating restrictions are necessary to ensure the plants remain within their design bases?

ANSWER

The plants are operating within their design basis; the recommended actions, provided in NSAL-93-007, emphasize that attention be given to specific routine operating practices.

GENERIC ASSESSMENT OF SALEM EVENT

NRC ~~QUESTIONS~~ FOR REGULATORY RESPONSE GROUP

What ~~longer term~~ actions are contemplated to ~~resolve this issue?~~

ANSWER

The ~~evaluation~~ already underway of the Salem event ~~should continue~~. The WOG will collect data on ~~operating events~~ and continue to interact with the ~~NRC during the~~ evaluation period.

## GENERIC ASSESSMENT OF SALEM EVENT

### WOG FUTURE ACTIONS

- NRC ~~updates on~~ status
- Update ~~full~~ Owners Group (6/16/93)
- Address ~~NRC co~~ comments resulting from this meeting
- Continue ~~to partici~~participate in the evaluation of the root cause determination of the event.
- Meet ~~with NRC~~ to discuss evaluations (August)
- WOG ~~to contin~~ue to investigate Rod Control System performance ~~his~~ history (TBD)