



State of New Jersey
Department of Environmental Protection and Energy
Division of Environmental Safety, Health and Analytical Programs
CN 415
Trenton, NJ 08625-0415

Jeanne M. Fox
Acting Commissioner

Gerald P. Nicholls, Ph.D.
Director

August 3, 1993

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Salem Generating Station Units Nos. 1 and 2
Docket Nos. 50-272 and 50-311
Amendment to the Facility Operating License
License Change Request 92-12

The subject request was submitted to the NRC by PSE&G letter dated February 23, 1993 and revised by PSE&G letter dated July 19, 1993. The revised request proposes to delete the Boric Acid Storage Tank level instrumentation and associated surveillance and action statement requirements from the list of Post Accident Monitoring instrumentation contained in Tables 3.3-11 and 4.3-11 of the Salem Units 1 and 2 Technical Specifications. This is based on this instrumentation not being assumed operable in the Salem accident analysis. The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b) and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Distribution

090072

9308100157 930803
PDR ADOCK 05000272
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

ADD 1/0

Distribution

Jill Lipoti
N.J. DEPE

M. Miller
NRC Region I State Liaison Officer

T. Johnson
NRC Sr. Resident Inspector

J. Stone
NRC Project Manager

F. Thompson
PSE&G