



State of New Jersey
Department of Environmental Protection and Energy
 Division of Environmental Safety, Health and Analytical Programs
 CN 415
 Trenton, NJ 08625-0415

Jeanne M. Fox
 Acting Commissioner

-Gerald P. Nicholls, Ph.D.
 Director

September 20, 1993

U.S. Nuclear Regulatory Commission
 Document Control Desk
 Washington, D.C. 20555

To Whom it May Concern:

Subject: Salem Nuclear Generating Station, Unit 2.
 Docket No. 50-311
 License Change Request 93-01, Revision 1

A.C. Power Requirements During Switchyard Modifications
 By letter dated August 24, 1993, Public Service Electric and Gas Company (PSE&G) submitted the subject license change request to the Nuclear Regulatory Commission (NRC). The letter is a revision of PSE&G's request of August 4, 1993 (NLR-N93075), in response to NRC staff comments received from the Licensing Project Manager for the Salem Generating Station, Mr. J. C. Stone.

The requested change would extend the Allowed Outage Time (AOT) that the Salem Unit 2 may operate with one inoperable offsite power circuit, to allow for switchyard modifications. It would also modify the Emergency Diesel Generator (EDG) testing requirements to exempt the Unit 2 EDG from repetitive testing when an offsite power circuit is de-energized for implementation of switchyard modifications.

Per 10 CFR 50.91(b) requirements, the New Jersey Department of Environmental Protection and Energy's (NJDEP&E) Bureau of Nuclear Engineering (BNE) reviewed the License Change Request (which included the revised proposed amendment, PSE&G's reasoned analysis about no significant hazards consideration, and PSE&G's response to NRC's comments). Based on this review, the BNE has no comments on the proposed request.


9309290021 930920
 PDR ADDOCK 05000311
 P PDR

New Jersey is an Equal Opportunity Employer
 Recycled Paper

A001 1/0

If you have any questions, please contact Suren Singh
at (609) 987-2039.

Sincerely,



Kent Tosch, Manager
Bureau of Nuclear Engineering

- c. J. Lipoti, Assistant Director
Radiation Protection Programs, NJDEP&E

- Marie Miller, State Liaison Officer -Region I
U.S. NRC

- J. Stone, Project Manager, NRR
U.S. NRC

- S. Barr, Artificial Island Acting Senior Resident Inspector
U.S. NRC

- F. Thomson, Manager Licensing and Regulation
PSE&G