

Public Service
Electric and Gas
Company

Stanley LaBruna

Public Service Electric and Gas Company

P.O. Box 236, Hancocks Bridge, NJ 08038 609-339-1700

Vice President - Nuclear Engineering

JAN 18 1994

NLR-N93189

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

NRC BULLETIN 88-11
PRESSURIZER SURGE LINE THERMAL STRATIFICATION
SALEM GENERATING STATION
UNIT NO. 1
DOCKET NO. 50-272

By letter dated December 10, 1992 (ref: NLR-N92164), Public Service Electric & Gas Company (PSE&G) revised its response to NRC Bulletin 88-11. WCAP-12913, Revision 1, was submitted as an enclosure to the letter. Based on the revised WCAP, PSE&G withdrew its commitment to perform spring hanger modifications and committed to perform walkdown measurements of the Pressurizer Surge Line spring hanger travel and pipe whip restraints during the eleventh refueling outage.

PSE&G hereby confirms the completion of the required walkdown measurements. These walkdowns were performed during the on-going eleventh refueling outage. The results of these walkdowns indicate that the spring hanger displacements and whip restraints do not show any adverse results and are satisfactory. No further actions have been identified at this time.

Should there be any questions with regard to this submittal, please do not hesitate to contact us.

Sincerely,



280007

9402020095 940118
PDR ADOCK 05000272
Q PDR

IF30
1/0

JAN 18 1994

Document Control Desk
NLR-N93189

2

C Mr. J. C. Stone
Licensing Project Manager

Mr. C. Marschall
Senior Resident Inspector

Mr. T. Martin, Administrator
Region I

Mr. Kent Tosch, Manager IV
New Jersey Department of Environmental Protection
Division of Environmental Quality
Bureau of Nuclear Engineering
CN 415
Trenton, NJ 08625