



State of New Jersey
Department of Environmental Protection and Energy

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

May 20, 1994

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Salem Generating Station Unit 2
Docket No. 50-311
Amendment to the Facility Operating License
License Change Request 94-09

The subject request was submitted to the NRC by Public Service Electric and Gas on March 28, 1994. The request proposes to add a footnote to the Technical Specification Table listing containment isolation valves. This footnote will denote that the main feedwater stop check valves are exempt from 10 CFR 50 Appendix J Type C testing. These valves are designated as such in Section 6.2 of the Final Safety Analysis Report.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) has reviewed the request and the supplemental information in accordance with the requirements of 10 CFR 50.91(b) and has no comments. If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Distribution

960053

9405260232 940520
PDR ADCK 05000311
PDR

AD17 1/0

Distribution

A. McMahon
N.J. DEPE

D. Chawaga
NRC Region I State Liaison Officer

C. Marschall
NRC Sr. Resident Inspector

J. Stone
NRC Project Manager

F. Thomson
PSE&G