





TABLE 4. 11 (Continued)
SURVEILLANCE REQUIREMENTS FOR
ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
12. PORV Position Indicator	M	NA	 R
13. PORV Block Valve Position Indicator	M	NA	 G*
14. Pressurizer Safety Valve Position Indicator	M	NA	R
15. Containment Pressure - Narrow Range	M	NA	NA
16. Containment Pressure - Wide Range	M	R	NA
17. Containment Water Level - Wide Range	M	R	NA
18. Core Exit Thermocouples	M	R	NA
19. Reactor Vessel Level Instrumentation System (RVLIS)	M	R	NA

*

Unless the block valve is closed in order to meet the requirements of ACTION b, or C in Specification 3.4.3.

TABLE 4.1.1 (Continued)
SURVEILLANCE REQUIREMENTS FOR
ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
12. PORV Position Indicator	M	NA	 R
13. PORV Block Valve Position Indicator	M	NA	 R*
14. Pressurizer Safety Valve Position Indicator	M	NA	R
15. Containment Pressure - Narrow Range	M	NA	NA
16. Containment Pressure - Wide Range	M	R	NA
17. Containment Water Level - Wide Range	M	R	NA
18. Core Exit Thermocouples	M	R	NA
19. Reactor Vessel Level Instrumentation System (RVLIS)	M	R	NA

* Unless the block valve is closed in order to meet the requirements of ACTION b, or C in Specification 3.4.5.

SALEM - UNIT 2

3/4 3-52a

Amendment No. 35