PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (continued)

- b. At least once per 92 days on a STAGGERED TEST BASIS by:
 - 1. Verifying that each motor-driven pump develops a discharge pressure of greater than or equal to 1275 psig on recirculation flow.
 - Verifying that the steam turbine-driven pump develops a discharge pressure of greater than or equal to 1500 psig on recirculation flow when the secondary steam supply pressure is greater than 750 psig. The provisions of Specification 4.0.4 are not applicable Treet A
- c. At least once per 18 months during shutdown by:
 - 1. Verifying that each automatic valve in the motor driven pump flow path actuates to its correct position on a pump discharge pressure test signal.
 - Verifying that each auxiliary feedwater pump starts as designed automatically upon receipt of each auxiliary feedwater actuation test signal.

INSERT A

...provided the surveillance is performed within 24 hours after secondary side pressure is greater than 680 psig.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 92 days on a STAGGERED TEST BASIS by:
 - 1. Verifying that each motor-driven pump develops a discharge pressure of greater than or equal to 1275 psig on recirculation flow.
 - 2. Verifying that the steam turbine-driven pump develops a discharge pressure of greater than or equal to 1500 psig on recirculation flow when the secondary steam supply pressure is greater than #50 psig. The provisions of Specification 4.0.4 are not applicable TNSERT A
- c. At least once per 18 months during shutdown by:
 - 1. Verifying that each automatic valve in the motor driven pump flow path actuates to its correct position on a pump discharge pressure test signal.
 - Verifying that each auxiliary feedwater pump starts as designed automatically upon receipt of each auxiliary feedwater actuation test signal.

INSERT A

...provided the surveillance is performed within 24 hours after secondary side pressure is greater than 680 psig.