



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

October 26, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Ladies & Gentlemen:

Subject: Salem Nuclear Generating Station, Units 1 and 2
License Amendment Request, LCR-93-06. Reactor Trip
System Surveillance Requirements Revisions to Appendix A
of Operating Licenses DPR-70 and DPR-75
Docket Nos. 50-272 and 50-311

By letter dated September 20, 1994, Public Service Electric
and Gas Company (PSE&G) submitted the subject license change
request to the Nuclear Regulatory Commission (NRC).

The request will impact Technical Specification (TS) Section
3/4.3.1 "Reactor Trip System Instrumentation," Surveillance
Requirements in Table 4.3-1.

PSE&G considers this submittal to be a Cost Beneficial
Licensing Action (CBLA).

Via this change request, PSE&G proposes to adopt the
Westinghouse Standard Technical Specifications (NUREG-1431) Channel
Functional Test surveillance frequency for the Manual Reactor Trip
Switches and for the Reactor Trip Breakers (RTB) and relocate RTB
maintenance requirements from the TCs to the Salem Updated Final
Safety Analysis Report (UFSAR).


The New Jersey Department of Environmental Protection and
Energy's Bureau of Nuclear Engineering (BNE) has reviewed the
request in accordance with the requirements of 10 CFR 50.91(b) and
has no comments.

9411030324 941026
PDR ADOCK 05000272
P PDR

ADD 1/0

If you have any questions, please contact Ariadni Kapsalopoulou at (609) 987-2052 or Suren Singh at (609) 987-2039.

Sincerely,



Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Jill Lipoti, PhD., Assistant Director
Radiation Protection Programs,
NJ DEP

David Chawaga, State Liaison Officer - Region I
U.S. NRC

Leonard N. Olshan, Licensing Project Manager, NRR
U.S. NRC

C. Marschall, Artificial Island Senior Resident Inspector
U.S. NRC

F. Thomson, Manager Licensing and Regulation, PSE&G