



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

November 21, 1994

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Salem Generating Station, Unit Nos. 1 & 2
Docket Nos. 50-272 & 50-311
Amendment to Facility Operating License
License Change Request 94-29

The subject request was submitted to the NRC by PSE&G letter dated September 29, 1994. The proposed change revises Surveillance Requirement 4.6.2.1 by requiring a Containment Spray System header flow test once every ten years instead of once every five years to confirm that the spray nozzles are unobstructed.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b) and has the following comment. Attachments 2 & 3 identify pages and sections to be changed but do not contain the actual marked up pages (Ref. Salem LCR 93-28).

If you have any questions, please contact Tom Kolesnik at (609) 987-2053 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Distribution

000070
9412090058 941121
PDR ADOCK 05000272
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

COOL 1/0

Distribution

Jill Lipoti
N.J. DEP

Dennis Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

C. Marschall
NRC Sr. Resident Inspector

L. Olshan
NRC Project Manager

F. Thomson
PSE&G