



**State of New Jersey
Department of Environmental Protection**

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

December 9, 1994

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

**Subject: Salem Generating Stations
Docket Nos. 50-272 and 50-311
Request to Amend the Facility Operating License
License Change Request 94-19**

The subject request was submitted to the NRC by Public Service Electric and Gas on September 20, 1994. The request proposes to reduce the secondary side steam pressure required for surveillance testing of the steam turbine driven Auxiliary Feedwater Pump for Salem Units 1 and 2. The proposed change also clarifies the time required to perform the steam turbine driven Auxiliary Feedwater Pump surveillance test when entering Mode 3.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b) and has no comments.

Please contact Rich Pinney at (609) 987-2086 or Suren Singh at (609) 987-2039 if you need further information.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

270088

ADD 1/0

c: J. Lipoti
N.J. DEP

D. Chawaga
NRC Region 1 State Liaison Officer

C. Marschall
NRC Sr. Resident Inspector

L. Olshan
NRC Project Manager

F. Thomson
PSE&G