

Public Service  
Electric and Gas  
Company

Joseph J. Hagan

Public Service Electric and Gas Company

P.O. Box 236, Hancocks Bridge, NJ 08038 609-339-1200

Vice President - Nuclear Operations

DEC 23 1994

NLR-N94171

LCR 94-33

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**LICENSE AMENDMENT APPLICATION  
REVISION OF SURVEILLANCE REQUIREMENTS FOR AREAS WITHIN CONTAINMENT  
SALEM GENERATING STATION UNIT NOS. 1 and 2  
FACILITY OPERATING LICENSE NOS. DPR-70 AND DPR-75  
DOCKET NOS. 50-272 AND 50-311**

This letter submits an application for amendment to Appendix A of Facility Operating Licenses DPR-70 and DPR-75 for the Salem Generating Station Unit Nos. 1 and 2, respectively, and is being filed in accordance with 10CFR50.90. Pursuant to the requirements of 10CFR50.91(b)(1), a copy of this request for amendment has been sent to the State of New Jersey.

The proposed Technical Specification change contained herein represents a change to Specification 4.5.2.c.2 and implements a recommended line item improvement from Generic Letter 93-05, "Line-Item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation." The proposed change revises the surveillance requirement to perform a visual inspection of containment areas affected by containment entry when Containment Integrity is established. It should be noted that similar changes were approved by the NRC Staff for Palo Verde Nuclear Generating Station Unit Nos. 1, 2 and 3 in a Safety Evaluation dated September 2, 1994.

The proposed change has been evaluated in accordance with 10CFR50.91(a)(1), using the criteria in 10CFR50.92(c), and it has been determined that this request involves no significant hazards considerations.

A description of the requested amendment, supporting information and analyses for the change, and the basis for a no significant hazards consideration determination are provided in Attachment 1. The Technical Specification pages affected by the proposed change are provided in Attachment 2 and 3, with pen and ink changes, for Salem Units 1 and 2, respectively.

9501040273 941223  
PDR ADDCK 05000272  
P PDR

ADD 1

DEC 23 1994


Document Control Desk  
NLR-N94171

-2-

Upon NRC approval of this proposed change, PSE&G requests that the amendment be made effective on the date of issuance, but implemented within sixty days to provide sufficient time for associated administrative activities.

Should you have any questions regarding this request, please contact us.

Sincerely,

A handwritten signature in black ink, appearing to be "M. T. Martin", written over the word "Sincerely,".

Affidavit  
Attachments (3)

C Mr. T. T. Martin, Administrator - Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. L. N. Olshan, Licensing Project Manager - Salem  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Mr. C. S. Marschall (S09)  
USNRC Senior Resident Inspector

Mr. K. Tosch, Manager IV  
NJ Department of Environmental Protection  
Division of Environmental Quality  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625



