

Dreket File 50-272/311 50-354/355

MAY

NING FILE GENTER COPY

WASHINGTON, D.C. 20555-0001

January 5, 1995

Mr. Leon R. Eliason Chief Nuclear Officer & President Nuclear Business Unit Public Service Electric and Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

USE OF ASME CODE CASE N-508 FOR ROTATION OF SNUBBERS AND PRESSURE SUBJECT: RELIEF VALVES FOR THE PURPOSE OF TESTING, SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2, AND HOPE CREEK GENERATING STATION (TAC NOS. M89976, M89977, AND M89978)

Dear Mr. Eliason:

AUCLEAR REGUL

STATES

CI3LING

By your letter of July 21, 1994, you requested NRC approval for the use of ASME Code Case N-508, "Rotation of Serviced Snubbers and Pressure Relief Valves for the Purpose of Testing," for the purpose of snubber and pressure relief valve inservice testing. According to the Code Case, snubbers and pressure relief valves may be rotated from stock and installed on components (including piping systems) within the Section XI boundary, provided the requirements as listed in the Code Case are met. This Code Case was approved by ASME and published on March 11, 1993. However, the staff has not yet generically approved the use of this Code Case. It should be noted that a revision to the Code Case (N-508-1) was approved by ASME on May 11, 1994, which provides additional information about specific differences between certain editions of the ASME Code, but otherwise has the same provisions of Code Case N-508.

You indicated in the above letter that your ISI group utilizes a computer database program to track the current test results of all snubbers by type, rating and serial number. This database provides specific information that identifies a snubber's physical plan location at any point in time. A similar independent tracking system for pressure relief valves will be used. The staff concurs that this tracking mechanism, which is required by item (f) of Code Case N-508, will assure proper record keeping of the status of testing for each of the snubbers and pressure relief valves in the plant.

You also indicated that by utilizing the Code Case, use of an NIS-2 form, "Owner's Report for Repairs and Replacements," which is currently required by Section XI whenever a snubber of pressure relief valve is removed, will now be required only after the component fails a functional test (reference items (g) and (i) of the Code Case), which is performed during an outage. Testing of removed snubbers and pressure relief valves, including required sample expansions, will be performed in accordance with the owner's test programs (reference item (h).

9501110359 950105 PDR ADDCK 05000272

PNR

L. Eliason

Based on the information provided, the staff finds that the use of Code Case N-508 (or the revision N-508-1) does not create any technical or administrative changes that would impact the existing ISI Programs, IST Programs, or Technical Specifications for Salem and Hope Creek Generating Stations. The staff, therefore, recommends approval of your request as stated in the above July 21, 1994, letter.

Sincerely,

Original signed by:

Leonard N. Olshan, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION Docket File PUBLIC PDI-2 Reading SVarga JZwolinski JStolz LOlshan MO'Brien OGC ACRS(4) JWhite, RGN-I

OFFICE	PDILA/2/11AX	RDI-2/PM	PDI-2/PM	PDIA2/D	
NAME	MO'Briten	LO1shan:rb	DMoran	JStolz	
DATE	1/ /95	1/5/95	1/5/95	1 15 195	

OFFICIAL RECORD COPY DOCUMENT NAME: SA89976.GEN L. Eliason

Based on the information provided, the staff finds that the use of Code Case N-508 (or the revision N-508-1) does not create any technical or administrative changes that would impact the existing ISI Programs, IST Programs, or Technical Specifications for Salem and Hope Creek Generating Stations. The staff, therefore, recommends approval of your request as stated in the above July 21, 1994, letter.

Sincerely,

Jeour W. M. blu

Leonard N. Olshan, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

cc: See next page

Mr. Leon R. Eliason Public Service Electric & Gas Company

cc:

Mark J. Wetterhahn, Esquire Winston & Strawn 1400 L Street NW Washington, DC 20005-3502

Richard Fryling, Jr., Esquire Law Department - Tower 5E 80 Park Place Newark, NJ 07101

Mr. J. Hagan, Acting General Manager - Salem Operations Salem Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. J. Hagan Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, New Jersey 08038

Mr. Charles S. Marschall, Senior Resident Inspector
Salem Generating Station
U.S. Nuclear Regulatory Commission
Drawer I
Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director Radiation Protection Programs NJ Department of Environmental Protection and Energy CN 415 Trenton, NJ 08625-0415

Maryland Office of People's Counsel 6 St. Paul Street, 21st Floor Suite 2102 Baltimore, Maryland 21202

Mr. J. T. Robb, Director Joint Owners Affairs Philadelphia Electric Company 955 Chesterbrook Blvd., 51A-13 Wayne, PA 19087 Salem Nuclear Generating Station, Units 1 and 2, and Hope Creek Generating Station

Richard Hartung Electric Service Evaluation Board of Regulatory Commissioners 2 Gateway Center, Tenth Floor Newark, NJ 07102

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Mr. Frank X. Thomson, Jr., Manager Licensing and Regulation Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

Ms. P. J. Curham MGR. Joint Generation Department Atlantic Electric Company P.O. Box 1500 6801 Black Horse Pike Pleasantville, NJ 08232

Carl D. Schaefer External Operations - Nuclear Delmarva Power & Light Company P.O. Box 231 Wilmington, DE 19899

Public Service Commission of Maryland Engineering Division Chief Engineer 6 St. Paul Centre Baltimore, MD 21202-6806