

ATTACHMENT 2

TECHNICAL SPECIFICATION PAGE WITH PEN AND INK CHANGES

LICENSE AMENDMENT APPLICATION  
ONE-TIME EXTENSION OF SURVEILLANCE REQUIREMENT INTERVAL  
SALEM GENERATING STATION UNIT NO. 1  
FACILITY OPERATING LICENSE DPR-70  
DOCKET NO. 50-272

LR-N95056  
LCR 95-06

The following Technical Specification for Facility Operating License No. DPR-70 is affected by this License Amendment Request:

<u>Technical Specification</u>	<u>Page</u>
4.6.1.2.a	3/4 6-2

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of  $\leq L_a$ , 0.10 percent by weight of the containment air per 24 hours at design pressure, (47.0 psig).
- b. A combined leakage rate of  $\leq 0.60 L_a$  for all penetrations and valves subject to Type B and C tests as identified in Table 3.6-1, when pressurized to  $P_a$ .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding  $0.75 L_a$ , or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding  $0.60 L_a$ , restore the leakage rate(s) to within the limit(s) prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4-1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 + 10 month intervals during shutdown at design pressure (47.0 psig) during each 10-year service period.\* The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection.

\*The second inservice Integrated Leak Rate Test shall be performed at the fifth refueling outage, but no later than May, 1984.

*Replace with Insert*

**INSERT**

The fifth inservice Integrated Leak Rate Test shall be performed prior to or during the twelfth refueling outage, but no later than November 30, 1995.