



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

JUL 31 1996

LR-N96221

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

**GENERIC LETTER 93-04 COMMITMENT
ROD CONTROL SYSTEM FAILURE AND WITHDRAWAL OF ROD
CONTROL CLUSTER ASSEMBLIES
SALEM GENERATING STATION NOS. 1 AND 2
FACILITY OPERATING LICENSES DPR-70 AND DPR-75
DOCKET NOS. 50-272 AND 50-311**

Gentlemen:

This letter is to provide confirmation that Public Service Electric & Gas Company (PSE&G) has completed the long term actions pertaining to Generic Letter 93-04, *Rod Control System Failure and Withdrawal of Rod Cluster Control Assemblies, 10CFR50.54(f)*. The NRC's Request for Additional Information (RAI) dated December 19, 1994, requested that PSE&G inform the Staff in writing when the Westinghouse Owners Group recommended current order timing modification was implemented for the Salem Generating Stations. PSE&G had responded to the RAI on January 27, 1995, (ref. LR-95010), stating that the Unit 2 modification had been completed during the eighth refueling outage in 1994 and that the Unit 1 modification would be completed during the twelfth refueling outage in 1995.

Salem Unit 1 entered the twelfth refueling outage in September of 1995 and continues in an extended outage to replace the Steam Generators. During this present outage, the current timing modification was incorporated into the Rod Control System for Unit 1.

Implementation of this modification completes the actions requested of PSE&G relative to the Generic Letter and subsequent RAI.

Should you have any questions regarding this information, we will be pleased to discuss them with you.

Sincerely,

D.R. Powell

D. R. Powell
Manager -

Licensing and Regulation

9608080234 960731
PDR ADOCK 05000272
PDR

The power is in your hands.

40
A#30

JUL 31 1996

Document Control Desk
LR-n96221

-2-

C Mr. H. J. Miller, Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. L. Olshan, Licensing Project Manager - Salem
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 14E21
Rockville, MD 20852

Mr. C. Marschall (X24)
USNRC Senior Resident Inspector - Salem

Mr. K. Tosch, Manager IV
Bureau of Nuclear Engineering
33 Arctic Parkway
CN 415
Trenton, NJ 08625