



PSEG

Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

AUG 13 1996

CORRECTED COPY

LR-N96237

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**LER 272/96-014-00
SALEM GENERATING STATION - UNIT 1
FACILITY OPERATING LICENSE NO. DPR-70
DOCKET NO. 50-272**

This Licensee Event Report entitled "Potential Hydrogen Embrittlement on 4KV Breaker Parts" is being submitted pursuant to the requirements of the Code of Federal Regulations 10CFR50.73(a)(2)(i)(B).

Sincerely,

David F. Garchow
David F. Garchow
General Manager -
Salem Operations

Attachment

SORC Mtg. 96-106

DVH/tcp

C Distribution
LER File 3.7

9608200195 960813
PDR ADOCK 05000272
S PDR

RE 22
11

The power is in your hands.

Attachment A

The following represents the commitments that Public Service Electric & Gas (PSE&G) made to the Nuclear Regulatory Commission (NRC) relative to this LER (272/96-014-00). The commitments are as follows:

1. Removed all NLI refurbished breakers, except 2B4D, from vital loads. Breaker 2B4D will be removed when its loads are available to be transferred to another bus.
2. A QA stop work order was issued to NLI on July 26, 1996.
3. The circuit breakers will be removed for replacement and refurbishment. This will be completed for each breaker prior to that breaker being required to be operable.
4. Further corrective actions will be taken as a result of the root cause evaluation currently being conducted. Significant corrective actions that affect the discussion in this LER, if any, will be reported in a supplement to this LER.