



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN-415
Trenton, NJ 08625-0415

November 6, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S96-14

The subject request was submitted to the NRC by PSE&G letter dated September 30, 1996. The request proposes to permanently modify Technical Specification 3/4.7.7 to decrease air flow specifications for testing the Auxiliary Building Ventilation System (ABVS). The purpose of this request is to clarify that the ABVS will be tested up to the maximum design flow rate, but will be operated at a reduced flow rate since the system does not always operate at full capacity.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

9611150167 961106
PDR ADOCK 05000272
P PDR

1/0
A001

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

C. Marschall
NRC Sr. Resident Inspector

L. Olshan
NRC Project Manager

D. Powell
PSE&G