



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN-415
Trenton, NJ 08625-0415

December 2, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S95-36

The subject request was submitted to the NRC by PSE&G letter dated October 25, 1996. The request proposes to permanently modify Technical Specification Table 3.3.5 to increase the Containment Fan Coil Unit response time from less than or equal to 45 seconds, to less than or equal to 60 seconds.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

9612090212 961202
PDR ADOCK 05000272
PDR

090038

A001
1/0

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

C. Marschall
NRC Sr. Resident Inspector

L. Olshan
NRC Project Manager

D. Powell
PSE&G