



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 9, 2018

LICENSEE: Tennessee Valley Authority

FACILITY: Watts Bar Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF DECEMBER 12, 2017, PRE-APPLICATION TELECONFERENCE WITH TENNESSEE VALLEY AUTHORITY REGARDING PROPOSED LICENSE AMENDMENT TO TECHNICAL SPECIFICATION 3.6.3, "CONTAINMENT ISOLATION VALVES" (EPID L-2017-LRM-0063)

On December 12, 2017, a Category 1 public teleconference was held between the U.S. Nuclear Regulatory Commission (NRC) staff and Tennessee Valley Authority (TVA) representatives. The purpose of the teleconference was to discuss TVA's planned submittal of a license amendment request to revise the Watts Bar Nuclear Plant, Units 1 and 2, Technical Specification (TS) 3.6.3, "Containment Isolation Valves," for the containment purge valves. The proposed change would replace the specified surveillance interval with a reference to the Containment Leakage Rate Testing Program. The teleconference notice and agenda, dated November 28, 2017, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML17340B115. A list of participants is provided in the Enclosure.

TVA staff provided a presentation on the purpose of the proposed amendment, the proposed change to the surveillance requirement, a brief technical analysis of the proposed change, information regarding previous precedents, and its proposed schedule for submitting the amendment request. The presentation is available in the ADAMS at Accession No. ML17340B063.

The NRC staff queried the licensee about whether changes to inservice testing (IST) frequencies would also be requested, and whether the licensee could provide information regarding how often the subject valves are cycled and the valves' contributions to total containment leakage rate testing results.

TVA responded that no changes to the IST frequencies would be requested with the amendment application, and that information regarding cycling of the valves and the valves' contributions to leakage rate testing results could be provided in the application.

Members of the public did not participate in the call. No Public Meeting Feedback forms were received. No regulatory decisions were made during the teleconference.

Please direct any inquiries to me at 301-415-6020, or Robert.Schaaf@nrc.gov.

A handwritten signature in black ink, appearing to read "Robert G. Schaaf". The signature is fluid and cursive, with the first name being the most prominent.

Robert G. Schaaf, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-390 and 50-391

Enclosure: List of Attendees

cc: Listserv

SUBJECT: SUMMARY OF DECEMBER 12, 2017, PRE-APPLICATION TELECONFERENCE WITH TENNESSEE VALLEY AUTHORITY REGARDING PROPOSED LICENSE AMENDMENT TO TECHNICAL SPECIFICATION 3.6.3, "CONTAINMENT ISOLATION VALVES" (EPID L-2017-LRM-0063) DATED MAY 9, 2018

DISTRIBUTION:

PUBLIC

PM File Copy

RidsACRS_MailCTR Resource

RidsNrrDorLpl2-2 Resource

RidsNrrPMWattsBar Resource

RidsNrrLABClayton Resource

RidsRgn2MailCenter Resource

TWertz, NRR

JBettle, NRR

MFarnan, NRR

AMink, NRR

JBowen, EDO Region 2

ADAMS Accession Nos.:

Meeting Notice ML17340B115

Meeting Summary ML18102B169

Handouts ML17340B063

OFFICE	NRR/DORL/LPL2-2/PM	NRR/DORL/LPL2-2/LA	NRR/DORL/LPL2-2/BC(A)	NRR/DORL/LPL2-2/PM
NAME	RSchaaf	BClayton	BTindell	RSchaaf
DATE	5/8/2018	5/8/2018	5/9/2018	5/9/2018

OFFICIAL RECORD COPY

LIST OF ATTENDEES

DECEMBER 12, 2017, MEETING WITH TENNESSEE VALLEY AUTHORITY
PRE-APPLICATION TELECONFERENCE REGARDING PROPOSED LICENSE AMENDMENT
TO TECHNICAL SPECIFICATION 3.6.3, "CONTAINMENT ISOLATION VALVES"

<u>NAME</u>	<u>ORGANIZATION</u>
Robert Schaaf	U.S. Nuclear Regulatory Commission (NRC) Office of Nuclear Reactor Regulation (NRR)
Jerome Bettle	NRC/NRR
Michael Farman	NRC/NRR
Aaron Mink	NRC/NRR
Russell Wells	Tennessee Valley Authority (TVA)
Mark Gowin	TVA
Jose Ortiz	TVA
Andrew Pirkle	TVA