



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection
Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700

Robert C. Shinn, Jr.
Commissioner

May 12, 1997

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Ladies and Gentlemen:

Subject: Salem Generating Station Unit Nos. 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request LCR S95-10
Containment Cooling System

Public Service Electric and Gas Company submitted the subject change request to the Nuclear Regulatory Commission on April 11, 1997. The proposed amendment would change Technical Specification Section 3.6.2.3, "Containment Cooling System," by increasing the minimum surveillance testing flow rate to a value that is representative of the post accident requirements.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the above request in accordance with the requirements of 10 CFR 50.91(b) and has no comments on this proposed change.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent Tosch, Manager
Bureau of Nuclear Engineering

9705160230 970512
PDR ADCK 05000272
PDR



Distribution:

Jill Lipoti, Ph. D.
N.J. DEP

Dennis Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

L. Olshan
NRC Project Manager

C. Marschall
NRC Senior Resident Inspector

D. Powell
Manager, Licensing and Regulation
PSE&G