

Document Control Desk

LR-N970269
LCR S97-05

ATTACHMENT 3

Revised Technical Specification Bases Pages

9706180350 970612
PDR ADOCK 05000272
P PDR

PLANT SYSTEMS

• BASES

=====

3/4.7.10 CHILLED WATER SYSTEM - AUXILIARY BUILDING SUBSYSTEM

The OPERABILITY of the chilled water system ensures that the chilled water system will continue to provide the required normal and accident heat removal capability for the control room area, relay rooms, equipment rooms, and other safety related areas. Verification of the actuation of each automatic valve on a Safeguards Initiation signal includes actuation following receipt of a Safety Injection signal or a radiation monitoring signal.

Removal of non-essential heat loads from the chilled water system in the event one chiller is inoperable ensures the remaining heat loads are within the heat removal capacity of the two operable chillers.

Removal of non-essential heat loads from the chilled water system in the event two chillers are inoperable and aligning the CREACs to the maintenance mode ensures the remaining heat loads are within the heat removal capacity of the operable chiller.

During chiller testing, operator actions can take the place of automatic actions.

During Modes 5 and 6 and during movement of irradiated fuel assemblies, chilled water components do not have to be considered inoperable solely on the basis that the backup emergency power source, diesel generator, is inoperable. This is consistent with Technical Specification 3.8.1.2 which only requires two operable diesel generators.

PLANT SYSTEMS

BASES

=====

3/4.7.10 CHILLED WATER SYSTEM - AUXILIARY BUILDING SUBSYSTEM

The OPERABILITY of the chilled water system ensures that the chilled water system will continue to provide the required normal and accident heat removal capability for the control room area, relay rooms, equipment rooms, and other safety related areas. Verification of the actuation of each automatic valve on a Safeguards Initiation signal includes actuation following receipt of a Safety Injection signal or a radiation monitoring signal.

Removal of non-essential heat loads from the chilled water system in the event one chiller is inoperable ensures the remaining heat loads are within the heat removal capacity of the two operable chillers.

Removal of non-essential heat loads from the chilled water system in the event two chillers are inoperable and aligning the CREACs to the maintenance mode ensures the remaining heat loads are within the heat removal capacity of the operable chiller.

During chiller testing, operator actions can take the place of automatic actions.

During Modes 5 and 6 and during movement of irradiated fuel assemblies, chilled water components do not have to be considered inoperable solely on the basis that the backup emergency power source, diesel generator, is inoperable. This is consistent with Technical Specification 3.8.1.2 which only requires two operable diesel generators.