State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
P.O. Box-415
Trenton, NJ 08625-0415

November 18, 1997

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S97-14

The subject request was submitted to the NRC by PSE&G letter dated October 24, 1997. The request proposes to permanently modify Technical Specification (TS) 3/4.6.4.1 calibration time interval for hydrogen recombiners. This change will allow the utility to follow the manufacturers recommendations for channel calibrations from once per refueling outage to once per quarter, to prevent possible voltage signal degradation.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

9711260017 971118
PDR ADOCK 05000272
P PDR

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

D. Chawaga
NRC Region I State Liaison Officer

M. Evans
NRC Sr. Resident Inspector

L. Olshan
NRC Project Manager

D. Powell
PSE&G