

**Southern Nuclear Operating Company  
ND-18-0511  
Enclosure 2**

**Vogtle Electric Generating Plant (VEGP) Unit 3 and Unit 4  
Docket No.: 52-025 & 52-026**

**Completion Plan for Uncompleted ITAAC 3.3.00.07d.iii.c [Index Number 805]**

## **ITAAC Statement**

### **Design Commitment**

7.d) Physical separation is maintained between Class 1E divisions and between Class 1E divisions and non-Class 1E cables.

### **Inspections, Tests, Analyses**

Inspections of the as-built raceways that route Class 1E cables will be performed to confirm that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

iii) Where minimum separation distances are not maintained, the circuits are run in enclosed raceways or barriers are provided.

### **Acceptance Criteria**

Results of the inspection will confirm that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

iii.c) Where minimum separation distances are not met inside the radiologically controlled area of the auxiliary building, the circuits are run in enclosed raceways or barriers are provided.

## **ITAAC Completion Description**

Multiple ITAAC are performed to ensure that physical separation is maintained between Class 1E divisions and between Class 1E divisions and non-Class 1E cables. In accordance with this ITAAC, physical separation for circuits that do not meet the separation distance criteria of ITAAC 3.3.00.07d.ii.c may be provided by enclosed raceways or barriers. For circuits requiring enclosed raceways or barriers, the subject ITAAC requires inspections of the raceways that route Class 1E cables and raceways that route non-Class 1E cables inside the radiologically controlled area of the auxiliary building to confirm that circuits are run in enclosed raceways or have barriers provided. The Class 1E cables and raceways and non-Class 1E cables inside the radiologically controlled area of the auxiliary building are designed to be appropriately separated in accordance with APP-GW-E1-001 (Reference 1). Installation Specifications provided to the constructor identify the separation criteria, consistent with the ITAAC commitment.

Class 1E electrical cables and raceways are installed in accordance with design drawings, installation specifications issued for construction and work package requirements. Completed raceway installation, in-progress cable installation, and completed cable terminations are inspected to ensure the separation installation specifications are satisfied. Inspections are performed in accordance with the Construction Quality Verification Program 26139-000-4MP-T81C-N7101 (Reference 2). The completed inspection records document the satisfactory separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables.

Cable Separation Reports XXX (References 3 and 4) identify the inspection reports associated with the raceway separation inspections and confirm that the separation between raceways that route Class 1E cables of different divisions, and between raceways that route Class 1E cables and raceways that route non-Class 1E cables is consistent with the following:

Where minimum separation distances are not maintained inside the radiologically controlled area of the auxiliary building, the circuits are run in enclosed raceways or barriers are provided.

Exceptions to the subject ITAAC are not included within the scope of this ITAAC and are addressed within the scope of ITAAC 3.3.00.07d.iv.c (Enclosure 3) or ITAAC 3.3.00.07d.v.c (Enclosure 4).

The Cable Separation Reports (References 3 and 4) are available for NRC inspection as part of the Unit 3 and Unit 4 ITAAC 3.3.00.07d.iii.c Completion Packages (References 5 and 6, respectively).

### **List of ITAAC Findings**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all ITAAC findings and associated corrective actions. This review found no relevant ITAAC findings associated with this ITAAC.

### **References (available for NRC inspection)**

1. APP-GW-E1-001, Electrical Systems Design Criteria
2. 26139-000-4MP-T81C-N7101, Bechtel Construction Quality Verification Program
3. Unit 3 Cable Separation Report XXX
4. Unit 4 Cable Separation Report XXX
5. Unit 3 ITAAC 3.3.00.07d.iii.c Completion Package
6. Unit 4 ITAAC 3.3.00.07d.iii.c Completion Package
7. NEI 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52"