



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
P.O. Box-415
Trenton, NJ 08625-0415

October 19, 1998

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station Unit-1 and 2
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S95-34

The subject request was submitted to the NRC by PSE&G letter dated September 17, 1998. The request proposes to modify Technical Specification (TS) 3.8.2.2 Electrical Power Sources, 3.8.2.4 125-volt DC Distribution - Shutdown, and 3.8.2.6 28-volt DC Distribution - Shutdown, to delete the requirement for establishing Containment Integrity during irradiated fuel movement when certain electrical power sources are not available. 1/0
A-001

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Dennis J. Zannoni/KS

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

9811030174 981019
PDR ADOCK 05000272
P PDR

000026

c.: Distribution

Jill Lipoti
NJ DEP

D. Zannoni
NJ DEP

R. Bores
NRC Region I State Liaison Officer

S. Morris
NRC Sr. Resident Inspector

P. Milano
NRC Sr. Project Manager

D. Powell
PSE&G