



## State of New Jersey

Christine Todd Whitman  
Governor

Department of Environmental Protection  
Division of Environmental Safety, Health,  
and Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
PO Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700

Robert C. Shinn, Jr.  
Commissioner

February 25, 1999

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Ladies and Gentlemen:

Subject: Salem Generating Station Units 1 and 2  
Docket Nos. 50-272 and 50-311  
License Change Request S95-18  
AC Distribution System

Public Service Electric and Gas Company (PSE&G) submitted the subject change request to the Nuclear Regulatory Commission on March 26, 1998. The proposed change would incorporate operating requirements on the 'D' 115 Volt Vital Instrument Bus and Inverter into the Technical Specifications. These operating requirements were committed to in response to NRC Generic Letter 91-11 and are currently contained in a PSE&G Technical Specification Interpretation. Since this is the last interpretation in existence for Salem, the interpretations will be eliminated once this change is approved by the NRC.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the above request in accordance with the requirements of 10 CFR 50.91(b). We have no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

*Kent Tosch*

Kent Tosch, Manager  
Bureau of Nuclear Engineering

090093  
9903110060 990225  
PDR ADDCK 05000272  
P PDR

Distribution:

Jill Lipoti, Ph. D.  
N.J. DEP

Dennis Zannoni  
N.J. DEP

R. Bores, Ph. D.  
NRC Region I State Liaison Officer

P. Milano  
NRC Project Manager

D. Powell  
PSE&G