



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection
Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
PO Box 415
Trenton, NJ 08625-0415

Robert C. Shinn, Jr.
Commissioner

June 3, 1999

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station Units -1 and 2
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S99-05

The subject request was submitted to the NRC by PSE&G letter dated April 14, 1999. The request proposes to modify Technical Specifications which will allow industry standard testing of the Fuel Handling Area Ventilation System, deletion of the safety related automatic function of the High Radiation Alarm, and deletion of outdated surveillance tests.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

1000/10

9906090071 990603
PDR ADDCK 05000272
P PDR

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

S. Morris
NRC Sr. Resident Inspector

P. Milano
NRC Sr. Project Manager

D. Powell
PSE&G