



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

June 22, 1999

New Jersey Department of
Environmental Protection
Division of Water Quality
Bureau of Permit Management
P.O. Box 029
Trenton, NJ 08625-0029
Certified Mail Number Z 314 291 123

**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORTS
SALEM GENERATING STATION
PERMIT NO. NJ0005622**

Attached is the Discharge Monitoring Report for Salem Generating Station containing the information as required in Permit No. NJ0005622, for the month of May 1999.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analyses required to be performed by the above agencies. The choice of the measurement devices and analytical methods is controlled by EPA and NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or any reading or analytical result represents, the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

Sincerely,

David F. Garchow
General Manager -
Salem Operations

11

Attachments

9907010222 990622
PDR ADDCK 05000272
R PDR

IE-25

- C Executive Director - DRBC
- USNRC - Document Control Desk Unit#1-50-272 Unit#2-50-311
- General Manager - Salem Operations
- Director - Licensing, Regulation, and Fuels
- M. Vaskis
- D. Hurka
- J. Schloss
- Central Record Facility
- E. Keating

**NJPDES Report
Explanation of Deviations
May 1999**

The following explanations are included to clarify possible deviations from permit conditions.

General - The columns labeled, "No. Ex. " on the enclosed DMR, tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

All reported concentrations are based on daily discharge values.

Total residual chlorine is performed three times per week during chlorination unless otherwise indicated.

Analytical values which are less than detectable are reported as zero unless otherwise indicated.

Analytical results for all parameters other than pH, temperature, TSS, TRC and Bioassay results are provided by Raytheon Environmental Services Laboratory. (NJDEP certification 77343) or South Jersey Testing Laboratory (NJDEP certification 06431). Bioassay results are provided by New England Bioassay, Inc. (NJDEP certification 46405).

Net negative discharge values are reported as negative.

489C- Flow thru outfall 489 is calculated based on Oil Water Separator Lift Pump run times.

481-486 - Chlorination of the circulation water system normally does not occur except as otherwise noted. Service water system chlorination is normally continuous and is monitored on the circulating water system outfall.

Chlorination of both systems will be indicated by results reported for both and represents their combined effect upon the circulating water outfall.

NJPDES Report
Explanation of Deviations
May 1999

48C - Non-Radioactive Liquid Waste - This system continues to be operated in a batch mode to treat for hydrazine and ammonia by the addition of sodium hypochlorite. No hydrazine has been discharged from this outfall during the reporting period. Residual chlorine is monitored at the outfalls of DSN's 481, 482, 484, and 485, and has not exceeded the permit limits at these outfalls.


The following excursions are included in the attached report and are explained below. Excursions have not endangered nor significantly impacted public health or the environment.

<u>DSN NO.</u>	<u>EXPLANATION</u>
	None

COUNTY OF SALEM
STATE OF NEW JERSEY

I, David F. Garchow, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am General Manager of Salem Generating Station, and as such, am authorized to sign Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I have reviewed the attached Discharge Monitoring Reports. Pursuant to N.J. A. C. 7:14A-2.4, I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that based on my inquiry of those individuals responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



David F. Garchow
General Manager
Salem Operations

Sworn and subscribed before me
this 17 day of June 1999



BARBARA VAN WAGNER
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires Nov. 1, 1999
ID# 2171611



MAPLEWOOD TESTING SERVICES REPORT

TO: Dave Hurka
Sr. Staff Engineer - Nuclear
PSE&G

May 12, 1999
Report No. TP99016

**SUBJECT: DETERMINATION OF CIRCULATING WATER FLOW AT SALEM
GENERATING STATION - UNIT NO.1**

CONDUCTED BY: Joseph Fiumara
Sr. Test Engineer, Maplewood Testing Services

PURPOSE

To determine the flow capacities of the Unit No.1 circulating water pumps.

SUMMARY

On May 4 and 5, 1999 the Mechanical Division of Maplewood Testing Services conducted a series of test runs at Salem Unit No.1 to determine the pump capacities of the 11A, 11B, 12A, 12B, 13A and 13B (CMS designations H, J, K, E, L and A respectively) circulating water pumps.

Final test results are shown in Table 1 and Figure 1.

DISCUSSION


Discharge pressures could not be measured at the pump due to plugged feeler lines. The total dynamic heads reported were calculated using the pressures measured at the inlet water boxes which were lower than the pump discharge pressures. The difference in pressure is a result of losses in the piping between the pumps and the waterboxes.

Dave Hurka
Sr. Staff Engineer - Nuclear
PSE&G


May 12, 1999
Report No. TP99016

TEST METHOD

The circulating water flow was determined by fluorometry using MTS Mechanical Division Procedure Mech-40 "Determination of Water Flow Using The Turner Fluorometer". In fluorometry, a dye containing fluorescent particles is injected at a known flow rate sufficiently upstream to insure complete mixing. Dilution of the dye is measured downstream by a fluorometer and the flow is determined as a ratio.



Manager
Mechanical Division



Senior Supervising Test Engineer
Mechanical Division

cc F. Todd
M. Welker

F:\MAG\TP99016\TP99016.DOC

Table 1
Salem Generating Station
Circulating Water Pump Flow Test

Maplewood Testing Services
Mechanical Division

Report Number TP99016

SUMMARY OF TEST RESULTS

Pump No.	CMS Pump Desig.	Test Date	Measured Pump Capacity (gpm)	Pump Suction Head (ft h ₂ o)	Pump Discharge Head (ft h ₂ o)	Total Dynamic Head (ft h ₂ o)
11A	H	05/04/99	164,238	-8.6	15.6	24.2
11B	J	05/04/99	168,671	-9.4	11.5	20.9
12A	K	05/05/99	170,092	-12.5	12.5	25.0
12B	E	05/05/99	169,131	-12.3	10.8	23.1
13A	L	05/05/99	172,014	-11.5	8.2	19.7
13B	A	05/05/99	177,895	-10.6	9.2	19.8

Note: Pump suction heads and discharge heads corrected to elevation 100'

SALEM GENERATING STATION - UNIT NO.1 TOTAL PUMP HEAD VS. CIRCULATING WATER PUMP FLOW

