



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection
Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
PO Box 415
Trenton, NJ 08625-0415

Robert C. Shinn, Jr.
Commissioner

October 5, 1999

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station Units -1 and 2
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S99-07

The subject request was submitted to the NRC by PSE&G letter dated August 25, 1999. The request proposes to permit the use of a non-Class 1E single cell battery charger to be applied to operable class 1E batteries in the 28 volt and 125 volt DC battery banks.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

1/0

A001

250053
9910260178 991005
PDR ADOCK 05000272
P PDR

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

S. Morris
NRC Sr. Resident Inspector

P. Milano
NRC Sr. Project Manager

G. Saloman
PSE&G