

FOR ACTION/INFORMATION

BRANCH CHIEF:	Ziemann		
W/3 CYS FOR ACTION			
LIC. ASST.:	Diggs		
W/1 CYS			
ACRS 16 CYS HOLDING/SENT	As. CAT B		

INTERNAL DISTRIBUTION

<u>REG FILE</u>			
NRC PDR			
I & E (2)			
MIPC			
SCHROEDER/IPPOLITO			
HOUSTON			
NOVAK/CHECK			
GRIMES			
CASE			
BUTLER			
HANAUER			
TEDESCO/MACCARY			
EISENHUT			
BAER			
SHAO			
VOLLMER/BUNCH			
KREGER/J. COLLINS			

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Ft Pierce, Fla			
TIC:			
NSIC:			

335
A04

770.750205

60

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:
Mr. Norman C. Moseley

FROM:
Florida Power & Light Company
Miami, Florida
A. D. Schmidt

DATE OF DOCUMENT
2/25/77

DATE RECEIVED
3/14/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED
One signed

DESCRIPTION

Ltr. trans the following:

PLANT NAME:
St. Lucie Unit No. 1

RJL

ENCLOSURE

Licensee Event Report (RO 50-335-77-5) on 1/25/77 concerning the two MFP discharge valves not reopening after closing on a Main Steam Isolation Signal.....


(1-P) (2-P)

ACKNOWLEDGED
DO NOT REMOVE

SAFETY		FOR ACTION/INFORMATION		ENVIRO	
ASSIGNED AD:				ASSIGNED AD:	
BRANCH CHIEF:				BRANCH CHIEF:	
PROJECT MANAGER:				PROJECT MANAGER:	
LIC. ASST. :				LIC. ASST. :	

INTERNAL DISTRIBUTION			
REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
I- & E	SCHROEDER	BENAROYA	DENTON & MILLER
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	YOUNGBLOOD
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION			CONTROL NUMBER
LPDR:	NAT. LAB:	BROOKHAVEN NAT. LAB.	770250205
TIC:	REG V. IE	ULRIKSON (ORNL)	
NSIC:	LA PDR		
ASLB:	CONSULTANTS:		
ACRS CYS HOLDING/SENT			





LABORATORY DOCKET FILE COPY

February 25, 1977

PRN-LI-77-43

Mr. Norman C. Moseley, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
230 Peachtree Street, N.W., Suite 1217
Atlanta, Georgia 30303



Dear Mr. Moseley:

REPORTABLE OCCURRENCE 335-77-3
ST. LUCIE UNIT 1
DATE OF OCCURRENCE: JANUARY 25, 1977

MSIS CIRCUIT

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,

A. D. Schmidt
Vice President
Power Resources

MAS/cmp

Attachment

cc: Robert Lowenstein, Esquire
Director, Office of Inspection and Enforcement (30)
Director, Office of Management Information and
Program Control (3)

2629

770750205

US A E I
REGULATORY OPERATIONS
REGION II
ATLANTA, GA.

MAR 2 9 31 AM '77

LICENSEE EVENT REPORT

CONTROL BLOCK:

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME 01 F L S L S I						LICENSE NUMBER 00-00000-000						LICENSE TYPE 41111				EVENT TYPE 03	
CATEGORY 01 CONT		REPORT TYPE L		REPORT SOURCE L		DOCKET NUMBER 050-0335				EVENT DATE 012577				REPORT DATE 022577			

EVENT DESCRIPTION

02 During a review of the Main Feed Pump (MFP) control circuitry which had been undertaken
03 due to spurious pump trips, it was determined that the two MFP discharge valves could
04 reopen (cycle) after closing on a Main Steam Isolation Signal (MSIS) under the follow-
05 ing conditions: (1) MFP continues to run, (2) a Safety Injection Actuation Signal
06 (SIAS) is NOT present. Upon reaching full open, the valves would close if a MSIS were

SYSTEM CODE CD		CAUSE CODE B		COMPONENT CODE ZZZZZ				PRIME COMPONENT SUPPLIER Z		COMPONENT MANUFACTURER Z999			VIOLATION N	
-------------------	--	-----------------	--	-------------------------	--	--	--	-------------------------------	--	--------------------------------	--	--	----------------	--

CAUSE DESCRIPTION

08 The as-built control circuitry did not fully meet the design intent. On January 25,
09 1977, after Plant Facility Review Group and Company Nuclear Review Board approval, a
10 control circuit lead was lifted for each valve to ensure that the valves would remain

FACILITY STATUS B		% POWER 080		OTHER STATUS NA		METHOD OF DISCOVERY C		DISCOVERY DESCRIPTION NA			
FORM OF ACTIVITY RELEASED Z		CONTENT OF RELEASE Z		AMOUNT OF ACTIVITY NA		LOCATION OF RELEASE NA					

PERSONNEL EXPOSURES

NUMBER 000		TYPE Z		DESCRIPTION NA			
---------------	--	-----------	--	-------------------	--	--	--

PERSONNEL INJURIES

NUMBER 000		DESCRIPTION NA			
---------------	--	-------------------	--	--	--

PROBABLE CONSEQUENCES

15 Since these valves are redundant backups to the Main Feed Block Valves and since a Main

LOSS OR DAMAGE TO FACILITY

TYPE Z		DESCRIPTION NA			
-----------	--	-------------------	--	--	--

PUBLICITY

PUBLICITY NA	
-----------------	--

ADDITIONAL FACTORS

18 See Page 2 for continuation of Event Description, Cause Description, and Probable
19 Consequences.

NAME: M. A. Schoppman

PHONE: 305/552-3779



Faint, illegible text or markings in the top right corner of the page.

Event Description (continued)

still present. This was the second occurrence of this type involving a safeguards (ESFAS) design problem (see LER 335-76-3 dated March 18, 1976), however, the first occurrence involved ESFAS response on loss of power, and the two events are not considered to be generically related. (335-77-5).

Cause Description (continued)

closed when required. This interim fix was determined not to involve an unreviewed safety question per 10 CFR 50.59 as it implemented the original design intent of the Final Safety Analysis Report and did not affect any other accident analysis. Final corrective action was to permanently modify the circuits in accordance with 10 CFR 50.59 to meet the design intent. (335-77-5)

Probable Consequences (continued)

Steam line rupture would most likely initiate SIAS as well as MSIS, the probability of the valves not remaining closed was low.

REGULATORY OPERATIONS
REGION II
ATLANTA, GA.

MAR 2 9 31 AM '77