

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | V | A | S | P | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T 01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 8 | 0 | 7 | 1 | 2 | 2 | 0 | 7 | 8 | 8 | 0 | 1 | 0 | 2 | 7 | 9 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | On 12-20-78 Westinghouse notified Vepco of an input error in the currently applicable
03 | LOCA-ECCS analysis. The error was estimated to result in an increase in peak clad
04 | temperature of approximately 20°F. Further investigation revealed that the analysis
05 | input was correct but a modeling methodology which was slightly different from the
06 | methodology applied in the NRC approved Westinghouse ECCS Evaluation Model (Feb. 1978
07 | version) was being used. This is reportable per Tech. Spec. 6.6.2.a.(8). The
08 | health and safety of the public were not affected.

09 | SYSTEM CODE | X | X | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | X | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16 | LER/RO REPORT NUMBER | 17 | 7 | 8 | 21 | 22 | SHUTDOWN METHOD | Z | 21 | 36 | HOURS | 22 | 0 | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | Y | 23 | 41 | NPRD-4 FORM SUB. | N | 24 | 42 | PRIME COMP. SUPPLIER | Z | 25 | 43 | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 | 9 | 26 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | The margin to the Technical Specification limit on FQ and to the 10 CFR 50.46 limits
11 | was assessed and found to be sufficiently conservative to accommodate the above non-
12 | conservatism. A new analysis with the February 1978 Westinghouse LOCA-ECCS evaluation
13 | model, which includes more conservative modeling methodology was performed and has
14 | been submitted to the Nuclear Regulatory Commission for approval.

15 | FACILITY STATUS | G | 28 | 9 | % POWER | 0 | 0 | 0 | 0 | 29 | 12 | OTHER STATUS | NA | 30 | 13 | METHOD OF DISCOVERY | D | 31 | 45 | DISCOVERY DESCRIPTION | NSS Vendor Notification | 32 | 46

16 | ACTIVITY CONTENT | Z | 33 | 9 | RELEASED OF RELEASE | Z | 34 | 10 | AMOUNT OF ACTIVITY | NA | 35 | 11 | LOCATION OF RELEASE | NA | 36 | 44

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | 11 | TYPE | Z | 38 | 12 | DESCRIPTION | NA | 39 | 13

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | 11 | DESCRIPTION | NA | 41 | 12

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | 11 | DESCRIPTION | NA | 43 | 12

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | 10 | DESCRIPTION | NA | 45 | 11

7901080191

NRC USE ONLY

NAME OF PREPARER W. L. Stewart

PHONE: (804) 357-3184

Surry Power Station, Unit 1
Docket No: 50-280
Report No: 78-050/01T-0
Title of Report: LOCA-ECCS Analysis

1. Description of Event:

On 12-20-78 Westinghouse notified Vepco of an input error in the currently applicable LOCA-ECCS analysis. The error was estimated to result in an increase in peak clad temperature of approximately 20°F. Further investigation revealed that the analysis input was correct but a modeling methodology which was slightly different from the methodology applied in the NRC approved Westinghouse ECCS Evaluation Model (Feb. 1978 version) was being used.

2. Probable Consequences:

Because there is sufficient margin in the currently applicable LOCA-ECCS to accommodate this non-conservatism, there are no probable consequences of this event.

3. Cause of Event:

The cause of this event is an alternate modeling methodology used in analyzing containment pressure response effects resulting from the broken loop accumulator flow.

4. Immediate Corrective Actions:

The margin to the Technical Specification Limit on F_0 and the 10 CFR 50.46 limits was assessed and found to be sufficiently conservative to accommodate the above non-conservatism.

5. Subsequent Corrective Actions:

A new analysis performed with the February 1978 Westinghouse LOCA-ECCS evaluation model, which includes more conservative modeling methodology, has been submitted to the Nuclear Regulatory Commission for approval.

6. Actions Taken to Prevent Recurrence:

None necessary.

7. Generic Implications:

None.