

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

January 19, 1979

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Albert Schwencer, Chief  
Operating Reactors Branch No. 1  
Division of Reactor Licensing  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Serial No. 036  
LQA/RMN:esh

Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Dear Mr. Denton:

AMENDMENT TO OPERATING LICENSE  
SURRY POWER STATION UNIT NOS. 1 AND 2  
PROPOSED TECHNICAL SPECIFICATION CHANGE NO. 71  
ADDITIONAL INFORMATION

Our letter of December 28, 1978, Serial Number 737, contained an error in the attached proposed Technical Specifications. Please substitute the attached page for the page TS 6.4-7a previously submitted.

Very truly yours,

C. M. Stallings  
Vice President-Power Supply  
and Production Operations

Attachment:  
Proposed Technical Specification

cc: Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
Region II

REGULATORY DOCKET FILE COPY

7901230207

App  
S  
1/1

- D. All procedures described in A and b above shall be followed.
- E. Temporary changes to procedures described in A and B above which do not change the intent of the original procedure may be made, provided such changes are approved prior to implementation by the person designated below based on the type of procedure to be changed:

1. Administrative	Station Manager
2. Abnormal	Shift Supervisor
3. Annunciator	Shift Supervisor
4. Health Physics	*Health Physicists
5. Emergency	Shift Supervisor
6. Electrical Maintenance	*Electrical Foreman
7. Mechanical Maintenance	*Mechanical Foreman
8. Operating	Shift Supervisor
9. Periodic Test	*Cognizant supervisor
10. Start-up Test	*Engineering Supervisor
11. Special Test	*Engineering Supervisor
12. Quality Assurance	Resident Quality Control Engineer
13. Chemistry	*Chemist

\*These procedures must have the approval of a licensed Senior Reactor Operator.

Such changes will be documented and subsequently reviewed by the Station Nuclear Safety and Operating Committee and approved by the Station Manager within fourteen days.

- F. Temporary changes to procedures described in A and B above which change the intent of the original procedure may be made, provided such changes are approved prior to implementation by the person designated below based on the type of procedure to be changed.